

Received March 26, 2020, accepted April 17, 2020, date of publication May 6, 2020, date of current version May 28, 2020.

Digital Object Identifier 10.1109/ACCESS.2020.2992654

# Optimal Sizing of Battery Energy Storage for Grid-Connected and Isolated Wind-Penetrated Microgrid

UMAR T. SALMAN<sup>1</sup>, (Student Member, IEEE),

FAHAD SALEH AL-ISMAIL<sup>1</sup>, (Senior Member, IEEE),

AND MUHAMMAD KHALID<sup>1</sup>, (Senior Member, IEEE)

Electrical Engineering Department, King Fahd University of Petroleum and Minerals, Dhahran 31261, Saudi Arabia

King Abdullah City for Atomic and Renewable Energy (K. A. CARE) Energy Research and Innovation Center, Dhahran 31261, Saudi Arabia

Corresponding author: Umar T. Salman (g201706090@kfupm.edu.sa)

The author(s) would like to acknowledge the support provided by the Deanship of Scientific Research (DSR) at King Fahd University of Petroleum & Minerals (KFUPM) for funding this work through project No. DF181035. Also the funding support provided by the K.A.CARE Energy Research & Innovation Center (ERIC).

**ABSTRACT** Renewable energy (RE) sources, particularly wind and solar are gaining more popularity due to their inherent benefits, consequently, nations have set ambitious goals to enhance the penetration of RE into their energy-mix. However, the RE sources especially wind and photovoltaic sources are intermittent, uncertain, and unpredictable. Therefore, there is a need to optimize their usage when they are available. Moreover, energy storage system like battery energy storage has much potential to support the RE integration with the power grid. This study, therefore, investigates the sizes of battery energy storage required to support a grid-connected microgrid and a stand-alone microgrid for 12 months considering hourly wind power potential. In this study, we have considered three Scenarios of operations and have determined the BESS sizes and recommend the best based on the cost of operation. Scenarios 1 and 2 are grid-connected configuration while Scenario 3 is a standalone microgrid supported with diesel generators. In each Scenario, the optimization problem is formulated based on the optimal operation cost of the microgrids. The powers consumed from the main grid are reported in Scenarios 1 & 2 and the extra cost spent on the maintenance of diesel generators is reported in Scenario 3. The study evaluates and analyzes the operational environmental effects and costs between the three Scenarios. The formulated problems are solved using the nonlinear optimization method. Simulations results proved the effectiveness of the study.

**INDEX TERMS** Energy capacity, energy storage system, renewable energy, power capacity, optimal sizes, wind power.

## I. INTRODUCTION

Wind power is gaining more popularity in recent years as many countries are endeavoring to explore the wind power potential in terms of integration into the microgrid. It was reported in [1] that the renewable power capacity of the world increased by 8% in 2018 alone with more than 90 countries have added up to 1GW of renewable power out of which more than 30 had above 10GW. The global renewable power capacity trends is in shown in Figure 1. Besides, the electricity sector seems to be the hottest spot for renewable energy like

wind power and photovoltaic (PV) to thrive following the growing installation of wind and PV across the world [1].

Moreover, with the growth in electricity demand across the world, there are pressures on the need to find alternative clean sources of electricity to replace or to be added to the existing fossil fuel sources which is currently under the pressure of being faced out due to its popular greenhouse gases' emissions known to be hazardous to our friendly environment. Following the reports of the installation of more renewable generation (including wind and PV) than fossil fuel generation across the world [1], [2], there are corresponding reports that the price of electricity is becoming cheaper and emission of greenhouse gasses due to electricity generation are also decreasing [3].

The associate editor coordinating the review of this manuscript and approving it for publication was Dwarkadas Pralhaddas Kothari.




FIGURE 1. Renewables 2019 Global status report [1].

An important aspect of renewable power generation is its integration with the existing utility system. To achieve this, microgrids are built to form many interconnected systems. The microgrid has good features that make it work efficiently to support a constant varying load. Thanks to ESS like BESS which can be employed to support the microgrid for its smooth operation. However, the grid-connected microgrid relies on the support from the main grid during load variation and fluctuations from the RES at a given time. The microgrid is characterized by some features which makes it very reliable and efficient in its operation. These features include distributed generators like diesel generator or thermal plants, storage systems, and dumped load [4]. Furthermore, these features differentiate microgrids from centralized systems. The centralized systems are made of conventional generators and interconnection of transmission lines. Unlike in microgrid systems, where the cost of operation is extremely minimal because the operation cost is nearly negligible, the centralized system is far more expensive in terms of operation and maintenance. An interconnected system of a future distribution utility grid system is shown in Figure 2.

Also, a key component of the microgrid system is the ESS which provides great support for the microgrid during its operation. For example, the BESS performs the job of load leveling, peak shifting to support the peak demand [5]. Under these conditions, the ESS itself acts as a load. Besides, ESS can store electricity from the grid at times when the price of electricity is low and is sold to the customers at times of high prices. This provides a good economic benefit for the microgrid operators. Different types of storage technologies and their applications have been discussed in [5], [6]. ESS have different features, for example, some of the technologies differ in charging and discharging rates, energy, and power capacity characteristics [7], [8]. Consequently, storage technologies differ in sizes and weights. Figure 5 shows a comparison of the characteristics of different ESS technologies.

It is important to find the optimal size of the ESS during the operation of a microgrid. This is because the ESS especially BESS are expensive in terms of MW and MWh. Besides the overall economic cost of operation of the microgrid include




FIGURE 2. A typical microgrid [9].

the investment on the ESS. To find the optimal size of BESS, several strategies have been proposed in [10]–[16]. Besides, a critical review of energy management systems in microgrid was presented [17], the study discussed different methods, solutions, and benefits in microgrid management. The authors did an analysis of certain decisions for managing the uncertainty and intermittency that are associated with RE sources and demand. Moreover, the study discussed the implementation of cost-effective based on communication technology for future and real-world problems. In [12], a life cycle planning methodology of BESS in microgrids was presented and the optimal sizes of BESS were obtained under multi-scaled decision parameters to meet the demand growth. The authors in [13] find the optimal values of BESS for an islanded DC microgrid using an incremental cost approach while the authors in [16] used the convex optimization technique for minimization of the unit a unit commitment problem. However, the study in [13] evaluates the feasibility of installing a given battery unit to achieve the minimum running cost. In [14], the authors consider the efficiency of power supply probability and energy cost to size the BESS using the grasshopper optimization algorithm. The study was done under an islanded operated microgrid penetrated with wind, solar PV and diesel generators, and its results were compared with other metaheuristic optimizers.

Authors in [18] have done the optimizing of BESS in hybrid wind and solar for a grid-connected microgrid system. The study carried out source-sizing and battery sizing to maximize reliability and minimize cost. In [19], the authors proposed a power exchange strategy based on a schedule pattern between regions for determining power-sharing between BESS and distributed generators in a wind penetrated islanded microgrid. In [20], a double layer strategy was developed for the sizing of BESS in an energy management strategy for an islanded microgrid. The developed model was divided into an outer and inner loop, the optimization problem is then solved using iterative and dynamic programming method. Authors in [10], [21] considered the battery life of BESS in a wind-ESS penetrated microgrid. In [21], the component sizing of the lithium battery was done by formulating an objective function based on capacity degradation of the BESS and operation cost of the BESS. Simulations

done by the rule-based and genetic algorithm showed that the operation cost was well optimized. Besides authors in [10] considers the depth of discharge of the BESS when modeling the real-time battery operation cost. The firefly algorithm used for the simulation shows that the operation cost was well minimized.

Authors in [22]–[25] have discussed the methods of integration of REGs into the distribution systems. In [26], a review of Optimal planning of distributed generation in distribution systems was presented. The study reviewed the effect of operating characteristics and conditions of the DG system such as voltage profile, electric losses, reliability, and stability. Although the sizing of BESS for wind energy has been done in literature, there are only a few studies that compare the cases presented in this paper. Moreover, this study evaluates the effect of monthly variation of wind power from the studied site.

M. F. Zia *et al* [27] presented a study of operational planning of scalable DC microgrid, the study considered the effect of costs due to battery degradation, demand response and islanding operation of the microgrid. The authors argued that their findings could aid the future implementation of DC microgrids. Although the study computed levelized cost in cold and hot climate regions with special consideration for losses in the systems and nodal voltages, the study neither reports the rated energy and rated power nor the actual months referred to as the cold or hot weather. Furthermore, only a few of the studies reviewed so far have considered the specific scenarios investigated in this study.

This paper, therefore, presents the sizing of BESS for a wind penetrated grid-connected microgrid and stand-alone microgrid for 12 calendar months. Optimization was done for 24 hours using the methods of linear programming and nonlinear programming each month under the three Scenarios considered and based on the operation cost of the microgrid. Also, the rated energy capacities, rated power capacities of BESS, and optimal operation costs of the microgrid were computed for all scenarios. Besides, the case study considered in this study has a unique wind profile and has shown characteristics with interesting results.

The uniqueness of the work in this study are summarized as follows: (1) Our study carried out sizing and observation of BESS for 12 calendar months; taking note of the variability that exists within each month in terms of operation cost and BESS investment. (2) The case study considered in this study is unique in that the wind data obtained from the Khafji site shows unusual characteristics when compared with data obtained from other sites. For example, wind power in the month of June and July are so high that we have had to introduce dump loads and the effects of the dump load are observed. (3) Finally, the assumed scenarios in this study differentiate our study from many others seen in the literature. Our findings suggest where future improvement could be examined.

The rest of this paper is organized as follows: Section II presents the problem formulation and the studied Scenarios.




FIGURE 3. The proposed microgrid architecture.

Section III discussed the methodology and all assumed constraints are explained in this section. Section IV presents the case study used to test the proposed methodology, Section V shows the simulation results, and Section VI is the conclusion of the paper.

## II. PROBLEM FORMULATION

In the formulation of the proposed strategy, a wind power microgrid system of the types shown in Figure 3 is presented. The optimal operation cost of the microgrid is computed, leading to optimal sizes of energy capacity,  $E_b^{max}$  and power capacity,  $P_b^{max}$  of the BESS. In Scenario 1, the microgrid is grid-connected and the other sources of power apart from the windfarm are the grid and the BESS. The optimal sizes of BESS required to operate the microgrid optimally for 24 hours are computed. The microgrid is operated such that maximum power is consumed from the wind power  $P_w$ , and also to ensure that grid power,  $P_g$  imported is minimized as much as possible. In Scenario 2, the microgrid is off-grid but three diesel generators are used as backups for the system. It is desired that the generators operate for minimum times so that power  $P_i$ , is only consumed from a unit  $i$ , this ensures that wind power is efficiently utilized. The BESS is connected to the microgrid at the point of common coupling. Charging and discharging of the BESS takes place through the power converters which allow for proper control during smooth operation, however, the converter topologies and their control are not discussed in this paper. In both Scenarios, the BESS is discharged during hours of high demand  $P_D$  and or lower  $P_w$ , and it is charged during the hours of low demand and or higher wind output. However, the BESS power,  $P_b$  and energy,  $E_b$  at any time during its operation are maintained between  $P_b^{max}$  and  $E_b^{max}$ .

In order to prevent over-charging and consequently over-sizing of the BESS during the hours of high generation from the wind farm, the excess power is allowed to dispatch through the dump load,  $P_{dump}$  attached to the microgrid in Figure 3. These strategies adopted ensured efficient power management optimal sizing of the BESS within the microgrid. A flowchart showing a brief description of the algorithm used to solve the optimization problems is shown




FIGURE 4. Flowchart of the optimization algorithm.

in Figure 4. The adopted strategies in this paper summarized into Scenarios 1, 2 and 3 are as follows:

1) SCENARIO 1

It is assumed that the wind farm can supply substantial power to meet the demand at any point in time, the microgrid is grid-connected and the excess power can be sold to the grid. However, if the wind source is not enough to meet the demand, power can be bought from the grid to meet the supply or to charge the BESS.

2) SCENARIO 2

There is enough power from the wind farm to meet the load, the BESS is fully charged but the grid is not ready to buy power from the microgrid. So the excess power is dispatch through the dump load to prevent overcharging and oversizing of the BESS.

3) SCENARIO 3

The microgrid is off-grid, three diesel generators are connected to support the wind farm and the BESS. The generators start to operate only when the output from the wind farm is low and where the SOC of the BESS is low.

A. HYBRID MICROGRID SYSTEM

A microgrid system having three subsystems: power generation, power distribution, and power demand is called an isolated hybrid microgrid system. If a hybrid microgrid is connected to the main grid, then it is called a grid-connected hybrid microgrid system. In this section, the components of a hybrid microgrid system made up of DER (wind, diesel generators, and energy storage system), grid, load profile (residential, commercial and school & offices), and the microgrid itself are presented. The DER and grid serve as the generation subsystem while the load profile serves as the load subsystem and the microgrid is the distribution subsystem. Furthermore, the cost model of each of the subsystems is discussed.

A typical microgrid showing the components of the mentioned subsystems is shown in 2.

B. THE WIND TURBINE SUBSYSTEM

Wind power,  $P_w$  is largely dependent on wind speed,  $v$  and the relationship between wind power and wind speed is cubical. The wind power  $P_{Wt}$ , at hour  $t$ , is usually calculated from the wind speed [28] as presented (2).

The wind power, expressed in is given by the (1).

$$P_w = \frac{1}{2} \times K_{max} \times \rho \times A_f \times v^3 \quad (1)$$

where,  $A_f$  is the swept area by rotor of the wind turbine,  $\rho$  is the density of air and  $K_{max}$  is the power coefficient.

$$P_{Wt} = \begin{cases} 0 & v_t < v_{CI} \text{ or } v_t \geq v_{CO} \\ P_w^{max} \frac{v_t - v_{CI}}{v_R - v_{CI}} & v_{CI} \leq v_t < v_R \\ P_w^{max} & v_R \leq v_t < v_{CO} \end{cases} \quad (2)$$

The daily cost of wind power dissipation,  $C_{wt}$ , presented in [10] is given by the product of the initial cost of wind turbine and the power dispatch as in (3).

$$C_{WT} = \sum_{t=1}^T P_w(t) \times IC_{WT} \times CRF. \quad (3)$$

CRF is the capital recovery factor which can estimate the present value of the wind turbine with consideration given to lifetime of project and interest rate. This is expressed in (4).

$$CRF = \frac{1}{360} \times \frac{i_t(1+i_t)^y}{(1+i_t) - 1} \quad (4)$$

However,  $C_{WT}$  is given by (5). Where  $VWC$  is the value of wind curtailment and  $P_{wc}(t)$  is the wind power generation at time  $t$ .

$$C_{WT} = \sum_{t=1}^T VWC \times P_{wc}(t) \quad (5)$$

C. DIESEL GENERATOR

A diesel generator in a microgrid acts as a backup source like energy storage when the available wind power cannot meet up with the demand. This way, it can improve the system's reliability and help to smooth the output power from the wind. In [10], [29], the operation cost of diesel generators in terms of power dispatch is calculated using the equation formulated in (8). This equation includes the fuel cost  $FC$  and emission cost,  $EM$ . The  $FC$  is expressed in (6) where  $a_i$ ,  $b_i$  and  $c_i$  are fuel cost coefficients of generator unit  $i$ . Furthermore, the emission cost is included as part of the operation cost of the diesel generator [29]. The  $EM$ , is given by (7). So that the total operating cost of the diesel generator units becomes (8),  $d_i$ ,  $e_i$  and  $f_i$  are emission cost coefficients of generator unit  $i$ . The parameters of the diesel generators used in this study are given in Table 1.

$$FC = \sum_{t=1}^T \sum_{i=1}^I [a_i P^2_{i,t} + b_i P_{i,t} + c_i] \quad (6)$$



TABLE 1. Diesel generator parameters.

Parameters/ Diesel gen.	$a$ (\$/MW <sup>2</sup> )	$b$ (\$/MW)	$c$ (\$)	$d$ (kg/MW <sup>2</sup> )	$e$ (kg/MW)	$f$ (\$)	$P_{min}$ MW	$P_{max}$ MW
g1	0.012	0.8	0.3	0.12	-0.25	0.7	0	2.5
g2	0.0017	0.75	0.5	0.15	-0.35	0.7	0	3
g3	0.015	0.85	0.2	0.1	-0.15	0.6	0	2.5

$$EM = \sum_{t=1}^T \sum_{i=1}^I [d_i P^2 i, t + e_i P i, t + f_i] \quad (7)$$

$$C_{d.gen} = FC + EM \quad (8)$$

where  $i$  is the unit index,  $I$  is the number of units,  $t$  is the hour index,  $T$  is the number of hours respectively. The quadratic function has been used to calculate the cost of the function of the generator because of the non-linearity of equation (6) which gives non-approximated results.

#### D. BATTERY ENERGY STORAGE MODEL

The BESS utilized in this paper is the lithium-ion based. The lithium-ion battery technology has a good power density, high energy density, high efficiency, and longer life cycle when compared with other technologies [30], [31]. Figure 5 shows the characteristics of some battery energy storage technologies. Principally the function of the BESS in a microgrid is to prevent power mismatch. It is known that the cost of ESS increases with an increase in depth of discharge (DOD) since the ESS discharge more powers. Moreover, a decrease in BESS discharge power leads to a decrease in the capacity of the ESS and consequently make the DOD be high. The formulation of the cost function of BESS power charge/discharge at any time  $t$  as a function DOD and battery power is presented in [10], [32]. However, the cost function utilized in this paper does not include DOD.

The state of charge of the BESS represented by SOC is given by (9). Where  $\eta_{BESS}^{cha}$  and  $\eta_{BESS}^{disch}$  represent the charging and discharging efficiencies of the BESS.  $\Delta t$  is the incremental time for the optimization and has been taken as 1 hour in this paper.

$$SOC_{BESS}(t + 1) = \frac{P_{BESS}^{cha} \times \Delta t \times \eta_{BESS}^{cha}}{E_{BESS}} - \frac{P_{BESS}^{disch} \times \Delta t}{E_{BESS} \times \eta_{BESS}^{disch}} \quad (9)$$

Equations (10) formulates the BESS investment cost. The unit prices of ESS power and energy are the parameters in this equation. Besides, the required optimal sizes of the BESS are the rated power and energy of the BESS and they represent the decision variables.

$$IC_{BESS} = PC_{BESS} P_{BESS}^{max} + EC_{BESS} E_{BESS}^{max} \quad (10)$$

where  $PC_{BESS}$  is the power cost of the BESS per one MW,  $P_{BESS}^{max}$  is the rated power of the BESS,  $EC_{BESS}$  is the energy cost of the BESS per megawatt-hour.  $P_{BESS}^{max}$  and  $E_{BESS}^{max}$  are respectively the rated power and rated energy of the BESS.




FIGURE 5. Characteristics of different ESS technologies [7].

#### E. MAIN GRID

The main grid, interchangeably used as the grid or utility in this paper acts as another source of power to the microgrid apart from the wind farm, BESS, and diesel generator. Power is either bought (imported) from or sold (exported) to the grid. To compute the cost of power exchanged with the main grid, (11) is proposed. We assume a positive convention for power imported from the grid and a negative sign for the power exported from the main grid. The cost of exchanged power,  $\eta$  with the utility is assumed to be \$20 per MW in this study. It is noted that the value of the objective function is more when power is imported and less when power is exported.

$$CMG_{ex} = \sum_{t=1}^T \eta P_{grid}(t) \quad (11)$$

The  $P_g(t)$  assumes a positive sign when power flows from the main grid to the microgrid and a negative when the power flows to the main grid from the microgrid.

#### F. DATA

The demand or load data in Figure 8 used for the formulation of the problem in this study is a real average load data made of residential, commercial, school and offices for the month of July from a city in Eastern province of KSA as obtained in [33], besides different categories of demand of Eastern region of Saudi Arabia is reported in [34]. The wind data correspond to the average data of the year 2018 from January to December measured at the Khafji site. Wind speed is measured at height of 50m at an average density of  $1.18Kg m^{-3}$  and temperature 43 degrees. The wind speed is shown in Figure 6 and the corresponding wind power calculated with a  $K_{max}$  of 0.45 is shown in Figure 7




FIGURE 6. Wind speed profile for calendar year 2018.




FIGURE 7. Wind power.

### III. PROPOSED METHODOLOGY

#### A. OBJECTIVE FUNCTION

The formulated problem in each Scenario is based on the overall cost of operation of the microgrid and the objective function is to minimize this cost. The objective function is expressed in (12). The optimization problems are solved using the linear programming and non-linear programming (quadratically constraint optimization) in GAMS software for Scenarios (1 & 2) and Scenario 3 respectively.

$$\min J = C_{WT} + C_{d.gen} + CMG_{ex} + IC_{ESS} \quad (12)$$

Furthermore the associated constraints are listed in the following subsections.

#### B. SYSTEM CONSTRAINTS

##### 1) BALANCE CONSTRAINT

The balance constraint is formulated as in (13):

$$\sum_{i=1}^I [P_i(t)] + P_{BESS}(t) + P_{grid}(t) + P_w(t) - P_{dump}(t) = P_D(t) \quad \forall t \in T \quad (13)$$

where  $P_D(t)$  is the power demand at instant of hour  $t$  and  $P_{dump}(t)$  is the dump load.  $P_{dump}(t)$  is chosen such that  $P_{dump}(t) < P_w(t) - P_D(t)$ . Noting that  $P_{dump}(t)$  is introduced in Scenario 2 and  $P_i(t)$  is introduced in Scenario 3.

##### 2) GRID CONSTRAINT

The exchanged power between the main grid and microgrid is limited because of the limit of the transmission line connecting the two systems. A constraint is needed to limit this power and it is dependent on the capacity of the transmission line.

$$-P_{grid}^{max} \leq P_{grid}(t) \leq P_{grid}^{max} \quad \forall t \in T \quad (14)$$

where  $P_M^{max}$  is the maximum capacity of the transmission line connecting between the microgrid and main grid.

##### 3) DIESEL GENERATOR CONSTRAINTS

The diesel generator output power are limited to the maximum and minimum output power of each of the generator. The constraint is expressed as:

$$P_i^{min} \leq P_i(t) \leq P_i^{max} \quad \forall i \in I, \forall t \in T \quad (15)$$

where  $P_i^{min}$  is the minimum power that can be produced by a unit DG  $i$ ,  $P_i^{max}$  is the maximum power that can be produced by unit DG  $i$  and  $I$  is the set of units.

#### 4) ENERGY STORAGE SYSTEM CONSTRAINTS

The BESS charging and discharging power is limited to its maximum power, which is its optimal size. The BESS acts as a load when it charges and acts as a generator when it discharges. Besides, it is assumed that when the BESS is in the charging mode, its power is negative and positive in the discharging mode. This constraint is formulated as:

$$P_{BESS}^{min} \leq P_{BESS}(t) \leq P_{BESS}^{max} \quad \forall t \in T \quad (16)$$

The stored energy in the BESS is limited by its rated energy. Of course, the stored energy is always positive. This constraint is formulated as:

$$E_{BESS}^{min} \leq E_{BESS}(t) \leq E_{BESS}^{max} \quad \forall t \in T \quad (17)$$

where  $E_{BESS}(t)$  is the energy stored in the BESS at hour  $t$ .

The equation to calculate the state of charge which essentially is the stored energy at a specific hour is formulated in (18). The  $\delta t$  is the unit optimization time which is equal to 1 hour in this study.

$$E_{BESS}(t) = E_{BESS}(t - 1) - P_{BESS}(t) \times \delta t \quad \forall t \in T \quad (18)$$

### IV. CASE STUDY

In this study, a microgrid of the different configuration is considered. Sizing of the BESS is done for the different Scenarios as mentioned in section II. The load data are residential loads of a city in Easter Province while the wind data are obtained from the windographer station in Khafji also in the Eastern province of Saudi Arabia. To compute the resulting power using the wind power equation presented in (1). The value of  $K_{max}$  is chosen as 0.45,  $\rho$  is  $1.19 \text{ Kg m}^{-3}$  and radius of rotor turbine is 31 m. The wind power system is made up of 40 wind turbines with each having a rated capacity of 1MW. The wind speed and power are shown in Figures 6 and 7 respectively.

### V. RESULTS AND DISCUSSION

The total operation costs for the three Scenarios together with the respective sizes of BESS are presented in Tables 2, 3 and 4. In Table 2, it is seen that operation cost is reduced




FIGURE 8. Electricity demand.

TABLE 2. Results from Scenario 1.

Months	Total cost (\$)	$E_{BESS}^{max}$ (MWh)	$P_{BESS}^{max}$ (MW)
Jan	6703.813	6.592	1.092
Feb	3711.401	2.775	0.94
Mar	2091.65	0.647	0.517
Apr	4386.114	3.039	0.764
May	6364.4	5.83	1.129
Jun	-2971.03	2.25	1.53
Jul	-528.635	0.622	0.427
Aug	3041.742	2.635	0.695
Sep	1689.314	0.862	0.648
Oct	7474.306	7.644	1.512
Nov	4725.832	4.778	1.019
Dec	4973.564	2.892	0.789
Total	41662.47	18.263	11.085

with the availability of more wind power. The highest operation cost is observed in January when the wind speed is low compared to the rest of the months. In June and July, there are enough wind powers to meet the maximum demand at all hours and the excess powers are sold to the grid so the lowest operation costs are negative in these two months resulting to profits of \$2971.03 and \$528.635 for June and July respectively as seen in Table 6. Besides the months of June and July requires lower BESS sizes when compared to other months since excess power has been sold to the grid, consequently, the abundant available wind power has little effects on the energy rating and the power ratings in these months. Moreover, it can be observed that the investment cost on BESS in June is the least amongst all other months. The investment on BESS in June appears to be larger than expected but this is due to the larger wind power availability that contributes to the sizes of the BESS rating. It can also be observed that January recorded the highest BESS investment cost.

The total operation cost in all Scenarios are presented in Figure 12 while the magnitude of exchanged power with grid for Scenarios 1 and 2 together with the power dispatched

TABLE 3. Results from Scenario 2.

Month	Total cost (\$)	$E_{BESS}^{max}$ (MWh)	$P_{BESS}^{max}$ (MW)
Jan	6703.813	6.592	1.092
Feb	6984.991	4.721	3.196
Mar	8051.513	14.761	2.52
Apr	4489.187	3.039	0.764
May	6003.322	4.638	1.079
Jun	15074.03	24.15	7.531
Jul	13699.77	34.51	4.227
Aug	2414.011	0.673	0.539
Sep	4796.294	6.437	2.066
Oct	4610.209	1.041	0.512
Nov	4725.832	4.778	1.019
Dec	4875.887	2.892	0.789
Total	82428.859	108.232	25.334

TABLE 4. Results from Scenario 3.

Month	Total cost (\$)	$E_{BESS}^{max}$ (MWh)	$P_{BESS}^{max}$ (MW)
Jan	3217.053	6.592	1.092
Feb	10638.28	12.221	6.196
Mar	10981.98	16.83	5.52
Apr	756.857	0.616	0.342
May	4136.601	8.048	1.579
Jun	9671.815	11.432	5.615
Jul	4926.882	8.245	2.327
Aug	995.642	0.873	0.539
Sep	4181.254	6.437	2.066
Oct	3652.037	7.006	1.387
Nov	1266.664	1.932	0.519
Dec	1882.441	2.892	0.789
Total	56307.503	83.124	27.971

by the DGs in Scenario 3 are shown in Figure 13. Figure 13 shows that powers are sold to the grid in Scenario 1 in the month of June and July only. Moreover lower operation costs are recorded in March and September due to lower exchanged power in the two months.

In Scenario 2, the microgrid does not sell power to the grid but could buy power from the grid. The optimal operation costs, sizes of BESS, investment cost, and power imported from the grid are as shown in Table 3 and Table 6 respectively. Since the power is not exported to the grid, the available wind power is used to supply the load and a part of this load is dispatched through the dump load. However, the operation costs and BESS sizes during the months of June and July are the highest in this case due to the large available wind power




FIGURE 9. Total grid power exchanged in each month of Scenarios 1 and 2.




FIGURE 10. BESS rated energy recorded in each month.

TABLE 5. Values recorded before the introduction of dump load.

Parameters	June	July
BESS Investment cost (\$)	36,700.518	21,099.766
$E_{BESS}^{max}$	24.150	54.510
$P_{BESS}^{max}$	25.553	6.227

that requires large-rated energies and rated powers as seen in Figures 10 and 11. Table 3 shows that the total operation cost and the total BESS sizes recorded for all months in Scenario 2 are higher than those of Scenario 1 and Scenario 3. The months of June and July contribute significantly to this cost as a result of the higher availability of wind power that surpasses the demand. Furthermore, Table 5 shows the huge amount recorded in Scenario 2 before the introduction of the dump load. When compared, the values from Table 5 and Table 6 showed that up to 59% and 35% savings on investment cost of the BESS are achievable for June and July respectively.

Also in Table 6, it is seen that powers are not imported from the grid during the hours of these months. After June and July, higher operation cost is observed in March and February. However, BESS sizes in March and January are higher than in other months as observed in Table 3. Figure 9 compared the exchanged powers with the grid in Scenarios 1 and 2. The figure shows negative plots in June and July which indicates exported power in Scenario 1.

It can be observed in Figures 10 and 11 that the rated energies and rated powers are equal in January and December for




FIGURE 11. BESS rated power recorded in each month.




FIGURE 12. Total operation cost of all Scenarios.




FIGURE 13. Total power exchanged for all Scenarios.

all Scenarios. Besides, rated energies, as well as rated powers in April and November, are approximately equal for Scenarios 1 and 2. However, it is observed that rated energies and rated powers of BESS are mostly higher in Scenario 2 than other Scenarios. Table 6 shows the cost of power exchanged with grid and investment cost on the BESS. The Table shows that the total investment cost for BESS in Scenario 2 exceeds that of Scenario 1. Also, the total cost of the exchanged power for Scenario 2 is higher than in Scenario 1. This result shows that Scenario 1 is more economical than Scenario 2.

In Scenario 3, the operation costs and the BESS sizes (Table 4), and the cost of operating the diesel generators, (Table 7) are graphed in Figures 12 and 13 respectively. Generally, Scenario 2 is more expensive than Scenarios (1 and 3) with June and July having the highest. The huge cost in these months results from the high wind power availability of these two months since dump loads are not installed in this Scenario, the lowest fuel and emission costs are recorded in these two months. Although there are sufficient powers in



**TABLE 6. Cost of power exchanged and cost of BESS investment for Scenarios 1 and 2.**

Months	Scenario 1		Scenario 2	
	$CMG_{ex}$ (\$)	$IC$ (\$)	$CMG_{ex}$ (\$)	$IC$ (\$)
Jan	3745.545	2958.267	3745.545	2958.267
Feb	1889.512	1821.889	1968.944	5016.048
Mar	1309.313	782.337	1337.542	6713.971
Apr	2709.598	1676.516	2812.67	1676.516
May	3551.464	2812.936	3549.079	2454.243
Jun	-5396.77	2425.737	-	15074.03
Jul	-1196.37	667.734	-	13699.77
Aug	1592.39	1449.352	1599.24	814.772
Sep	696.187	993.128	707.337	4088.958
Oct	3749.421	3724.885	3736.214	873.995
Nov	2308.94	2416.892	2308.94	2416.892
Dec	3303.822	1669.742	3206.145	1669.742
Total	18263.057	23399.415	24971.656	57457.204

**TABLE 7. Operation cost of DGs in Scenario 3.**

Month	Total cost from DGs (\$)	Fuel cost (\$)	Emission cost (\$)
Jan	258.785	182.111	76.674
Feb	147.231	110.663	36.568
Mar	150.668	101.522	49.146
Apr	192.563	141.264	51.299
May	229.807	170.713	59.094
Jun	77.744	29.724	48.02
Jul	73.738	26.351	47.387
Aug	130.865	90.318	40.547
Sep	92.296	52.869	39.427
Oct	236.274	175.074	61.2
Nov	161.46	119.791	41.669
Dec	212.698	157.37	55.328
Total	1961.855	1357.77	606.359

these two months to cater for the loads without supply from the DGs, the microgrid allows the DGs to run for some time to allow the generators to warm up. Table 7 shows the average amount spent as fuel and emission costs. It is observed that a higher amount is spent on fuel in January, October, May, and December, when compared to other months resorting to higher emission costs but not more than about 8% of the total cost of operation is recorded in each month. However, lower costs of fuel are recorded in June and July as may be expected. The total amount spent on DGs in Scenario 3 is about \$1960. This amount is less than 4% of the total amount spent on operation in costs in Scenario 3. The amount shows how less

dependent is the microgrid on the DGs, and by extension signifies how friendly the microgrid in Scenario 3 is to the environment. The total amount spent in 24 hour through all months in all Scenarios as observed in Tables 2, 3, and 4 are \$41,662.471, \$82,428.859 and \$56,307.503 respectively.

## VI. CONCLUSION

In this paper, optimal sizing of BESS for a wind-penetrated, grid-connected microgrid and standalone microgrid has been studied. In the three Scenarios considered, the sizes of BESS energy capacities and power capacities resulting from the minimum operational costs of the microgrid were computed. The optimization was done within 24 hours in every month from January to December. The microgrid in Scenarios 1 and 2 are grid-connected while Scenario 3 is a stand-alone microgrid. Simulations are done using the GAMS optimization software. The study found out that the microgrid of Scenario 1 is cheaper to operate than that of Scenario 2 or 3 and Scenario 2 is the most expensive. In particular, we have determined the minimum BESS investment cost needed for the operation of microgrid of the size proposed. Furthermore, our study revealed that hourly requirements of BESS are different every month in all Scenarios and Scenario 1 is the cheapest in terms of operation cost and investment cost of the BESS. Moreover, the study found that we can potentially save a significant amount in terms of BESS investment cost and the cost of emission of greenhouse gas. Finally, we conclude that the microgrid operation of the type proposed in Scenario 1 is very economical and worth to be considered for efficient dispatch of wind power.

## REFERENCES

- [1] *What are the Current Trends in Renewable Energy*, Jan. 2020.
- [2] J.-M. Glachant, "New business models in the electricity sector," Robert Schuman Centre Adv. Stud. Res., Washington, DC, USA, Tech. Rep. 44, 2019.
- [3] D. Milborrow, "Wind energy economics," in *The Age Wind Energy*. Springer, 2020, pp. 307–326.
- [4] M. A. Abdulgalil, A. M. Amin, M. Khalid, and M. AlMuhaini, "Optimal sizing, allocation, dispatch and power flow of energy storage systems integrated with distributed generation units and a wind farm," in *Proc. IEEE PES Asia-Pacific Power Energy Eng. Conf. (APPEEC)*, Oct. 2018, pp. 680–684.
- [5] Y. Ghiassi-Farrokhfal, C. Rosenberg, S. Keshav, and M.-B. Adjaho, "Joint optimal design and operation of hybrid energy storage systems," *IEEE J. Sel. Areas Commun.*, vol. 34, no. 3, pp. 639–650, Mar. 2016.
- [6] S. Parhizi, H. Lotfi, A. Khodaei, and S. Bahramirad, "State of the art in research on microgrids: A review," *IEEE Access*, vol. 3, pp. 890–925, 2015.
- [7] K. Bradbury, L. Pratson, and D. Patiño-Echeverri, "Economic viability of energy storage systems based on price arbitrage potential in real-time U.S. electricity markets," *Appl. Energy*, vol. 114, pp. 512–519, Feb. 2014.
- [8] A. A. Akhil, G. Huff, A. B. Currier, B. C. Kaun, D. M. Rastler, S. B. Chen, A. L. Cotter, D. T. Bradshaw, and W. D. Gauntlett, "Electricity storage handbook in collaboration with Nreca," Sandia Nat. Laboratories, Albuquerque, NM, USA, Tech. Rep., 2013.
- [9] Strategicmicrogrid.com. (2019). *Strategic Microgrid*. Accessed: Dec. 2019. [Online]. Available: <https://strategicmicrogrid.com/>
- [10] M. Sufyan, N. Abd Rahim, C. Tan, M. A. Muhammad, and S. R. Sheikh Raihan, "Optimal sizing and energy scheduling of isolated microgrid considering the battery lifetime degradation," *PLoS ONE*, vol. 14, no. 2, Feb. 2019, Art. no. e0211642.

- [11] W. Gai, C. Qu, J. Liu, and J. Zhang, "An improved grey wolf algorithm for global optimization," in *Proc. Chin. Control Decis. Conf. (CCDC)*, Jun. 2018, pp. 2494–2498.
- [12] Y. Zhang, J. Wang, A. Berizzi, and X. Cao, "Life cycle planning of battery energy storage system in off-grid wind-solar-diesel microgrid," *IET Gener., Transmiss. Distrib.*, vol. 12, no. 20, pp. 4451–4461, Nov. 2018.
- [13] K. Hesaroor and D. Das, "Optimal sizing of energy storage system in islanded microgrid using incremental cost approach," *J. Energy Storage*, vol. 24, Aug. 2019, Art. no. 100768.
- [14] A. L. Bukar, C. W. Tan, and K. Y. Lau, "Optimal sizing of an autonomous photovoltaic/wind/battery/diesel generator microgrid using grasshopper optimization algorithm," *Sol. Energy*, vol. 188, pp. 685–696, Aug. 2019.
- [15] T. S. Mahmoud, B. S. Ahmed, and M. Y. Hassan, "The role of intelligent generation control algorithms in optimizing battery energy storage systems size in microgrids: A case study from western australia," *Energy Convers. Manage.*, vol. 196, pp. 1335–1352, Sep. 2019.
- [16] M. Zolfaghari, N. Ghaffarzadeh, and A. J. Ardakani, "Optimal sizing of battery energy storage systems in off-grid micro grids using convex optimization," *J. Energy Storage*, vol. 23, pp. 44–56, Jun. 2019.
- [17] M. F. Zia, E. Elbouchikhi, and M. Benbouzid, "Microgrids energy management systems: A critical review on methods, solutions, and prospects," *Appl. Energy*, vol. 222, pp. 1033–1055, Feb. 2018. [Online]. Available: <http://www.sciencedirect.com/science/article/pii/S0306261918306676>
- [18] U. Akram, M. Khalid, and S. Shafiq, "Optimal sizing of a wind/solar/battery hybrid grid-connected microgrid system," *IET Renew. Power Gener.*, vol. 12, no. 1, pp. 72–80, Jan. 2018.
- [19] S. Ashfaq, D. Zhang, C. Zhang, and Z. Y. Dong, "Regionalisation of islanded microgrid considering planning and operation stages," *IET Renew. Power Gener.*, vol. 14, no. 1, pp. 145–153, Jan. 2020.
- [20] M. C. Pham, T. Q. Tran, S. Bacha, A. Hably, and L. N. An, "Optimal sizing of battery energy storage system for an islanded microgrid," in *Proc. 44th Annu. Conf. IEEE Ind. Electron. Soc.*, Oct. 2018, pp. 1899–1903.
- [21] Y. Liu, X. Wu, J. Du, Z. Song, and G. Wu, "Optimal sizing of a wind-energy storage system considering battery life," *Renew. Energy*, vol. 147, pp. 2470–2483, Mar. 2020.
- [22] M. Simeon, A. U. Adoghe, S. T. Wara, and J. O. Oloweni, "Renewable energy integration enhancement using energy storage technologies," in *Proc. IEEE PES/IAS PowerAfrica*, Jun. 2018, pp. 864–868.
- [23] R. Malkowski, P. Bucko, M. Jaskolski, W. Pawlicki, and A. Stoltmann, "Simulation of the dynamics of renewable energy sources with energy storage systems," in *Proc. 15th Int. Conf. Eur. Energy Market (EEM)*, Jun. 2018, pp. 1–5.
- [24] X. Liu and B. Su, "Microgrids—An integration of renewable energy technologies," in *Proc. China Int. Conf. Electr. Distrib.*, 2008, pp. 1–7.
- [25] A. Ahmed and T. Jiang, "Operation management of power grid system with renewable energy sources and energy storage system integrations," in *Proc. 2nd IEEE Conf. Energy Internet Energy Syst. Integr. (EI2)*, Oct. 2018, pp. 1–6.
- [26] R. Viral and D. K. Khatod, "Optimal planning of distributed generation systems in distribution system: A review," *Renew. Sustain. Energy Rev.*, vol. 16, no. 7, pp. 5146–5165, Sep. 2012.
- [27] M. F. Zia, E. Elbouchikhi, and M. Benbouzid, "Optimal operational planning of scalable DC microgrid with demand response, islanding, and battery degradation cost considerations," *Appl. Energy*, vol. 237, pp. 695–707, Mar. 2019.
- [28] S. Bahramirad, W. Reeder, and A. Khodaei, "Reliability-constrained optimal sizing of energy storage system in a microgrid," *IEEE Trans. Smart Grid*, vol. 3, no. 4, pp. 2056–2062, Dec. 2012.
- [29] A. Soroudi, *Power System Optimization Modeling in GAMS*. Springer, 2017.
- [30] H. Khorramdel, J. Aghaei, B. Khorramdel, and P. Siano, "Optimal battery sizing in microgrids using probabilistic unit commitment," *IEEE Trans. Ind. Informat.*, vol. 12, no. 2, pp. 834–843, Apr. 2016.
- [31] J. P. Torreglosa, P. Garcia, L. M. Fernandez, and F. Jurado, "Predictive control for the energy management of a fuel-cell-battery-supercapacitor tramway," *IEEE Trans. Ind. Informat.*, vol. 10, no. 1, pp. 276–285, Feb. 2014.
- [32] S. Han, S. Han, and H. Aki, "A practical battery wear model for electric vehicle charging applications," *Appl. Energy*, vol. 113, pp. 1100–1108, Jan. 2014.
- [33] (Nov. 2019). *Electricity Consumption by Sectors*. [Online]. Available: [https://datasource.kapsarc.org/explore/dataset/electricity-consumption-by-%sectors/information/?disjunctive.region&disjunctive.type\\_of\\_consumption](https://datasource.kapsarc.org/explore/dataset/electricity-consumption-by-%sectors/information/?disjunctive.region&disjunctive.type_of_consumption)
- [34] A. S. Alahmed, S. U. Taiwo, M. A. Abido, and M. M. Almuhami, "Intelligent flexible priority list for reconfiguration of microgrid demands using deep neural network," in *Proc. IEEE Innov. Smart Grid Technol.*, May 2019, pp. 3490–3495.



**UMAR T. SALMAN** (Student Member, IEEE) was born in Lagos, in February 1992. He received the B.Sc. degree in electrical/electronic engineering from the University of Lagos, Lagos, Nigeria, in 2015. He recently obtained the M.Sc. degree in electrical engineering with Electrical Engineering Department, King Fahd University of Petroleum and Minerals (KFUPM), Dhahran, Saudi Arabia. His research interests include the modeling, control, and optimization of the complex systems, including battery energy storage systems, electric vehicles, microgrid clusters, energy management, generation and dispatch, hybrid energy storage, and smart grids. He is a Graduate Student Researcher with the King Abdullah City for Atomic and Renewable Energy (K. A. CARE) Energy Research and Innovation Center, Dhahran. He received the award for the second rank in the 2019 King Fahd University of Petroleum Student Scientific Forum (SSF). His article received the Best Poster Award at the 2019 ICRERA Conference, Romania, and recently was awarded the K. A. CARE Graduate Student Scholarship in KFUPM.



**FAHAD SALEH AL-ISMAIL** (Senior Member, IEEE) received the B.Sc. and M.Sc. degrees in electrical engineering from the King Fahd University of Petroleum and Minerals (KFUPM), Dhahran, Saudi Arabia, in 2009 and 2012, respectively, and the Ph.D. degree in electrical engineering from Texas A & M University at College Station, TX, USA, in December 2016. He is currently an Assistant Professor with the Department of Electrical Engineering, KFUPM, and the Director of the Energy Research and Innovation Center (ERIC), sponsored by King Abdullah City for Atomic and Renewable Energy (K. A. CARE). He offers various courses on energy efficiency, demand-side management, power system operation and control, and power system planning. His research interests include power system planning and reliability, renewable energy integration, energy storage system planning and operation, demand-side management modeling with intermittent resources, and uncertainty representation of renewable energy.



**MUHAMMAD KHALID** (Senior Member, IEEE) received the Ph.D. degree in electrical engineering from the School of Electrical Engineering and Telecommunications (EE and T), University of New South Wales (UNSW), Sydney, Australia, in 2011. He worked there initially as a Postdoctoral Research Fellow for three years and then he continued as a Senior Research Associate at the Australian Energy Research Institute, School of EE and T, UNSW, for another two years. He is currently serving as an Assistant Professor with Electrical Engineering Department, King Fahd University of Petroleum and Minerals (KFUPM), Dhahran, Saudi Arabia. He has authored/coauthored several journal articles and conference papers in the field of control and optimization for renewable power systems. He is also currently working as a Researcher with the King Abdullah City for Atomic and Renewable Energy (K. A. CARE) Energy Research and Innovation Center, Dhahran. His current research interests include the optimization and control of battery energy storage systems for large-scale grid-connected renewable power plants (particularly wind and solar), distributed power generation and dispatch, hybrid energy storage, EVs, and smart grids. In addition, he has been a reviewer for numerous international journals and conferences. He was a recipient of the highly competitive Postdoctoral Writing Fellowship from UNSW, in 2010. Most recently, he has received the prestigious K. A. CARE Fellowship.

• • •