

Received July 10, 2020, accepted July 15, 2020, date of publication July 27, 2020, date of current version August 7, 2020.

Digital Object Identifier 10.1109/ACCESS.2020.3012036

# Slack and Excessive Loading Avoidance in $n$ -Tendon Continuum Robots

MOHSEN MORADI DALVAND<sup>1</sup>, SAEID NAHAVANDI<sup>1</sup>, (Fellow, IEEE),  
AND ROBERT D. HOWE<sup>2</sup>, (Fellow, IEEE)

<sup>1</sup>Institute for Intelligent Systems Research and Innovation (IISRI), Deakin University, Geelong VIC 3220, Australia

<sup>2</sup>Harvard Paulson School of Engineering and Applied Sciences, Cambridge, MA 02138, USA

Corresponding author: Mohsen Moradi Dalvand (mdalvand@seas.harvard.edu)

**ABSTRACT** In this work, two tendon tension loading distributions (fixed and moving) are designed to prevent undesired slack and excessive loading in tendons of continuum manipulators. For any given beam configuration, the algorithms utilize the proposed loading distributions to find a new beam configuration as well as base displacement to control the orientation or position of the  $n$ -tendon continuum robot. The algorithms account for the bending and axial compliance of the manipulator as well as tendon compliance. Numerical results are provided to demonstrate the orientation and position control algorithms under fixed or moving loading distributions. A 6-tendon continuum robot system is employed to experimentally evaluate the effectiveness and accuracy of the proposed control algorithms. Multiple experiments are carried out and results are reported. The results verify the performance of the proposed control algorithms in avoiding slack and excessive loading in tendons and controlling the orientation and position of continuum structures.

**INDEX TERMS** Continuum robot, catheter, slack avoidance, kinematics, load analysis, tendon-driven.

## I. INTRODUCTION

Continuum robots are inspired by natural continuum structures like elephant trunks [1], octopus arms [2], squid tentacles [3], and snakes [4], [5]. Their continuous structure and inherent compliance enable them to exhibit elastic deformation along their entire length and navigate safely [6]–[11]. In the medical field, catheters and catheter-like instruments are well-known examples of continuum structures that have gained attention in minimally invasive treatments [12], [13].

A direct approach to manipulating a continuum structure is the use of remotely actuated tendons [14], [15]. Tendons can only support tension (negative load) and in compression they go slack because of their low bending stiffness [14], [16]. Actuation of a slacked tendon will first recover the slack before producing tension in the tendon [17]. This latency results in actuator backlash that is one of the key causes of inefficiency and inaccuracy in the controllers of robotic catheters [18]. Slack directly affects the stiffness of the articulating beam and the load distribution among tendons [13]. Although slack may be mitigated by increasing tension loads in all tendons, high tendon load in continuum robots

generates less compliance and more friction. Therefore, slack and excessive loading are both undesirable characteristics especially in catheters in which tendon size and materials are constrained by the environment [13], [19].

Methods were introduced to prevent slack based on a redundancy of control actions in redundant rigid-link tendon-driven mechanisms [20]–[24]. A similar approach was employed to prevent slack in redundant tendon-driven continuum robots based on the numerical optimization techniques in a closed-loop control architecture [17], [25], [26]. These studies do not promise reliable control algorithms capable of performing the real-time computations involved in numerical optimization process, especially for higher numbers of tendons. This may cause a drift in Jacobian estimation from the true estimate and take longer to converge, leading the robot to diverge from the desired path [25]. They also require load cells for online measurement and feedback of the tension loading in tendons [25]. Pretensioning tendons was also utilized in multiple studies [27]–[31]. Excessive pretension causes more friction which leads to faster wear and tear and shorter lifetime [32], [33]. Not enough pretension causes slack and deficiency in control [27].

The main contribution of this study is algorithms to control orientation or tip position of  $n$ -tendon continuum robots

The associate editor coordinating the review of this manuscript and approving it for publication was Derek Abbott<sup>1</sup>.

guaranteeing no slack or excessive loading in tendons. Two loading distributions (fixed and moving) are proposed to minimize the tension loadings to a certain level that causes tension in all tendons (no slack). For any given beam configuration within workspace, the algorithms utilize the proposed loading distributions to find a new beam configuration as well as base displacement to control the orientation or position of the continuum robot.

In the following section, the tension loading model in  $n$ -tendon continuum robots used throughout this paper is explained. Slack and excessive loading problems are described and their effects are demonstrated using numerical analysis in Section III. Fixed and moving loading distributions and how they are utilized in orientation and position control algorithms are explained and numerical results are provided in Sections IV and V. Section VI presents details about experimental setup, procedure and results followed by discussion and concluding remarks in Section VIII.

## II. LOADING MODEL

Figure 1 shows the schematic description of the articulating beam of a single segment cable-driven continuum robot with  $n$  equidistant tendons ( $n = 6$  in this case) in an arbitrary beam configuration defined with bending angle ( $\theta$ ), pending plane angle ( $\phi$ ), and beam length along its centerline ( $L$ ). As previously developed [34], the tension load model for  $i$ -th tendon in  $n$ -tendon continuum robots can be expressed as a function of beam configuration parameters as

$$F_i(\theta, \phi, L) = \frac{EI(k-1)}{nL_0R_a} \theta \cos(\phi - \alpha_i) - (L_0 - L) \frac{EA}{nL_0} \quad i = 1, \dots, n \quad (1)$$

where  $i$  is tendon number ( $i = 1, \dots, n$ ),  $E$ ,  $I$  and  $A$  are the Young's modulus, area moment of inertia, and cross section area of the beam,  $R_a$  and  $\alpha_i$  are radial and angular location of tendons,  $L_0$  is the initial length of the continuum structure, and  $k$  is representative of number of degrees of freedom (DOF) of the continuum robot and is defined as

$$k = \begin{cases} n & \text{if } n = 1, 2 \\ 3 & \text{if } n \geq 3 \end{cases} \quad (2)$$

The angular location of  $i$ -th tendon ( $\alpha_i$ ) of  $n$  equidistant tendons can be represented by  $2\pi/n(i-1)$ . In Figure 1, a *virtual* tendon is defined that is located at the back of the continuum structure on the bending plane at the distance  $R_a$  from the centerline.

Figure 2 schematically presents different loading distributions in a  $n$ -tendon continuum robot ( $n = 3$  in this example). As demonstrated in this figure, applying actuator displacements obtained from the inverse kinematics solution for a given configuration results in unique set of tendons tensions in a continuum robot that are linearly distributed among the tendons [34]. The conceptual axis on the cross section of the continuum structure, perpendicular to the bending plane, with zero tension in tendons lying on it is called zero-load axis. The location of this axis from the centerline of the continuum structure is denoted by  $D_{zl}$  and can be derived as [34]

$$D_{zl} = \frac{AR_a^2}{2I\theta}(L_0 - L) \quad (3)$$

This axis is different from the neutral axis with zero displacement in tendons lying on it. The location of the neutral




FIGURE 1. Schematic description of the articulating beam of a tendon-driven catheter with  $n$  equidistant tendons ( $n = 6$  in this description) at a beam configuration  $([\theta, \phi, L])$ .





FIGURE 2. Schematic presentation of different loading distributions with (a) slack (b) and excessive loading as well as (c) fixed and (d) moving loading distribution in a  $n$ -tendon continuum robot ( $n = 3$  in this description).

axis from the centerline of the continuum structure can be derived as  $D_{zd} = (L_0 - L)/\theta$ .

In order to illustrate the behavior of the tendon loading for different beam configurations and demonstrate the effects of slack and excessive loadings in tendons, numerical simulations are performed and the results are provided in the following section. Similar simulations are also utilized to evaluate the performance of the developed control algorithms for slack and excessive loading avoidance and the results are also described in the following sections.

### III. SLACK AND EXCESSIVE LOADING

Figure 3 presents results for the numerical simulations for the estimated tendon tension loads in a 6-tendon continuum robot at different sets of beam configurations. The mechanical specification of the continuum structure used in the simulation are chosen identical to those from the experimental setup (Table 1). The beam configurations  $[\theta, \phi, L_{SS}]$  and  $[\theta, \phi, L_E]$  (Table 2) served as inputs to estimate tendon tension loads using Equation (1) for the first and second simulations, respectively. These configurations are selected to respectively demonstrate slack (in some of the tendons) and excessive loading in tendons as presented in Figures 2a and 2b. Table 3 includes parametric results of the numerical analysis.



**FIGURE 3.** Numerical simulation results for the tendon tension loads in a 6-tendon continuum robot at the beam configurations (a)  $[\theta, \phi, L_{SS}]$  and (b)  $[\theta, \phi, L_E]$ . Parameters are listed in Tables 1 and 2.

As shown in Figure 3a, in every configuration, there are tendons with positive tension values (peak values of +2.63 and -4.66 N). This means that in order to reach these configurations, some of the tendons must act like a solid rod and push (positive loading as shown in Figure 2a).

**TABLE 1.** Mechanical specification of the continuum robot.

Mechanical Parameter	Value
Number of tendons ( $n$ )	6
Beam Young's modulus ( $E$ )	5.9 MPa
Radial tendon location ( $R_a$ )	3.5 mm
Beam radius ( $R_o$ )	6 mm
Beam initial length ( $L_0$ )	160 mm
Tendon Young's modulus ( $E_t$ )	48.9 GPa
Tendon radius ( $R_t$ )	0.23 mm
Tendon initial length ( $L_{t0}$ )	435.54 mm

**TABLE 2.** Beam configurations used in numerical analysis and experiments.

Beam configuration parameter	Value
Bending angle ( $\theta$ )	40 deg
Bending plane angle ( $\phi$ )	$[0, 10, 20, \dots, 360]$ deg
Length - Some slack ( $L_{SS}$ )	159 mm
Length - Excessive loading ( $L_E$ )	154 mm
Length - All slack ( $L_{AS}$ )	175 mm

However, tendons can only support tension (negative load) and in compression they tend to buckle (go slack) because of their low bending stiffness. Actuation of a slacked tendon results in inefficiency and inaccuracy in the control of robotic catheters [13], [34].

It should be noted that slack may be produced in tendons even when the beam structure is under compression. For example, there is 1 mm compression across all beam configurations in the first simulation. This is because of the zero-load axis located inside the beam structure;  $D_{zd} < R_a$  (Figure 2a and Table 3, #1). This generates different loading directions in tendons located on opposite sides of this axis [34] and results in the summation of the tension loads to be as low as -6.10 N (Table 3, #1).

The second simulation is an example of excessive loading in tendons (Figures 2b and 3b). Although  $\theta$  and  $\phi$  used in both simulations have similar values, the beam structure in the second simulation is under 5 mm additional compression which causes more loading in tendons (peak values of -2.45 and -9.77 N as listed in Table 3, #2). In this simulation, the zero-load axis is located outside of the beam structure;  $D_{zd} > R_a$  (Figure 2b and Table 3, #2). This generates similar loading directions in all tendons. As shown in Figure 3b, there is no slack in any of the tendons across all configurations; however, tendons are always under tension even at their minimum contribution (Figure 2b). This results in the large value of -36.60 N for the summation of tension loads. High tendon tension in continuum robots generates less compliance and more friction [29], [33].

Therefore, slack and excessive loading are both undesirable characteristics especially in catheters in which tendon size and materials are constrained by the environment [17]. Given the above examples, the question is how can slack in continuum robots be avoided without producing excessive

**TABLE 3. Results of the numerical simulations.**

Simulation	Given config.	Target config.	Tension peaks (N)	$D_{z_l}$ (mm)	$D_{z_d}$ (mm)	$\Delta Z_{f(m)p}$ mm	$\sum_{i=1}^n F_i$ (N)
#1 - Some slack	$[\theta, \phi, L_{SS}]$	$[\theta, \phi, L_{SS}]$	$[-4.66, +2.63]$	+0.97	+1.43	0.00	-6.10
#2 - Excessive loading	$[\theta, \phi, L_E]$	$[\theta, \phi, L_E]$	$[-9.77, -2.45]$	+5.84	+8.59	0.00	-36.60
#3 - Fixed - Orientation	$[\theta, \phi, L_{SS}]$	$[\theta, \phi, L_{fo}]$	$[-7.30, 0.00]$	+3.50	+5.14	0.00	-21.90
#4 - Fixed - Position	$[\theta, \phi, L_{SS}]$	$[\theta_{fp}, \phi, L_{fp}]$	$[-7.43, 0.00]$	+3.50	+5.14	+2.89	-22.30
#5 - Fixed - Position	$[\theta, \phi, L_E]$	$[\theta_{fp}, \phi, L_{fp}]$	$[-7.17, 0.00]$	+3.50	+5.14	-2.68	-21.52
#6 - Moving - Orientation	$[\theta, \phi, L_{SS}]$	$[\theta, \phi, L_{mo}]$	$[-7.30, 0.00]$	[+3.03 to +3.50]	[+4.45 to +5.14]	0.00	[-21.90 to -18.97]
#7 - Moving - Position	$[\theta, \phi, L_{SS}]$	$[\theta_{mp}, \phi, L_{mp}]$	$[-7.43, 0.00]$	[+3.03 to +3.50]	[+4.45 to +5.14]	[+2.35 to +2.89]	[-22.30 to -19.20]
#8 - Moving - Position	$[\theta, \phi, L_E]$	$[\theta_{mp}, \phi, L_{mp}]$	$[-7.17, 0.00]$	[+3.03 to +3.50]	[+4.45 to +5.14]	[-3.21 to -2.68]	[-21.52 to -18.57]

loading in tendons? The proposed solution is to determine, based on fixed and moving loading distributions, new beam configuration as well as base displacement to satisfy no-slack and excessive loading conditions for orientation and position controls.

#### IV. FIXED LOADING DISTRIBUTION

To prevent slack in a continuum robot, target beam configurations requiring tendon tensions larger than zero should be prevented. As shown in Figure 2c, this can be achieved by pushing the location of the zero-load axis at or behind the virtual tendon ( $D_{z_l} \geq R_a$ ). The bigger  $|D_{z_l} - R_a|$ , the more tension loading in tendons. To minimize the loading distribution and still have no slack in any of the tendons, the zero-load axis can be located right at the location of the virtual tendon ( $D_{z_l} = R_a$ ). In order to also control the stiffness of the continuum manipulator, as shown in Figure 2c, the tension loading  $F_0$  (instead of zero) is considered at the location of the virtual tendon (see Discussion). In this approach, the location of the zero-load axis is independent of beam configuration and same minimum  $F_0$  loading condition can be satisfied for all configurations. This results in a loading distribution with fixed zero-load axis location that is referred to as the *fixed loading distribution* in this paper (Figure 2c).

The location of the bending plane at which the peak tension loads in the  $i$ -th tendon happen may be determined by differentiating  $F_i$  from Equation (1) with respect to  $\phi$  ( $dF_i/d\phi = 0$ ) as

$$\phi_{i_f} = \alpha_i + m\pi \quad \begin{cases} i = 1, \dots, n \\ m \in \mathbb{N} \end{cases} \quad (4)$$

As implied from this equation, the peak tension loads in each tendon happen when it lies on the bending plane. Even and odd values of parameter  $m$  result in the angular location of the maximum and minimum magnitude of the tension loadings in the  $i$ -th tendon. Substituting odd values of  $m$  in Equation 4 determines the bending plane at which the  $i$ -th tendon is on the virtual tendon. To satisfy the minimum tension loading  $F_0$  in the  $i$ -th tendon at the bending plane angle of  $\phi_{i_f}$ , Equation (4) can be substituted in Equation (1) as

$$F_i(\theta, \phi_{i_f}, L) = F_0 \quad \begin{cases} i = 1, \dots, n \\ m = 1 \end{cases} \quad (5)$$

By solving this equation with respect to  $L$ , the new length of the continuum structure ( $L_f$ ) guaranteeing minimum tension loading  $F_0$  is derived as a function of  $\theta$  as

$$L_f(\theta) = C_1 - C_2\theta \quad k \geq 2 \quad (6)$$

where constant parameters  $C_1$  and  $C_2$  are


$$C_1 = L_0 \left( \frac{nF_0}{AE} + 1 \right)$$

$$C_2 = \frac{I(k-1)}{AR_a}$$

The constraint  $k \geq 2$  in this equation is because slack is meaningless in case of single tendon robot. It is worth noting that  $L_f$  is independent of parameters  $i$ ,  $L$ , and  $\phi$  and is a function of only  $\theta$ . In the following sections, control algorithms are developed based on the fixed loading distribution in order to enable orientation and position control of continuum robot while satisfying minimum  $F_0$  tension constraint (no slack).

#### A. ORIENTATION CONTROL

Figure 4 illustrates the beam structure at different configurations and under various control scenarios. The beam structure illustrated with solid line represents a target beam configuration in which tendons are under excessive loading or slack.



**FIGURE 4. Schematic description the beam structure at different configurations and under various control scenarios (solid lines: target configuration causing slack or excessive loading in tendons, dashed line: orientation control under fixed or moving loading distribution, dash-dot lines: position control under fixed or moving loading distribution for slack and excessive loading cases).**

In some applications, the orientation of the tip of the continuum robot or catheter is more important than its position, e.g. pointing an ultrasound imaging catheter [35]. In order to manipulate a continuum structure to the given bending angle  $\theta$  under the fixed loading distribution, Equation (6) may be used to find the length of the continuum structure  $L_{fo}$  satisfying minimum  $F_0$  loading in tendons as

$$L_{fo} = L_f(\theta) \quad k \geq 2 \quad (7)$$

The dashed line in Figure 4 illustrates the beam structure under orientation control with similar  $\theta$  as of the solid line. Based on the Equation (7), for orientation control under fixed loading distribution, only parameters  $\theta$  and  $\phi$  are required and the algorithm determines the maximum possible length of the continuum structure ( $L_{fo}$ ) at which there is minimum  $F_0$  loading in tendons (no slack or excessive loading). Substituting Equation (7) into the Equation (1), the tendon tensions for orientation control of a  $n$ -tendon continuum robot under fixed loading distribution is derived as

$$F_{i_{fo}}(\theta, \phi) = F_0 - \frac{EI(k-1)}{nL_0 R_a} \theta \times \left( \cos(\phi - \alpha_i) + 1 \right) \quad \begin{cases} i = 1, \dots, n \\ k \geq 2 \end{cases} \quad (8)$$

A characteristic feature of fixed loading distribution is the minimum  $F_0$  loading in the virtual tendon (Figure 2c). This can be demonstrated using Equation (8) by calculating the tension load in the 4-th tendon ( $F_{4_{fo}}$ ) of a 6-tendon robot at  $\phi = 0$  ( $\phi - \alpha_4 = -\pi$ ) which makes it lay on the virtual tendon ( $F_{4_{fo}} = F_0$ ). Using Equation (8), the summation of the tension loads of all tendons for orientation control of a continuum robot under fixed loading distribution for any given configuration  $[\theta, \phi, L]$  can be derived as a function of  $\theta$  as

$$\sum_{i=1}^n F_{i_{fo}} = nF_0 - \frac{EI(k-1)}{L_0 R_a} \theta \quad k \geq 2 \quad (9)$$

Based on the beam configuration and tendon tension, tendon displacements  $\Delta L_i$ , tendon stretches  $\delta_i$ , and actuator displacements ( $\Delta L_{a_i}$ ) can be determined using

$$\Delta L_i = (L_0 - L) + R_a \theta \cos(\alpha_i - \phi) \quad i = 1, \dots, n \quad (10)$$


$$\delta_i = \frac{F_i L_{t0}}{E_t A_t} \quad i = 1, \dots, n \quad (11)$$

$$\Delta L_{a_i} = \Delta L_i + \delta_i \quad i = 1, \dots, n \quad (12)$$

To control orientation of a continuum robot under fixed loading distribution, target  $\theta$  and  $\phi$  are used in Equation (7) to determine the desired length of the continuum structure ( $L_{fo}$ ). The new beam configuration  $[\theta, \phi, L_{fo}]$  can then be used to determine  $\Delta L_{a_i}$  to reach orientation  $\theta$  and satisfy no-slack and minimum  $F_0$  loading conditions (Algorithm 1).

To demonstrate the effectiveness of the orientation control algorithm under fixed loading distribution in satisfying  $F_0$  loading constraint (no slack), the numerical simulation process for the beam configurations  $[\theta, \phi, L_{SS}]$  and  $[\theta, \phi, L_E]$

are repeated based on this control algorithm. The minimum loading is set to zero ( $F_0 = 0$ ). The results are presented in Figure 5a. The orientation control algorithm is independent of the given  $L$  as it determines the required beam length ( $L_{fo}$ ) to satisfy the desired conditions. Therefore, the results for both configurations  $[\theta, \phi, L_{SS}]$  and  $[\theta, \phi, L_E]$  are similar.



**FIGURE 5.** Simulation examples for the estimated tendon tension loads in a 6-tendon continuum robot at the beam configuration  $[\theta, \phi, L_{SS}]$  for orientation control under (a) fixed and (b) moving loading distributions. Parameters are defined in Table 2.

As shown in Figure 5a compared to Figure 3, the peak values are changed to 0 and  $-7.3$  N (Table 3, #3) which means that tendons are never under positive tension for any configuration. Tendon tension summation (Equation (9)) is a function of only  $\theta$  that results in a constant value of  $-21.90$  N in this simulation. As expected, this value is decreased significantly compared to the summation of tensions in the simulation for the excessive loading in tendons (Figure 3b and Table 3, #3). On the other hand, there is no excessive loading in tendons as their tensions reach the minimum absolute values of zero ( $F_0 = 0$  in this case) when they meet the virtual tendon (Figure 2c). In all other configurations, the absolute values of the tensions in all tendons are always bigger than  $|F_0|$ , e.g. at  $\phi = 90^\circ$  in Figure 5a. In other words, in case of fixed loading distribution, the magnitude of the tensions in all tendons are always greater than  $F_0$  except that of the tendon laid on the virtual tendon with tension equal to  $F_0$ . This is another characteristic feature of the fixed loading distribution that exists for both orientation and position control algorithms.

## B. POSITION CONTROL

To control the tip position of a continuum robot and satisfy no-slack and minimum  $F_0$  loading conditions, the fixed

**Algorithm 1** Orientation Control Algorithm Under Fixed (or Moving) Loading Distribution

---

**input** : Bending angle ( $\theta$ ), bending plane angle ( $\phi$ ), minimum loading ( $F_0$ ), and geometry and mechanical properties of beam and tendons ( $[p]$ )

**output**: Tendon actuator displacements  $[\Delta L_{a_i}]$

1 **Algorithm** ControlOrientation ( $\theta, \phi, F_0, [p]$ )

2

3 Determine  $L_{fo}$  using Equation (7) (or  $L_{mo}$  using Equation (21));

4 Determine tendon displacements  $[\Delta L_i]$  using Equation (10) ;

5 Determine tendon tensions  $[F_{i_{fo}}]$  using Equation (8) (or  $[F_{i_{mo}}]$  using Equation (22));

6 Determine tendon stretches  $[\delta_i]$  based on the tendon tensions  $[F_{i_{fo}}]$  (or  $[F_{i_{mo}}]$ ) using Equation (11);

7 Determine tendon actuator displacements  $[\Delta L_{a_i}]$  using Equation (12);

8 **return**  $[\Delta L_{a_i}]$ ;

---

loading distribution can be utilized in combination with an axial actuated DOF of the base of the continuum structure, i.e. insertion/retraction of the catheter shaft. The dash-dot line in Figure 4 illustrates the beam structure under position control. As shown in this figure, a continuum robot commanded to  $[x, y, z]$  coordinates (point  $p$  in the figure) can instead be manipulated to a new coordinates  $[x, y, z_{fp}]$  (point  $p_{fp}$  in the figure) while the axial actuated DOF of the base compensates for  $z$  and  $z_{fp}$  differences ( $\Delta Z_{fp}$ ). To meet minimum  $F_0$  loading condition as well as  $x$  and  $y$  coordinates condition, two constraints are defined. The first constraint is to guarantee minimum  $F_0$  loading in tendons (no slack) which is defined based on the Equation (6) as

$$L_{fp} = R_{fp}\theta_{fp} = C_1 - C_2\theta_{fp} \quad k \geq 2 \quad (13)$$

where  $L_{fp}$  in the new length of the continuum structure that can be represented by multiplying the radius of the beam structure ( $R_{fp}$ ) by the new beam bending angle ( $\theta_{fp}$ ).  $L_{fp}$  and  $\theta_{fp}$  are the unknown beam parameters satisfying the desired conditions. As shown in Figure 4, the tip position of the dash-dot line (point  $p_{fp}$ ) have similar  $x$  and  $y$  coordinates as of those of the solid lines (point  $p$ ). Therefore, both tip points  $p$  and  $p_{fp}$  (Figure 4) projected upon  $xy$  plane should be equidistant from the origin. The second constraint is defined as

$$R_{fp} = \frac{1 - \cos(\theta)}{1 - \cos(\theta_{fp})} \times \frac{L}{\theta} \quad (14)$$

To find the two unknown variables  $R_{fp}$  and  $\theta_{fp}$ , Equation (14) is substituted into Equation (13):

$$\left(C_2 + \frac{1 - \cos(\theta)}{1 - \cos(\theta_{fp})} \times \frac{L}{\theta}\right)\theta_{fp} = C_1 \quad (15)$$

By finding  $\theta_{fp}$  from this equation and substituting it back into Equation (14) and then in Equation (13), both configuration variables  $L_{fp}$  and  $\theta_{fp}$  are determined. The required base displacement to compensate for the changes in  $z$  coordinates of points  $p$  and  $p_{fp}$  (Figure 4) can be derived as

$$\Delta Z_{fp} = \frac{L}{\theta} \left( \sin(\theta) - \frac{1 - \cos(\theta)}{1 - \cos(\theta_{fp})} \times \sin(\theta_{fp}) \right) \quad (16)$$

As described in Algorithm 2, to manipulate a continuum robot to a given tip position  $[x, y, z]$  (corresponding to the configuration  $[\theta, \phi, L]$ ) and also satisfy no-slack condition under fixed loading distribution, the robot can be commanded to the beam configuration  $[\theta_{fp}, \phi, L_{fp}]$  while the displacement  $\Delta Z_{fp}$  is simultaneously commanded to the axial base DOF. Numerical simulations are performed for the configurations  $[\theta, \phi, L_{SS}]$  and  $[\theta, \phi, L_E]$  and  $F_0 = 0$  based on the position control algorithm under fixed loading distribution. The results have similar patterns to those presented in Figure 5a but different peak values (Table 3, #4 and #5). As implied from numerical results, position control algorithm satisfies no-slack condition. However, it requires extra DOF of the base to compensate for  $\Delta Z_{fp}$ .

## V. MOVING LOADING DISTRIBUTION

To prevent slack in a continuum robot, zero-load axis can be pushed at or behind the location of the virtual tendon at the back of the continuum structure ( $D_{zI} \geq R_a$ ). In case of fixed loading distribution, the minimum loading in tendons guaranteeing no slack in tendons happens when the zero-load axis is located right at the location of the virtual tendon ( $D_{zI} = R_a$ ). The magnitude of this loading distribution can be further decreased whenever the bending plane does not coincide with a tendon location (Figure 2). To minimize the loading distribution magnitude to the lowest possible value and still satisfy the no-slack condition, the zero-load axis can be located at the location of the farthest tendon at the back of the continuum structure.

To avoid slack and unnecessary loading in tendons under moving loading distribution and also be able to potentially adjust stiffness in continuum structure, the location of the zero-load axis can be moved behind the farthest tendon at the back of the continuum structure such that there is a minimum tension loading of  $F_0$  in the farthest tendon at the back. An illustration of this loading distribution is presented in Figure 2d. As  $\phi$  changes, the location of the farthest tendon and consequently the zero-load axis location and the loading distribution magnitude changes. This results in a loading distribution that is referred to as the *moving loading distribution*

**Algorithm 2** Position Control Algorithm Under Fixed (or Moving) Loading Distribution

**input** : Tip position  $([x, y, z])$ , minimum loading  $(F_0)$ , and geometry and mechanical properties of beam and tendons  $([p])$   
**output**: Tendon actuator displacements  $[\Delta L_{a_i}]$ , base actuator displacement  $\Delta Z_{fp}$  (or  $\Delta Z_{mp}$ )

```

1 Algorithm ControlPosition  $([x, y, z], F_0, [p])$ 
2
3   Determine beam configuration parameters  $[\theta, \phi, L]$  of the tip position  $[x, y, z]$  [36];
4   Determine  $\theta_{fp}$  using Equation (15) (or  $\theta_{mp}$  using Equation (28));
5   Determine  $L_{fp}$  using Equation (13) (or  $L_{mp}$  using Equation (26));
6   Determine tendon displacements  $[\Delta L_i]$  using Equation (10) ;
7   Determine tendon tensions  $[F_i]$  using Equation (1);
8   Determine tendon stretches  $[\delta_i]$  Equation (11);
9   Determine tendon actuator displacements  $[\Delta L_{a_i}]$  using Equation (12);
10  Determine base actuator displacement  $\Delta Z_{fp}$  using Equation (16) (or  $\Delta Z_{mp}$ );
11  return  $[\Delta L_{a_i}], \Delta Z_{fp}$  (or  $\Delta Z_{mp}$ );

```

in this paper. Equation (1) can be used to equate tension in the farthest tendon at the back of the continuum structure (tendon  $i_m$ ) to  $F_0$  as

$$F_i(\theta, \phi, L_c) = F_0 \quad i = i_m \tag{17}$$

where  $i_m$  is determined as

$$i_m = \arg \min_{\{i: i=1, \dots, n\}} (R_a \cos(\phi - \alpha_i))$$

Using Equation (17), the new length of continuum structure satisfying minimum  $F_0$  loading condition is derived as

$$L_m(\theta) = C_1 + C_2 \theta \cos(\phi - \alpha_{i_m}) \tag{18}$$

The differences between  $L_m$  and  $L_f$  (Equation 6) is

$$L_m - L_f \begin{cases} = 0, & \text{if } \alpha_{i_m} - \phi = \pi \\ > 0, & \text{otherwise} \end{cases} \tag{19}$$

As implied, the length of the beam structure under moving loading distribution is always bigger than its length under fixed loading distribution, unless the  $i_m$ -th tendon is laid on the bending plane ( $\alpha_{i_m} - \phi = \pi$ ). This is because  $(\alpha_{i_m} - \phi)$  is always larger than  $\pi/2$  which means that  $L_f$  and  $L_m$  only equate when the later has its minimum value

$$L_f = \min(L_m) \tag{20}$$

This produces less compression in the continuum structure and consequently less tension in tendons. Both orientation and tip position of a continuum robot can be controlled under moving loading distribution that are explained in the following sections.

**A. ORIENTATION CONTROL**

To control the pointing angle of a continuum robot under moving loading distribution, Equation (18) may be used to find the length of the continuum structure ( $L_{mo}$  in Figure 4) satisfying the minimum  $F_0$  loading condition as

$$L_{mo} = L_m(\theta) \quad k \geq 2 \tag{21}$$

Similar to orientation control under fixed loading distribution, to control orientation angle under moving loading distribution, parameters  $\theta$  and  $\phi$  are needed for the algorithm to obtain the maximum length of the continuum structure ( $L_{mo}$ ) satisfying  $F_0$  loading condition (Algorithm 1). Substituting Equation (21) into the Equation (1), the required tendon tensions for orientation control of a  $n$ -tendon continuum robot under moving loading distribution is

$$F_{i_{mo}}(\theta, \phi) = F_0 - \frac{EI(k-1)}{nL_0 R_a} \theta \times \begin{cases} \cos(\phi - \alpha_i) - \cos(\phi - \alpha_{i_m}) \\ i = 1, \dots, n \\ k \geq 2 \end{cases} \tag{22}$$

The behavior of the orientation control algorithm under moving loading distribution is studied using the numerical simulation for similar beam configurations and  $F_0$  as in previous simulations. The results are presented in Figure 5b. This orientation control algorithm is also independent of the given  $L$  and, therefore, for both given  $L_{SS}$  and  $L_E$ , the results are similar. The peak values of the tendon tensions in this simulation (Table 3, #6) are identical to those of the orientation control under fixed loading distribution (Table 3, #3 and Figure 5b) which demonstrates the effectiveness of this algorithm in avoiding slack and excessive loading the tendons.

The summation of the tension loadings in all tendons for orientation control of a continuum robot under moving loading distribution can be derived from (Equation 22) as

$$\sum_{i=1}^n F_{i_{mo}} = nF_0 + \frac{EI(k-1)}{L_0 R_a} \theta \times \cos(\phi - \alpha_{i_m}) \quad k \geq 2 \tag{23}$$

Comparing this equation with Equation (9) results in


$$\left| \sum_{i=1}^n F_{i_{mo}} \right| - \left| \sum_{i=1}^n F_{i_{fo}} \right| \begin{cases} = 0, & \text{if } \alpha_{i_m} - \phi = \pi \\ < 0, & \text{otherwise} \end{cases} \tag{24}$$

which means that manipulating a continuum robot under moving loading distribution always produces less tendon

tensions than those produced under fixed loading distribution unless the  $i_m$ -th tendon is laid on the bending plane ( $\alpha_{i_m} - \phi = \pi$ ). This can be expressed as

$$\left| \sum_{i=1}^n F_{i_{fo}} \right| = \max \left( \left| \sum_{i=1}^n F_{i_{mo}} \right| \right) \quad (25)$$

Figure 6 shows the simulation results for summation of the tension loads for orientation control under fixed and moving average distributions with respect to  $\phi$ . As shown in this figure and also implied from (Equation 23), unlike the summation of tensions in orientation control under fixed loading distribution (Equation (9)) that is a function of only  $\theta$ , this summation under moving distribution is a function of both  $\theta$  and  $\phi$ . Therefore, it has variable values ranging from -18.97 N to -21.9 N (Table 3, #6). The results verify Equation (25). The moving loading distribution also causes movements in both locations of zero-load and neutral axes (Table 3, #6).



**FIGURE 6.** Summation of the tension loads in all tendons calculated in the simulation for orientation control under both fixed and moving loading distributions with respect to the bending plane angle  $\phi$ .

There is no excessive loading in tendons as their tensions reach the minimum absolute values of zero ( $F_0 = 0$  in this case) when they meet the virtual tendon (Figure 2d). A characteristic feature of the moving loading distribution, as shown in Figure 5b, is that in every beam configurations one of the tendons has the minimum  $F_0$  tension loading. This is a key difference between the fixed and moving loading distributions as in fixed loading distribution the tension in one of the tendons is  $F_0$  only when the tendon is laid on the bending plane. Similar to fixed loading distribution, this feature exists in both orientation and position control under moving loading distribution.

## B. POSITION CONTROL

It is also possible to control the tip position of a continuum robot under moving loading distribution to avoid slack and excessive loading in tendons. However, similar to position control under fixed loading distribution, an axial displacement of the base of the continuum structure is needed to reach the target tip position. Two constraints are defined to satisfy no slack and excessive loading as well as  $x$  and  $y$  coordinates conditions. The first constraint is to have minimum  $F_0$  loading on the  $i_m$ -th tendon which is, based on the Equation (18), defined as

$$L_{mp} = R_{mp}\theta_{mp} = C_1 + C_2\theta_{mp} \cos(\phi - \alpha_{i_m}) \quad (26)$$

where  $R_{mp}$ ,  $\theta_{mp}$ , and  $L_{mp}$  are the new radius, bending angle, and length of the continuum structure satisfying the desired conditions represented by the dash-dot line in Figure 4. The second constraint guaranteeing similar  $x$  and  $y$  coordinates for both tip points  $p$  and  $p_{mp}$  is defined as

$$R_{mp} = \frac{1 - \cos(\theta)}{1 - \cos(\theta_{mp})} \times \frac{L}{\theta} \quad (27)$$

Substituting Equation (27) into Equation (26) leads to a single-variable equation in  $\theta_{mp}$

$$\frac{C_1}{\theta_{mp}} + C_2 \cos(\phi - \alpha_{i_m}) = \frac{1 - \cos(\theta)}{1 - \cos(\theta_{mp})} \times \frac{L}{\theta} \quad (28)$$

Oposed to  $\theta_{fp}$  determined from Equation (15) which is a function of only  $\theta$ ,  $\theta_{mp}$  derived from Equation (28) is a function of  $\theta$ ,  $\phi$ , and  $\alpha_{i_m}$ . This introduces dependency to  $\phi$  and  $\alpha_{i_m}$  in parameters  $L_{mp}$  and consequently  $\Delta Z_{mp}$  and  $F_{i_{mp}}$ . By finding  $\theta_{mp}$  from Equation (28) and substituting it back into Equation (27) and then in Equation (26), configuration variables  $L_{mp}$  and  $\theta_{mp}$  are determined. Similar to position control under moving loading distribution, the required base displacement to compensate for  $\Delta Z_{mp}$  can be derived using Equation (16) based on  $\theta_{mp}$ .

As described in Algorithm 2, to manipulate a continuum robot to the beam configuration  $[\theta, \phi, L]$  corresponding to the given tip position  $[x, y, z]$  under moving loading distribution, the robot and base DOF should be commanded to the beam configuration  $[\theta_{mp}, \phi, L_{mp}]$  and  $\Delta Z_{mp}$ , respectively. This moves the tip of the continuum structure to  $[x, y, z]$  coordinates and satisfy no-slack and minimum  $F_0$  loading conditions.


The numerical simulations for similar beam configurations and  $F_0 = 0$  for position control of a 6-tendon continuum robot under moving loading distribution results in similar tendon tension pattern as shown in Figure 5b, but with different peak values (Table 3, #7 and #8). As expected, these peak values are still identical with those of the position control under fixed loading distribution. The results verify the expected dependency of  $\Delta Z_{mp}$  and  $F_{i_{mp}}$  to  $\phi$  and  $\alpha_{i_m}$  parameters as well as their relations with  $\Delta Z_{fp}$  and  $F_{i_{fp}}$ .

## VI. EXPERIMENTS

### A. EXPERIMENTAL SETUP

The 6-tendon robotic catheter system, shown in Figure 7, is employed to experimentally evaluate the control algorithms and validate simulation results. The system is integrated with a real-time vision-based shape sensing system that enables the 3D reconstruction of the catheter tube at the rate of 200 Hz with accuracy of  $\pm 0.6$  mm and  $\pm 0.5$  deg for the linear and angular parameters, respectively [37]. DC geared motors (Model EC-max 22, Maxon Motors Inc., 6072 Sachseln, Switzerland) are utilized for the actuation of the tendons. The base of this robotic system is fixed and not actuated. Load-cells (Model FC22, Phidgets Inc., Calgary, Canada) are incorporated into the actuation modules using a flexure mechanism to measure the tension loads in tendons.






**FIGURE 7.** The developed modular continuum robotic system capable of manipulating robots with up to 6 tendons integrated with a real-time vision-based 3D reconstruction system [34].

Mechanical parameters of the continuum structure and tendons are listed in Table 1 which are similar to those used in the numerical simulations. Although these parameters are readily available for the prototype in the experimental setup, they need to be either measured or obtained from manufacturer for off-the-shelf continuum robots and catheters. Tendons used in this setup are Spectra microfilament braided lines (Spectra, PowerPro Inc., Irvine, CA, United States). To decrease the friction between the tendon and pulleys, low-friction pulleys with ball bearing are employed in the system. The 6-lumen catheter was molded of urethane rubber (PMC 780, Smooth-On Inc., Macungie, PA, United States). The Young’s modulus of the tubes and tendons are measured using an Instron 5566 universal testing machine. Tendons are passed through the lumens and knotted to the actuator spools from one end and to a cap part from the other end at termination point at distal end of the catheter. The system was operated by a PC with Intel Core i7 processors running at 3.00 GHz with 16 Gb of memory.

**B. EXPERIMENT PROCEDURE AND RESULTS**

To evaluate the effectiveness of the proposed methods, the cases presented in Figure 3, namely beam configurations  $[\theta, \phi, L_{SS}]$  and  $[\theta, \phi, L_E]$  respectively causing slack and excessive loading using inverse kinematics solution, as well as the beam configurations modified by the proposed algorithms to avoid slack and excessive loadings are experimentally examined and the results are presented here.  $F_0$  is considered zero in experiments. Before commanding the robot to a configuration, the catheter was commanded to its home configuration (at rest in vertical position with zero tension in tendons) as shown in Figure 7.

Figure 8 presents the experimental results for the beam configurations of  $[\theta, \phi, L_{SS}]$  and  $[\theta, \phi, L_E]$  causing slack and excessive loading in tendons, respectively. As implied from Figure 8a (peak values of 0 and  $-5.34$  N), at most of the configurations, tendons have zero tension loads which is an indication of slacked tendon. Slacked tendons do not




**FIGURE 8.** Experimental results for the tendon tension loads in a 6-tendon continuum robot for the beam configurations (a)  $[\theta, \phi, L_{SS}]$  causing mean bending angle error of 19.77 deg and  $[\theta, \phi, L_E]$  (b) causing mean bending angle error of 1.63 deg.


produce any load, therefore, slacked tension loads measured by load-cells at these configurations are zero. Results shown in Figure 8b presents excessive loadings in tendons ranging from  $-2.56$  to  $-10.96$  N. Experimental results are in good confirmation with simulation results (Figure 3) in terms of trend and magnitude for both cases of slack and excessive loading (Table 3). It is worth noting that the tension loads obtained from all experiments have higher magnitudes than corresponding loads obtained from numerical simulations. This correlation that exists across all experiments may be due to friction, nonlinearity, and viscoelasticity in the materials [32], [33].

Experimental results for orientation control algorithm under fixed loading distribution for beam configurations  $[\theta, \phi, L_{SS}]$  are presented in Figure 9a. Figures 9b and 9c display the tendon tensions measured in experiments for the position control algorithm under fixed loading distribution for beam configurations  $[\theta, \phi, L_{SS}]$  and  $[\theta, \phi, L_E]$ , respectively. Figure 10 presents the experimental results for orientation and position control algorithms under moving loading distribution based on the beam configurations  $[\theta, \phi, L_{SS}]$  and  $[\theta, \phi, L_E]$ . Both orientation and position control algorithms under fixed and moving loading distributions satisfy no-slack and minimum  $F_0$  ( $F_0 = 0$  in experiments) loading conditions. They also match the simulation results listed in Figure 5 in terms of peak values and loading distributions.

Figures 11a and 11b present errors in the bending angles measured in experiments with respect to the desired bending angle (Table 2) for the orientation and position control



**FIGURE 9.** Experimental results for the tendon tension loads in a 6-tendon continuum robot for (a) orientation control of beam configurations  $[\theta, \phi, L_{SS}]$ , (b) position control of beam configurations  $[\theta, \phi, L_{SS}]$ , and (c) position control of beam configurations  $[\theta, \phi, L_E]$  under fixed loading distribution.




**FIGURE 10.** Experimental results for the tendon tension loads in a 6-tendon continuum robot for (a) orientation control of beam configurations  $[\theta, \phi, L_{SS}]$ , (b) position control of beam configurations  $[\theta, \phi, L_{SS}]$ , and (c) position control of beam configurations  $[\theta, \phi, L_E]$  under moving loading distribution.

algorithms under fixed and moving loading distributions for the beam configurations  $[\theta, \phi, L_{SS}]$  and  $[\theta, \phi, L_E]$ , respectively. As shown in Figure 11a, slacked tendons negatively affect the control accuracy of continuum robot; mean error of 19.77 deg in  $\theta$ . On the other hand, despite its disadvantages, excessive loading produced more accurate manipulation; mean error of 1.63 deg in  $\theta$  in Figure 11b. Orientation and position control algorithms under fixed and moving loading distributions decreased the errors down to the range of 3.51 to 4.96 deg. Given the open-loop nature of the testing and evaluation process, the results demonstrate good accuracy and effectiveness for the proposed control algorithms.

For both cases of  $[\theta, \phi, L_{SS}]$  and  $[\theta, \phi, L_E]$ , the errors for orientation control algorithm are similar as these algorithms are independent of length. There are no significant differences between the errors for orientation and position control algorithms for any of the cases of slack or excessive loadings.

This is because of small differences between the desired  $\theta$  for both cases of slack and excessive loading (40 deg) and  $\theta_{fp}$  (40.74 and 39.31 deg) and  $\theta_{mp}$  (40.6 to 40.74 and 39.18 to 39.31 deg) determined respectively from Equations (15) and (28) for the cases of slack and excessive loading.

To better demonstrate the capability of the algorithms in controlling orientation and position of the continuum structure, a new set of beam configuration is chosen ( $[\theta, \phi, L_{AS}]$  - Table 2). This configuration is chosen to produce considerable differences between the given  $\theta$  and  $L$  and those determined from the orientation and position control algorithms. Given the initial length of the continuum structure, commanding the robot to this configuration causes slack in all tendons which results in no movement in the continuum structure. To reach this exact beam configuration, base displacement is required. However, as explained in previous sections, for position control requiring base displacements, a new coordinates is derived to satisfy x and y coordinates



**FIGURE 11.** Mean and standard deviation of orientation errors for (a) beam configurations  $[\theta, \phi, L_{SS}]$ , (b) beam configuration  $[\theta, \phi, L_E]$  as well as mean orientation and position errors for (c) configurations  $[\theta, \phi, L_{AS}]$  for the orientation and position control algorithms under fixed (F-O and F-P) and moving (M-O and M-P) loading distributions in a 6-tendon continuum robot.


of the original target point while the axial displacement of the base compensates for the target  $z$  coordinate. Since the experimental setup does not allow base movements, the new point satisfying  $x$  and  $y$  coordinates is utilized. This is not expected to have any effects on accuracy because the required base movement is a pure straight displacement and does not involve any manipulations in the continuum structure.

The errors in experimental results for bending angle and tip position for the case of traditional inverse kinematics as well as four control algorithms are listed in Figure 11c. Although each algorithm has different target orientation and tip position, the errors are calculated with respect to the original target beam configurations. For the orientation angles, the given  $\theta$  (40 deg) is used as the reference. The vector sum of  $x$  and  $y$  coordinates of the tip position ( $D_{xy}$  in Figure 4) corresponding to  $[\theta, \phi, L_{AS}]$  (58.64 mm) is chosen as the reference for calculating errors in tip positions for different control algorithms. The first column of this figure shows errors as big as the target  $\theta$  and  $D_{xy}$  calculated from the kinematics of the continuum structure for the target configuration. The reason for such big errors is that commanding the actuators displacements calculated using the inverse kinematics for the target configuration ( $[\theta, \phi, L_{AS}]$ ) simply does not cause any

movement in the robot at all and only makes all tendons go slack.

As implied from Figures 11c, orientation control algorithms under both fixed and moving loading distributions produced errors as low as 4.35 and 4.18 deg in the bending angle, respectively. Since the objective of these control algorithms is not tip position control, the tip position differences with respect to the given configurations is relatively large; 10.12 and 10.81 mm for fixed and moving loading distributions, respectively. On the other hand, position control algorithms produce small position errors of 3.17 and 3.21 mm under two fixed and moving loading distributions, respectively. The orientation errors of position control algorithms under the two loading distributions (1.13 and 1.32 mm, respectively) listed in this figure are lower than those of the orientation control algorithms. This is because the listed errors are calculated based on the given  $\theta$  which means the orientation errors for the case of the position control algorithm do not represent the actual orientation error. Computing these errors with respect to the new bending angles calculated by the algorithms ( $\theta_{fp}$  and  $\theta_{mp}$  from Equations (15) and (28), respectively) produces similar orientation errors as of those in orientation control algorithms for the two loading distributions. These results demonstrates the capability of the proposed control algorithms in controlling orientation and tip position of a continuum robot.

Figure 12 presents the experimental results for the summation of the tension loads in all tendons for each bending plane angle  $\phi$  for orientation control (Figure 12a), position control of beam configuration  $[\theta, \phi, L_{SS}]$  (Figure 12b),



**FIGURE 12.** Summation of the tension loads in all tendons measured in experiments for (a) orientation control, (b) position control of beam configuration  $[\theta, \phi, L_{SS}]$  and (c)  $[\theta, \phi, L_E]$  under both fixed and moving loading distributions with respect to the bending plane angle  $\phi$ .

and  $[\theta, \phi, L_E]$  (Figure 12c) under both fixed and moving loading distributions. The experimental results match the simulation results presented in Figure 6 in terms of the magnitude and overall pattern. As implied from these figures, summation of the tension loads for orientation and position control under fixed loading distribution are mostly around the maximum absolute values of those of the similar control algorithms under moving loading distribution. In other words, moving loading distribution always produces less tension in tendons than the fixed loading distribution unless the  $i_m$ -th tendon is laid on the bending plane ( $\alpha_{i_m} - \phi = \pi$ ) in which case the tensions are equal for both loading distributions.

## VII. DISCUSSION

As shown in Figure 12, in a 6-tendon robot, the fixed and moving loading distributions lead to similar tendon tension summations at the bending plane angles of  $[0, 60, 120, \dots, 360]$  deg. Interestingly, the number of maximum peak values ( $N_{mp}$ ) of the tension summation is directly related to the number of tendons  $n$  in the continuum structure. In continuum robots with even number of tendons, the peak values are repeated at the bending plane angles of 0 and 360 deg. However, there is no peak value at the bending plane angle 0 deg in continuum robots with odd number of tendons. This results in no repetition of the peak values in continuum robots with odd number of tendons. It is worth noting that this difference is dependent of the location of the tendons. This relationship is represented as

$$N_{mp} = \begin{cases} n & \text{when } n \text{ is odd} \\ n + 1 & \text{when } n \text{ is even} \end{cases} \quad (29)$$

Experimental results validated the numerical simulation and verified the performance of the proposed control algorithms under fixed and moving loading distributions in controlling orientation and position of a 6-tendon continuum robot. The algorithms are proved to be capable of avoiding slack and excessive loading in multi-tendon continuum robots even in open-loop control architecture for a polymer-based continuum manipulator. Based on the application control requirements, e.g. orientation or position control, computational capabilities of the controller, e.g. analytical or numerical iterative solutions, hardware specification, e.g. DOFs and robot workspace, and manipulation features, e.g. motion smoothness, the proposed control algorithms may be chosen to manipulate a continuum robot with any number of tendons without concern about slack deficiencies or excessive loading damage.

Stiffness of a continuum structure may be controlled by manipulating the tension loads in tendons. Reduction of the stiffness of the continuum robot can enable safe navigation inside delicate confined spaces, e.g. to avoid wall puncture. In contrast, a high stiffness continuum structure may be advantageous during tissue manipulation [14], [38], [39]. In order to avoid both slack and unnecessary loading in tendons and also to adjust stiffness in the continuum structure,

the location of the zero-load axis can be moved behind virtual tendon so that there is a minimum tension loading of  $F_0$  in the virtual tendon. The minimum tension loading  $F_0$  in tendons may be used to trade off between tension loading magnitudes and beam manipulator stiffness required for any applications. Changing  $F_0$  directly affects the stiffness of the manipulator. The larger  $F_0$  values, the stiffer manipulator. The minimum allowable value of  $F_0$  is zero and negative values cause slack in some or all of the tendons.

## VIII. CONCLUSION

In this work, orientation and position control algorithms developed based on two fixed and moving loading distributions in  $n$ -tendon continuum robots. These loading distributions were designed to prevent slack and excessive loading in tendons. The algorithms were developed to account for the bending and axial compliance of the continuum structure as well as tendon compliance. Numerical simulations were performed to help describe the control algorithms and their key characteristic features under fixed and moving loading distributions. The effectiveness of the proposed control algorithms in avoiding slack and excessive loadings in tendons and controlling the orientation and tip position of the continuum structure for different beam configurations was experimentally verified using a 6-tendon continuum robotic system in open-loop control architecture. Future works may take friction and external loading and disturbance into consideration and address experimental characterization of off-the-shelf catheters and continuum robots.

## REFERENCES

- [1] R. Cieslak and A. Morecki, "Elephant trunk type elastic manipulator—A tool for bulk and liquid materials transportation," *Robotica*, vol. 17, no. 1, pp. 11–16, Jan. 1999.
- [2] I. D. Walker, D. M. Dawson, T. Flash, F. W. Grasso, R. T. Hanlon, B. Hochner, W. M. Kier, C. C. Pagano, C. D. Rahn, and Q. M. Zhang, "Continuum robot arms inspired by cephalopods," in *Proc. Defense Secur.*, May 2005, pp. 303–314.
- [3] W. M. Kier, "The functional morphology of the musculature of squid (Loliginidae) arms and tentacles," *J. Morphol.*, vol. 172, no. 2, pp. 179–192, May 1982.
- [4] M. Tanaka and K. Tanaka, "Control of a snake robot for ascending and descending steps," *IEEE Trans. Robot.*, vol. 31, no. 2, pp. 511–520, Apr. 2015.
- [5] A. M. Andruska and K. S. Peterson, "Control of a snake-like robot in an elastically deformable channel," *IEEE/ASME Trans. Mechatronics*, vol. 13, no. 2, pp. 219–227, Apr. 2008.
- [6] G. Granosik, M. G. Hansen, and J. Borenstein, "The OmniTread serpentine robot for industrial inspection and surveillance," *Ind. Robot, Int. J.*, vol. 32, no. 2, pp. 139–148, Apr. 2005.
- [7] A. Wolf, H. B. Brown, R. Casciola, A. Costa, M. Schwerin, E. Shamas, and H. Choset, "A mobile hyper redundant mechanism for search and rescue tasks," in *Proc. IEEE/RSJ Int. Conf. Intell. Robots Syst. (IROS)*, vol. 3, Oct. 2003, pp. 2889–2895.
- [8] H. B. Gilbert, J. Neimat, and R. J. Webster, "Concentric tube robots as steerable needles: Achieving Follow-the-Leader deployment," *IEEE Trans. Robot.*, vol. 31, no. 2, pp. 246–258, Apr. 2015.
- [9] N. Simaan, K. Xu, W. Wei, A. Kapoor, P. Kazanzides, R. Taylor, and P. Flint, "Design and integration of a telerobotic system for minimally invasive surgery of the throat," *Int. J. Robot. Res.*, vol. 28, no. 9, pp. 1134–1153, Sep. 2009.
- [10] B. A. Jones and I. D. Walker, "Kinematics for multisection continuum robots," *IEEE Trans. Robot.*, vol. 22, no. 1, pp. 43–55, Feb. 2006.

- [11] Y.-J. Kim, S. Cheng, S. Kim, and K. Iagnemma, "A novel layer jamming mechanism with tunable stiffness capability for minimally invasive surgery," *IEEE Trans. Robot.*, vol. 29, no. 4, pp. 1031–1042, Aug. 2013.
- [12] C. Bergeles, A. H. Gosline, N. V. Vasilyev, P. J. Codd, P. J. del Nido, and P. E. Dupont, "Concentric tube robot design and optimization based on task and anatomical constraints," *IEEE Trans. Robot.*, vol. 31, no. 1, pp. 67–84, Feb. 2015.
- [13] Y.-J. Kim, S. Cheng, S. Kim, and K. Iagnemma, "A stiffness-adjustable hyperredundant manipulator using a variable neutral-line mechanism for minimally invasive surgery," *IEEE Trans. Robot.*, vol. 30, no. 2, pp. 382–395, Apr. 2014.
- [14] I. D. Walker, "Continuous backbone 'continuum' robot manipulators," *ISRN Robot.*, vol. 2013, pp. 1–19, Jul. 2013.
- [15] R. J. Webster and B. A. Jones, "Design and kinematic modeling of constant curvature continuum robots: A review," *Int. J. Robot. Res.*, vol. 29, no. 13, pp. 1661–1683, Nov. 2010.
- [16] A. Müller, "Internal preload control of redundantly actuated parallel manipulators—Its application to backlash avoiding control," *IEEE Trans. Robot.*, vol. 21, no. 4, pp. 668–677, Aug. 2005.
- [17] D. B. Camarillo, C. F. Milne, C. R. Carlson, M. R. Zinn, and J. K. Salisbury, "Mechanics modeling of tendon-driven continuum manipulators," *IEEE Trans. Robot.*, vol. 24, no. 6, pp. 1262–1273, Dec. 2008.
- [18] A. Trevisani, "Planning of dynamically feasible trajectories for translational, planar, and underconstrained cable-driven robots," *J. Syst. Sci. Complex.*, vol. 26, no. 5, pp. 695–717, Oct. 2013.
- [19] Y. Chen, J. H. Chang, A. S. Greenlee, K. C. Cheung, A. H. Slocum, and R. Gupta, "Multi-turn, tension-stiffening catheter navigation system," in *Proc. IEEE Int. Conf. Robot. Autom. (ICRA)*, May 2010, pp. 5570–5575.
- [20] M. Gouttefarde, J. Lamaury, C. Reichert, and T. Bruckmann, "A versatile tension distribution algorithm for  $n$ -DOF parallel robots driven by  $n + 2$  cables," *IEEE Trans. Robot.*, vol. 31, no. 6, pp. 1444–1457, Dec. 2015.
- [21] R. L. Williams, P. Gallina, and J. Vadia, "Planar translational cable-direct-driven robots," *J. Robot. Syst.*, vol. 20, no. 3, pp. 107–120, Mar. 2003.
- [22] M. Carricato and J.-P. Merlet, "Stability analysis of underconstrained cable-driven parallel robots," *IEEE Trans. Robot.*, vol. 29, no. 1, pp. 288–296, Feb. 2013.
- [23] S. Fang, D. Franitza, M. Torlo, F. Bekes, and M. Hiller, "Motion control of a tendon-BasedParallel manipulator using optimal tension distribution," *IEEE/ASME Trans. Mechatronics*, vol. 9, no. 3, pp. 561–568, Sep. 2004.
- [24] P. H. Borgstrom, B. L. Jordan, G. S. Sukhatme, M. A. Batalin, and W. J. Kaiser, "Rapid computation of optimally safe tension distributions for parallel cable-driven robots," *IEEE Trans. Robot.*, vol. 25, no. 6, pp. 1271–1281, Dec. 2009.
- [25] M. C. Yip, J. A. Sganga, and D. B. Camarillo, "Autonomous control of continuum robot manipulators for complex cardiac ablation tasks," *J. Med. Robot. Res.*, vol. 02, no. 1, Mar. 2017, Art. no. 1750002.
- [26] D. B. Camarillo, C. R. Carlson, and J. K. Salisbury, "Configuration tracking for continuum manipulators with coupled tendon drive," *IEEE Trans. Robot.*, vol. 25, no. 4, pp. 798–808, Aug. 2009.
- [27] M. Haghighipanah, M. Miyasaka, and B. Hannaford, "Utilizing elasticity of cable-driven surgical robot to estimate cable tension and external force," *IEEE Robot. Autom. Lett.*, vol. 2, no. 3, pp. 1593–1600, Jul. 2017.
- [28] T. Kato, I. Okumura, S.-E. Song, A. J. Golby, and N. Hata, "Tendon-driven continuum robot for endoscopic surgery: Preclinical development and validation of a tension propagation model," *IEEE/ASME Trans. Mechatronics*, vol. 20, no. 5, pp. 2252–2263, Oct. 2015.
- [29] B. L. Conrad and M. R. Zinn, "Interleaved continuum-rigid manipulation: An approach to increase the capability of minimally invasive surgical systems," *IEEE/ASME Trans. Mechatronics*, vol. 22, no. 1, pp. 29–40, Feb. 2017.
- [30] M. Khoshnam and R. V. Patel, "Tendon-sheath analysis for modeling and control of steerable ablation catheters," in *Proc. IEEE Int. Conf. Adv. Intell. Mechatronics (AIM)*, Jul. 2016, pp. 1585–1590.
- [31] E. Naerum, H. H. I. King, and B. Hannaford, "Robustness of the unscented Kalman filter for state and parameter estimation in an elastic transmission," in *Proc. Robot., Sci. Syst.*, 2009, pp. 1–8.
- [32] S. N. Kosari, S. Ramadurai, H. J. Chizeck, and B. Hannaford, "Control and tension estimation of a cable driven mechanism under different tensions," in *Proc. ASME Int. Design Eng. Tech. Conf. Comput. Inf. Eng. Conf.*, 2013, Art. no. V06AT07A077.
- [33] R. Roy, L. Wang, and N. Simaan, "Modeling and estimation of friction, extension, and coupling effects in multisegment continuum robots," *IEEE/ASME Trans. Mechatronics*, vol. 22, no. 2, pp. 909–920, Apr. 2017.
- [34] M. M. Dalvand, S. Nahavandi, and R. D. Howe, "An analytical loading model for  $n$ -tendon continuum robots," *IEEE Trans. Robot.*, vol. 34, no. 5, pp. 1215–1225, Oct. 2018.
- [35] P. M. Loschak, L. J. Brattain, and R. D. Howe, "Automated pointing of cardiac imaging catheters," in *Proc. IEEE Int. Conf. Robot. Autom. (ICRA)*, May 2013, pp. 5794–5799.
- [36] B. He, Z. Wang, Q. Li, H. Xie, and R. Shen, "An analytic method for the kinematics and dynamics of a multiple-backbone continuum robot," *Int. J. Adv. Robot. Syst.*, vol. 10, no. 1, p. 84, Jan. 2013.
- [37] M. Moradi Dalvand, S. Nahavandi, and R. D. Howe, "Fast vision-based catheter 3D reconstruction," *Phys. Med. Biol.*, vol. 61, no. 14, pp. 5128–5148, Jul. 2016.
- [38] M. Mahvash and P. E. Dupont, "Stiffness control of surgical continuum manipulators," *IEEE Trans. Robot.*, vol. 27, no. 2, pp. 334–345, Apr. 2011.
- [39] M. Mahvash and P. E. Dupont, "Stiffness control of a continuum manipulator in contact with a soft environment," in *Proc. IEEE/RSJ Int. Conf. Intell. Robots Syst. (IROS)*, Oct. 2010, pp. 863–870.



**MOHSEN MORADI DALVAND** received the Ph.D. degree in mechanical engineering from Monash University, Australia. He then worked as a Research Fellow in robotics and haptics at the Institute for Intelligent Systems Research and Innovation (IISRI), Deakin University, Australia. He then joined the Harvard Paulson School of Engineering and Applied Sciences, Harvard University. He is a Principal Controls Engineer (Test Lead) with Medtronic Surgical Robotics MITG. His research interests include robotics and automation with a special focus on surgical robotics and medical instrumentation.



**SAEID NAHAVANDI** (Fellow, IEEE) received the Ph.D. degree from Durham University, U.K., in 1991. He is currently an Alfred Deakin Professor, a Pro Vice-Chancellor, a Chair of Engineering, and the Founding Director of the Institute for Intelligent Systems Research and Innovation, Deakin University. He has published over 900 scientific papers in various international journals and conferences. His research interests include modeling of complex systems, robotics, and haptics.

Dr. Nahavandi is a Fellow of Engineers Australia (FIEAust), the Institution of Engineering and Technology (FIET), and a Fellow of the Australian Academy of Technology and Engineering (ATSE). He is an Editor-In-Chief of the *IEEE SMC Magazine*, an Senior Associate Editor of the *IEEE SYSTEMS JOURNAL*, an Associate Editor of the *IEEE TRANSACTIONS ON CYBERNETICS*, and the *IEEE Press Editorial Board* member.



**ROBERT D. HOWE** (Fellow, IEEE) received the bachelor's degree in physics from the Reed College and the Ph.D. degree in mechanical engineering from Stanford University. He is currently the Abbott and James Lawrence Professor of engineering with the Harvard Paulson School of Engineering and Applied Sciences. Then, he worked in the electronics industry in Silicon Valley. He joined the faculty at Harvard, in 1990. He directs the Harvard BioRobotics Laboratory, which investigates the roles of sensing and mechanical design in motor control, in both humans and robots. His research interests focus on manipulation, the sense of touch, and robot-assisted, and image-guided surgery. He is a Fellow of the AIMBE.

• • •