

Received October 9, 2021, accepted October 19, 2021, date of publication October 26, 2021, date of current version November 4, 2021.

Digital Object Identifier 10.1109/ACCESS.2021.3123153

Energy Conservation Approach for Continuous Power Quality Improvement: A Case Study

LALITH PANKAJ RAJ NADIMUTHU¹, KIRUBAKARAN VICTOR¹,
CHAKARAJAMULA HUSSAIAN BASHA², T. MARIPRASATH²,
C. DHANAMJAYULU³, (Senior Member, IEEE),
SANJEEVIKUMAR PADMANABAN^{4,5}, (Senior Member, IEEE),
AND BASEEM KHAN⁶, (Senior Member, IEEE)

¹Centre for Rural Energy, The Gandhigram Rural Institute (Deemed to be University), Chinnalapatti, Tamil Nadu 624302, India

²K. S. R. M. College of Engineering (Autonomous), Kadapa, Andhra Pradesh 516003, India

³School of Electrical Engineering, VIT University, Vellore 632014, India

⁴CTIF Global Capsule, Department of Business Development and Technology, Aarhus University, 8000 Aarhus, Denmark

⁵Renewable Energy Laboratory (REL), Communication and Networking Department, Prince Sultan University, Riyadh 11586, Saudi Arabia

⁶Department of Electrical and Computer Engineering, Hawassa University, Awassa 1530, Ethiopia

Corresponding authors: Kirubakaran Victor (kirbakaran@yahoo.com) and Baseem Khan (baseem.khan04@ieee.org)

ABSTRACT This work focused on a harmonic mitigating filter and investigated the effect of the harmonic mitigating filter in the textile industry with innovative energy conservation strategies for energy bill reduction, which covers a pathway to climate change mitigation. Here, the effect of the harmonic filter is found out by the systematic energy audit methodology (Preliminary, Detailed and Post-Audit phase). From the energy auditing, it has been found that the textile industry needed a passive harmonic filter for harmonic mitigation. Since, third, fifth, and seventh order of harmonic predominantly exists in the system. The high stability at higher current, known tuning frequency, low cost and low power consumption makes the passive filter to be the best fit for the system. The voltage and current Total Harmonic Distortion Factor (THDF) have been measured using the class 'A' power quality and energy analyzer. The harmonic filter's effect in harmonics mitigation is prominent; 66.45% of the reduction of current harmonics which is achieved after installing the passive filter at the Point of Common Coupling (PCC) of the system. Also, the reduction of harmonics ensures energy conservation through the reduction of additional losses (joule, copper and eddy current losses). The techno-economic analysis with payback period calculation is carried out and reported. Also, the effect of harmonics like mechanical anomalies (temperature rise) is carefully studied using an infrared thermo graphic technique in the textile industry's motor loads. The energy conservation and their carbon emission reduction are calculated and reported.

INDEX TERMS Carbon emission reduction, energy audit, energy conservation, harmonic mitigation, passive mitigation techniques, and power quality.

I. INTRODUCTION

According to the Energy Conservation Act of India, the textile industry is conserved as one of the highly energy-intensive industries. India is the third-largest textile exporter in the global arena. In India, the textile industry contributes 2% of the country's Gross Domestic Product (GDP) and 12% of export earnings. According to the India Brand Equity Foundation (IBEF), the Indian textile market's size is expected to touch the US \$223 by 2021, growing at a Compound Annual

Growth Rate (CAGR) of 10.23% over 2016. The growth rate is equally proportional to energy consumption. Therefore, the energy intensity of the textile industry is rapidly increasing in India. The Power Quality issue (Harmonics) is an undesirable phenomenon that came into existence due to the non-linear electronic components in the power system [1].

The textile industry is fast-growing and completely mechanized by sophisticated machinery to rapidly increase the industry's productivity with high accuracy. This intervention of highly sophisticated machinery has more scope for creating nonlinearities in the system. The Indian textile industries are classified into two which are organized (spinning and

The associate editor coordinating the review of this manuscript and approving it for publication was Javed Iqbal¹.

composite mill) and decentralized (handloom, power loom, and fabric processing sector). According to the Beauru of energy efficiency [1], energy auditing is defined as the verification, monitoring and analysis of energy use, including submission of technical report containing recommendations for improving energy efficiency with cost-benefit analysis and an action plan to reduce energy consumption. Here, the systematic detailed energy auditing of the textile industry is carried out.

This paper aims to perform the real-time critical case comparison with the detuned reactor configuration and without a detuned reactor configuration in the high-tension textile industry for its effectiveness study (or) a key initiative for post-audit assessment. The energy auditing process is kick-started with the industry’s walkthrough audit and came up with a no-cost or low-cost optimization technique for energy cost-cutting. The sophisticated electronic components in the textile automation machinery make the system more complex and prone to nonlinearities, creating harmonic pollution. Table.1, gives the power specifications of the industry and Figure.1 gives the textile industry’s month-wise maximum demand profile; the KVA demand utilization is very low compared with the sanctioned demand. The connected load of the industry is significant with the sanctioned demand. Therefore, sanctioned demand is higher due to the operation pattern, business profile stipulations, and future expansion scope [3].

TABLE 1. Electrical specification of industry under study.

Parameter	Ratings
Sanctioned Demand	250 KVA
Sanctioned Load	259.5 HP + 18 KW
CT Ratio	20 / 5A
PT Ratio	11KV / 110 V




FIGURE 1. Month-wise maximum demand curve of the Industry.

In the global context, the scope for energy conservation in the textile industry is enormous. The energy conservation potential of the Taiwan textile industry is developed with the roadmap to the Kyoto protocol [2]. In Textile Industry, the significant electrical loads like an air compressor, dynamic facilitator, spinning frame, and refrigerator accounts for 17%,

57%, 5.4%, and 1%, respectively. The Taiwanese textile industry’s energy-saving results are about 46.1 kiloton of oil equivalent and 143.7 kiloton of annual carbon reduction from energy utilization. In Pakistan, the textile industry is considered an energy-intensive industry, and a benchmarking of 10-15% of energy-saving potential is possible in the textile industry by implementing environmentally sound energy-saving measures.

The optimal sizing, soft starter, and star-delta transition are employed to achieve maximum efficiency with good power quality. The adoption of cleaner production strategies ensures the energy conservation of Brazil’s textile industries [3]. The new production line is equipped with environmentally sound and energy-efficient raw material, which paves the way for energy saving of 488,921 kWh/month to reduce the overall energy bill and environmental pollution due to energy utilization. In the Chinese model, the energy conservation measures are taken from the production process line optimization and carbon emission reduction through energy conservation. Energy utilization and carbon emission mitigation have a direct correlation to ensure environmental sustainability.

In the Indian context, the textile industry’s energy cost is 15-20% of textile production cost, next to the raw material cost. The industrial process and motor influence on energy conservation are discussed. The authors developed a detailed energy analysis of productive and non-productive machines in the textile industry in Tamil Nadu, India, with a detailed energy saving methodology for the Bale room department, ring spinning, humidification plant, and air compressor. From the results, 56,053 kWh is monthly energy-saving with Rs.2, 52,239 per month. The extensive heterogeneity in the process and various technologies involved in the Indian textile industry [4]. Therefore, the industry’s clustering is challenging to arrive at a benchmark and compare it with global standards and norms. Innovative energy conservation strategies like installing automatic power factor correction capacitor banks and replacing the inefficient and energy-guzzling motors with the energy efficient motors in the spinning mill are suggested.

The energy model is developed for power quality improvement in the textile industry using power factor improvement technologies. The power factor correction capacitor is suggested based on the careful energy analysis, and the effect of the same is verified. The review concludes that the power factor is vital in maintaining the excellent voltage profile, low current profile, and heat generation reduction in the power system and the connected electrical loads. The various forms of the power factor improvement in an SME unit with the underlying design calculations for power capacitors and various power quality issues in a process industry were discussed [5].

In the harmonic environment, replacing super premium (IE4) line start permanent magnet synchronous motor in the place of squirrel cage induction motor is highly recommended to have better power quality in the system. The Voltage Total Harmonic Distortion Factor directly relates the motor temperature rise and copper loss of motor. The Lumped

Parameter Thermal Model (LPTM) is an inverse electric motor loss estimation method [6]. Here, the rotor and winding temperature are calculated critically, and a numerical model is developed for the loss analysis. The electromagnetic and mechanical friction losses are tough to compute in the conventional electrical and mechanical assessment methodologies.

The temperature is a crucial parameter in motor performance, and the temperature measurement method needs some alternative ways and means as an inverse approach to better model development. The overall energy audit process of the farmhouse and its electric motor loads, which in turn helps us to study the replacement of old induction type motor loads into energy-efficient motors in the textile industries. The power quality mitigation is a highly recommended technique for energy conservation [7].

The development of an economical and cost-effective T-connected autotransformer for the harmonic environment by combining two single-phase transformers reduces the weight and volume of the transformer [8]. Also, the 72-pulse output gives the more economic pulse doubling results at 60% of full load. From the review, harmonic mitigation is essential for the economic operation of the power system. The development of multiple-order harmonic mitigating filters as a CONTUNE (Continuously Tuning) filter is proposed, and simulated results show the filter's significant results. The theoretical calculation of harmonics without a filter is about 17.2% [9]. The simulation of the proposed CONTUNE filter is efficiently performing in multiple orders of harmonic mitigation purposes. The overall power quality and system efficiency have been enhanced by installing Smart Energy Management System (SMES) to the intermittent process industry [10].

The harmonic mitigation is achieved by designing and installing an Electronic Quality Regulator (EQR). The harmonic mitigation is ensured by installing electronic controller based harmonic filters in the location [11]. The intervention of renewable energy resources ensures sustainability. Solar photovoltaic has a significant scope in catering for the maximum daytime loads [12]. The load management system is essential for the optimal operating of the connected loads. The average life span of 25 years is assured for solar photovoltaic [13] with more significant energy savings.

The review concluded that power quality mitigation is essential in the industrial power system and is highly necessary for efficient and better performance. Implementing a detuned reactor is ensuring better power quality in the harmonic prone environment of the textile industry. Therefore, better power quality ensures energy conservation. The textile industry's process optimization has significant scope for reducing energy consumption. Also, integrating renewable energy resources is ensuring sustainability. The rooftop solar photovoltaic have a significant scope on the energy conservation of the textile industry with the more significant energy bill reduction.

II. EXISTING POWER INFRASTRUCTURE OF INDUSTRY

The entire process flow diagram of the industry is given in Figure.2. The industry's process kick-started from the raw material of cotton yarn fed into the parallel winding plies in the winder. The winder section is powered by two numbers of 7.5 HP induction motors. The material is then admitted for the twisting process in a Two for One (TFO) twister, powered by three numbers of 10 HP induction motor. Also, the 2HP and 5 HP ring doubles are used in the winder section. The significant energy consuming wrapping process is handled by the sectional wrapper of 30HP and a direct wrapper of 5 HP for beam and weft preparation, a high energy-guzzling process. It is then admitted to five numbers of the parallel (or) series combination of a weaving shuttle loom, which combines three numbers of 3HP and three numbers of 2HP motors. The inspection section is dedicatedly powered by two numbers of 3 HP motor and two numbers of 2 HP loom for quality assurance and inspection purposes. On the whole, 200 HP of installed loads are connected to the power system. In addition, the station loads and auxiliaries are added to the system.




FIGURE 2. Process flow diagram of industry.

III. METHODOLOGY

The energy conservation of the textile industry is kick-started from the preliminary energy audit (or) walk through walk through energy audit. To obtain the scope for no or low-cost energy-saving measures in the industrial operation and the prerequisites for conducting the detailed energy audit by systematically collecting the historical data. The detailed energy audit is started with an objective of energy bill reduction with power quality improvement of industrial operation. Identifying existing electrical infrastructure gives a keynote for a detailed energy audit and to set a reference point. The detailed energy audit results show that voltage and current

Total Harmonic Distortion Factor (THDF) is higher than the norms and standards of IEE 519-2014 and IEC61000-30.

Therefore, a low-cost, highly reliable passive filter (detuned reactor) is designed, proposed, and implemented as a harmonic mitigating technique to maintain the industry's good power quality indices. In addition, the post-audit phase of energy auditing is carried out to obtain the effectiveness of the installed detuned reactor with the systemic energy audit approach. Figure.3 illustrates the overall energy auditing phases of the textile industry under study using the Fluke 435-II class 'A' three-phase energy and power quality analyzer with two configurations like with and without a detuned reactor. The infrared thermo graphic technique is adopted for identifying the mechanical anomalies. The various energy efficiency enhancement strategies are implemented on three-phase induction motors through harmonic mitigation and their effect on the harmonic environment are studied using infrared thermography. The detailed power quality and energy optimization studies were carried out according to the guidelines of the Bureau of Energy Efficiency (BEE).



FIGURE 3. Systematic energy auditing phase using class 'A' Instrument.

A. PROPOSED HARMONIC MITIGATION FILTER

The proposed harmonic mitigating filtering technique is equipped with the combination of a capacitor and a detuned reactor for better power quality enhancement in the system. The detuned reactor and capacitors are configured with the series resonant circuit. The real-time power quality analysis has higher validity for designing a harmonic mitigation filter. The harmonic filter design with the power factor enhancing power capacitors enhances overall power quality [14].

The series resonant frequency is the lowest harmonic frequency present in the power system. These detuned reactors prevent harmonic resonance issues, capacitor overloading, voltage, and current harmonics suppression at the power system level. The Eq's. (1), (2) and (3) are used for calculating the capacity of the power capacitor. Leading KVAR supplied by Power Factor compensation equipment for compensation from 0.9 to 0.99.

$$KVAR = kW * (\tan\phi_1 - \tan\phi_2) \tag{1}$$

$$P_{total} = 0.746 * \text{connected_HP} \tag{2}$$

$$KVAR = 200 * (\tan(25.84) - \tan(8.1)) \tag{3}$$

For a system voltage of (VS) 415 V, 200 kW, 50 Hz, the KVAR of reactive power supplied by power factor compensation equipment with a standard rating is equal to 75 KVAR. The resultant capacitor compensation and the detuned reactor are employed for better harmonic mitigation in the system. The detuned reactor is powered by a 7% relative impedance and at the tuning factor of 3.8. The voltage applied to the capacitor is given by the Eq. (4).

$$V_C = \frac{V_S}{(1 - P)} \tag{4}$$

where the system voltage level (VS) is about 440 V, the voltage applied to the capacitor (VC) is about 446.24 V, and the 480 V is a recommended rated voltage (VR) applied to the capacitor range by considering all the safety factors. The reactive power delivered by the capacitor and detuned reactor combination is given in Eq. (5). The capacitor and detuned reactor combination will deliver 69.75 or 70 KVAR of reactive power at the system voltage level (VS). The reactive power delivered by the capacitor and detuned reactor combination is given in Eq. (6).

$$Q_C = (1 - P) * V_S \tag{5}$$

$$Q_N = Q_C * (V_R / V_C)^2 \tag{6}$$

The capacitor and detuned reactor combination will deliver 93.45 or 94 KVAR of reactive power at the rated voltage level. The textile industry under study is proposed and implemented with the 75 KVAR capacitor detuned reactors for harmonic mitigation in the power system and shown in Figure.4. The harmonic filter is made in the combination of one number of 20 KVAR, two numbers of 15 KVAR, two numbers of 10 KVAR, and one number of 5 KVAR detuned reactors to form the 75 KVAR capacities in the system. The detailed technical specification of each detuned reactor is shown in Table.2. This capacitor enabled detuned reactor has the potential of both harmonic suppression and power factor improvement in the system.




FIGURE 4. Installed detuned reactors.

The operation and control of installed detuned reactor are controlled through the microprocessor based 6 step output contacts. The targeted power factor correction and harmonic compensation are the fundamental operational procedure. The individual power capacitors and detuned reactors are

TABLE 2. Technical specification of detuned reactors.

Parameter	Ratings			
KVAr	20 KVAr	15 KVAr	10 KVAr	5 KVAr
Voltage	440 V	440 V	440 V	440 V
Frequency	50 Hz	50 Hz	50 Hz	50 Hz
Tuning Order	3.8	3.8	4.2	3.8
Inductance	2.282 mH	3.016mH	3.703 mH	9.05 mH
Ierms Max	21.3 A	21.3 A	16.1 A	7.1 A
Insulation level	1.1 kV	1.1 kV	1.1 kV	1.1 kV
Insulation Class	H			
Standard	IS 5553, IEC 60076-6			
Type	Dry, magnetic circuit, impregnated			




FIGURE 5. Time versus voltage-total harmonic distortion factor.

coupled with the protection Miniature Circuit Breaker (MCB) and relay to electrically turn ON and turn OFF. The human machine interface (HMI) is used for the sophisticated manual operation and control of the power capacitor and detuned reactors. The input current signal is provided through the current transformer for the optimum capacitor and reactor configuration. Also, defective step identification and optimization have been embedded in the microprocessor configuration.

IV. RESULTS AND DISCUSSION OF HARMONIC ANALYSIS OF INDUSTRIAL POWER SYSTEM

The harmonic analysis of industry was carried out using the class ‘A’ three-phase energy and power quality analyzer for precise measurements. Figure.5 gives the time evolution of voltage THDF of the industry generated by fluke power log 5.2 PC application software. The present V-THDF is under the IEEE 519-2014 and IEC 61000 standards and norms. In Figure.5, the %H₁ AN, %H₁B, and %H₁ CN represent the % voltage harmonics of R-Phase, Y-Phase, and B-Phase, respectively. The third order, fifth-order, and seventh order of voltage harmonics exist in the industrial power system. The seventh order of harmonics is predominantly present in the system. The V-THDF has a relationship with the voltage




FIGURE 6. Time versus current-total harmonic distortion factor.

unbalance, increased current consumption, and performance deterioration of induction motors; therefore, care must be given for mitigation.

Figure 6 gives the current total Harmonic Distortion Factor (I-THDF) time evolution, which is analyzed and created by Fluke Power Log 5.2 PC application software. In Figure.6, the %H₁ AN, %H₁ B, and %H₁ CN represent the % current harmonics of R-Phase, Y-Phase, and B-Phase, respectively. The third order, fifth-order, and seventh order of current harmonics exist, out of which, seventh order of harmonics is significant in the system. I-THDF has a relation with the performance of electrical and electronic loads in the system. The most likely mechanical anomalies like high-temperature rise and noise, increased energy consumption, performance deterioration, and lifespan deterioration of induction motors; therefore, care must be given for mitigation. From these results of a detailed energy audit, the harmonic mitigating filter design is proposed, and its effectiveness studies after installation of the same as a post-audit phase.

V. RESULTS AND DISCUSSION OF POST-AUDIT ANALYSIS OF INDUSTRIAL POWER SYSTEM

A. EFFECT OF FILTER IN POWER SYSTEM

Figure.7 and Figure.8 illustrates the graphical representation of time versus voltage profile without-detuned reactor and with-detuned reactor configuration, respectively. The without harmonic filter configuration has prominent abnormalities in the system. The voltage profile is increased by 1.6% from the fundamental level (without filter configuration). The enhanced voltage is clear for the effectiveness of with detuned reactor configuration. Similarly, Figure.9 and Figure.10 illustrates the graphical representation of time versus current profile without-detuned reactor and with-detuned reactor configuration, respectively. The with-filter configuration current profile shows that the maximum utilization of loads is nearly balanced and with little fluctuation compared to without filter configuration.




FIGURE 7. Voltage versus time (without filter).




FIGURE 10. Current versus time (with filter).




FIGURE 8. Voltage versus time (With filter).




FIGURE 11. V-THDF versus time versus (without filter).




FIGURE 9. Current versus time (without filter).




FIGURE 12. V-THDF versus time versus (with filter).

Figure.11 and Figure.12 illustrates the graphical representation of time versus V-THDF profile without-detuned reactor and with-detuned reactor configuration, respectively. As per the IEEE 519-2014 and IEC 61000 standards, at the PCC [15], the maximum allowable V-THDF of 5%. The system configuration without a detuned reactor is recorded as 2.77 %, and the configuration with a detuned

reactor is recorded as 2.67 %. The effectiveness of with-detuned reactor configuration is clear by the reduction of V-THDF by 3.61%. The lower effectiveness of harmonic voltage suppression is mainly due to inductance value selection. The selection of inductance value is restricted to 90% of the




FIGURE 13. I-THDF versus time (without filter).




FIGURE 14. I-THDF versus time (with filter).

predominant harmonic frequency. The presence of current harmonics is predominant in the system. Therefore, harmonic voltage mitigation has a lower significance. However, the voltage harmonic level is under the limits of Central Electricity Authority guidelines at the point of common coupling.

Figure.13 and Figure.14 illustrate the graphical representation of time versus I-THDF profile without-detuned reactor and with-detuned reactor, respectively. The maximum allowable I-THDF of 8% is the IEEE 519-2014 and IEC 61000 standards at the PCC. The system configuration without a detuned reactor is recorded as 15.5 %, and the configuration with a detuned reactor is recorded as 5.2 %. The effectiveness analysis was carried out at the constant loading condition. The effectiveness of with-detuned reactor configuration is clear by the reduction of I-THDF by 66.45 %.From the overall power quality analysis of with and without-detuned reactor configuration, the passive filter’s effectiveness is highly significant. It enhances the overall system health and efficiency by suppressing voltage and current harmonics.

B. EFFECT OF FILTER ON MOTOR PERFORMANCE

The mechanical anomalies like noise, temperature, and torque ripples are highly developed due to the voltage harmonic distortion. The rise in motor temperature is directly associated

with the presence of voltage harmonics in the system. As per the National Electrical Manufacturers Association (NEMA) recommendations, 5% of the voltage-total harmonic distortion factor in the system could reduce the overall motor capacity up to 95% from its full performance percentage [16].

Due to harmonics, the high frequency in the system will lead to an increase in the overall effective resistance of the motor winding. This increased effective resistance is due to the skin effect, and it leads to an enormous amount of copper loss and motor life span reduction. The voltage unbalances in the system unbalance the motor current by almost 6 to 10 times than the rated current. Therefore, the overall performance and life span of the motor are reduced drastically in the textile industry. The proper balancing of loads [17]ensures the better performance of electric loads.

Figure. 15 Shows the Infrared thermography of the motor winding, which is taken during the industry’s operation without a passive filter in the system. The motor winding temperature is higher than the manufacturing specification due to voltage harmonic distortion in the textile industry. Figure.16 gives the motor winding infrared thermography when the passive filter is switched ON in the industrial power system.

The IEC 60034-26 (Voltage Unbalance Factor) is calculated for the industry from the detailed voltage analysis. The 100 times the ratio of maximum deviation of voltage from the average voltage of the three-phase system to the average voltage defines the percentage voltage unbalance factor. The percentage voltage unbalance factor is about 1% without filter configuration and less than 0.2% with filter configuration. Therefore, the maximum utilization of motor full load capacity (say 100%) is possible because of a reduced voltage imbalance in the system by installing the passive filter.



FIGURE 15. Infrared thermography of motor without filter configuration.

C. EFFECT OF HARMONICS IN LIGHTING SYSTEM

The existing lighting infrastructure of the industry is entirely powered by 50-55 circuitry watts of the fluorescent lamp. The precise lux measurement is carried out in the various working locations of the industry. As per BEE’s lighting recommendations, the 150-lux level should be adequate for Bale breaking, blowing, carding, roving, slubbing, spinning




FIGURE 16. Infrared thermography of motor with filter configuration.

(ordinary counts), winding, heckling, spreading, and cabling purposes. The recommended lux level of 200 is required for Warming, slashing, dressing, dyeing, doubling (fancy), and spinning (fine counts). The 700-lux level is necessary for heating, weaving, and cloth inspection in the Indian textile industry premises.

Based on the measured lux level, sufficient lighting of 350 lux is provided in the winder, wrapper, and shuttle loom sections. The periodic maintenance for dustless operation is suggested for the better lux level output from the existing lighting infrastructure. In addition, the 350 lux is not adequate for the weaving section. Therefore, the retrofitting of fluorescent lamps with the energy-efficient LED lighting system for the recommended lux level with better power quality (voltage and current harmonics).

The non-linear load-LED has a significant power quality impact on the power system. The recent LED driver circuit development is incorporated with the passive filtering circuit for harmonic mitigation. Therefore, the retrofitting of fluorescent lamps with energy-efficient LED lighting significantly reduces harmonics [18] in the system. The IEEE 519-2014 and IEC 61000-3-2 Electromagnetic compatibility (EMC) limit the system's current harmonics by less than 16A per phase. The recent LED drivers are equipped to provide sophisticated power factor improvement with the harmonic mitigation of I-THDF up to 43% [19].

D. TECHNO-ECONOMIC ANALYSIS ON TEXTILE INDUSTRY ENERGY CONSERVATION

The power factor and harmonics are the crucial parameters in the power system [20]. The power factor improvement techniques and harmonic mitigation have a significant scope on economic benefits, respectively. As per the Central Electricity Authority (CEA) and Tamil Nadu Electricity Regulatory Commission (TNERC) guidelines [21], the voltage total harmonic distortion factor greater than 5% is not permissible. Also, the current harmonics greater than 8% is not recommended for the HT-Tariff- III consumers. The harmonics dumping level greater than the allowable limit will be penalized by 15% of their current consumption charges of the monthly energy bill. The dispensation of power factor

compensation below 0.75 is penalized by 2 percent of the current consumption charges of the monthly energy bill. The one unit (kWh) of electricity under the HT-Tariff- II costs about 8 rupees and a demand charge of 350 per kVA/month. The payback period is the ratio of capital investment cost to the annual cost saving [22] and is shown in (7).

$$\text{simple_payback} = \frac{\text{Capital Cost}}{\text{Annual Savings}} \quad (7)$$

The detailed energy audit of the textile industry under investigation shows that the voltage and current total harmonic distortion are recorded as 2.27 % and 15.77 %, respectively. The percentage harmonics recorded are more significant than the TNERC guidelines. In addition, the average recorded lagging power factor of 0.9 is recorded at the point of common coupling. The lagging power factor of 0.9 is considered being a poor power factor as per the guidelines of TNERC.

According to the Central Electricity Authority (CEA) and Tamil Nadu Electricity Regulatory Commission (TNERC) guidelines, the penalty levitated towards the energy utilization of the textile industry is summarized. The monthly energy consumption of 10,000 kWh is recorded in the history of energy consumption. Based on the current consumption charges of HT-tariff-III, the sum of rupees 25,000 per month penalty will be levitated towards the poor power quality, and the sum of rupees 3,350 fine is levitated towards the lagging power factor. Therefore, rupees 28,350 is levitated towards the poor power quality to the textile industry under investigation.

At the point of common coupling, the voltage total harmonic distortion factor, current total harmonic distortion factor, and power factor of the textile industry are enhanced by installing the harmonic filter. The overall power quality of the textile industry is improved to eliminate the penalty levitated by CEA and TNERC on the HT-tariff III guidelines. The overall capital investment includes the materials cost, labor cost, interest, tax and depreciation cost of 10% towards the design and installation of harmonic filter is calculated and reported. The following components like detuned reactors, heavy-duty power capacitors, multi-function harmonic indicator, control relay, contactors, moulded case circuit breakers, and miniature circuit breakers, high temperature withstanding wires and cable incomer, enclosure with a protection class of IP42 were included in the investment cost of the harmonic filter. The installation and commissioning of a harmonic filter are calculated as rupees 2300 rupees per kVAR. Therefore, from the specifications mentioned above, the investment cost for a harmonic filter is about 1, 70,000.00 Rupees. The installation of a harmonic filter achieves an annual saving of 3, 40,200.00 rupees. The simple payback period of 0.5 years or six months is highly economical and technically workable for significantly enhancing overall power quality.

The voltage and current harmonic distortions are prone to generate the additional system losses. The additional system losses include copper and eddy current loss in the

distribution transformer. Also, current harmonics increases the system joule losses in the conductor and asynchronous machines. The current (I_{rms}) is greater than the fundamental current in the harmonic prone environment. These additional energy losses have been mitigated through the installation of a passive filter. Figure.17 gives the correlation between the percentage total harmonic distortions versus joule losses and current (I_{rms}). Based on the installation of a passive filter, the energy conservation is achieved through continuous power quality improvement.




FIGURE 17. Harmonic distortion versus additional system losses [23].

In addition, the industry is powered by 160 numbers of fluorescent lamps with a low lux level from the detailed lighting analysis. Therefore, good quality 20-watt energy-efficient LED installation could save 51.2 kWh of power-saving per day of 20 operating hours. As per the Central Electricity Authority (CEA) of India [24], 1.04 kg-CO₂/kWh is the assumption for India's CO₂ emission calculations. The annual energy saving of 18,432 kWh has direct scope for annual carbon emission reduction of 19,170 kg (or) 19.17 tons from the industry. The detailed energy and economic analysis for energy conservation measures help in cost estimation and payback calculation [25] for LED retrofitting of the textile industry. The cost economics for the retrofitting of LED gives the payback period of fewer than 1.2 Years. Therefore, LED retrofitting is highly economical and eco-friendly.

VI. CONCLUSION

The detailed energy auditing of the textile industry is carried out by adopting the systematic energy auditing methodology. The scope for the energy conservation through power quality improvement is presented in the work successfully. From the textile industry's detailed energy auditing, the Voltage Total Harmonic Distortion Factor (V-THDF) and Current Total Harmonic Distortion Factor (I-THDF) are within the standard limits of IEEE 519-2014 and IEC 60034-26. The installed passive filter achieves the V-THDF reduction of 3.61% and I-THDF reduction of 66.45%. Therefore, the effectiveness of the designed harmonic filter in the harmonic mitigation activity is highly significant.

In the harmonic prone environment, the harmonic filter achieves the 80% reduction of voltage unbalances. This reduction in voltage unbalances aids in the reduction of motor temperature, noise, and torque ripples. The result of infrared thermography ensures the significant enhancement of three-phase induction motor performance by a 33.82 % reduction in motor temperature. The energy conservation is ensured by reducing joule, copper and eddy current losses (additional losses). In the installation of a harmonic filter, the overall cost saving of 3, 40,200 rupees is achieved with significantly lower payback period of 6 months. The installation of a harmonic filter is highly economical and workable.

In lighting, the retrofitting of fluorescent lamps with the energy-efficient Light Emitting Diode (LED) lamp is ensuring the significant annual energy saving of 18,432 kWh with a payback period of less than 1.2 years. In addition, sustainability is ensured by 19.17 tons of annual carbon emission reduction. In addition, the installation of solar photovoltaic (renewable energy resources) has significant scope for sustainability.

REFERENCES

- [1] Development Reports. (2021). *Bureau of Energy Efficiency*. Accessed: Jul. 23, 2021. [Online]. Available: <https://beeindia.gov.in/content/publications-0>
- [2] G.-B. Hong, T.-L. Su, J.-D. Lee, T.-C. Hsu, and H.-W. Chen, "Energy conservation potential in Taiwanese textile industry," *Energy Policy*, vol. 38, no. 11, pp. 7048–7053, Nov. 2010, doi: [10.1016/j.enpol.2010.07.024](https://doi.org/10.1016/j.enpol.2010.07.024).
- [3] G. C. de Oliveira Neto, J. M. F. Correia, P. C. Silva, A. G. de Oliveira Sanches, and W. C. Lucato, "Cleaner production in the textile industry and its relationship to sustainable development goals," *J. Cleaner Prod.*, vol. 228, pp. 1514–1525, Aug. 2019, doi: [10.1016/j.jclepro.2019.04.334](https://doi.org/10.1016/j.jclepro.2019.04.334).
- [4] M. S. Bhaskar, P. Verma, A. Kumar, and N. Delhi, "Indian textile industries towards energy efficiency movement," *Int. J. Environ. Sci., Develop. Monitor.*, vol. 4, no. 2231, pp. 36–39, 2013.
- [5] G. N. L. P. Raj and V. Kirubakaran, "Energy efficiency enhancement and climate change mitigations of SMEs through grid-interactive solar photovoltaic system," *Int. J. Photoenergy*, vol. 2021, Jan. 2021, Art. no. 6651717, doi: [10.1155/2021/6651717](https://doi.org/10.1155/2021/6651717).
- [6] A. Zeaiter, E. Videcoq, and M. Fénot, "Determination of electric motor losses and critical temperatures through an inverse approach," *Electr. Eng.*, vol. 103, no. 1, pp. 621–631, Feb. 2021, doi: [10.1007/s00202-020-01098-0](https://doi.org/10.1007/s00202-020-01098-0).
- [7] D. Thomas, G. D'Hoop, O. Deblecker, K. N. Genikomsakis, and C. S. Ioakimidis, "An integrated tool for optimal energy scheduling and power quality improvement of a microgrid under multiple demand response schemes," *Appl. Energy*, vol. 260, Feb. 2020, Art. no. 114314, doi: [10.1016/j.apenergy.2019.114314](https://doi.org/10.1016/j.apenergy.2019.114314).
- [8] R. Abdollahi, "Power quality enhancement of a T-connected autotransformer based on 72-pulse AC-DC converter with rated power reduction," *Electr. Eng.*, vol. 102, no. 3, pp. 1253–1264, Sep. 2020, doi: [10.1007/s00202-020-00948-1](https://doi.org/10.1007/s00202-020-00948-1).
- [9] A. Eren and A. M. Vural, "Arm cortex M4 microprocessors based ± 100 kVAR energy quality regulator for reactive power/neutral current compensation, load balancing and harmonic mitigation," *Eng. Sci. Technol., Int. J.*, early access, Jun. 2021, doi: [10.1016/j.jestech.2021.05.022](https://doi.org/10.1016/j.jestech.2021.05.022).
- [10] L. P. R. Nadimuthu and K. Victor, "Optimization of energy-intensive process in ayurvedic medicine manufacturing unit—A case study," *Process Integr. Optim. Sustainability*, vol. 5, no. 4, pp. 975–992, Dec. 2021, doi: [10.1007/s41660-021-00194-3](https://doi.org/10.1007/s41660-021-00194-3).
- [11] A. Ali, Arshad, H. Akhtar, M. U. R. Siddiqi, and M. Kamran, "An efficient and novel technique for electronic load controller to compensate the current and voltage harmonics," *Eng. Sci. Technol., Int. J.*, vol. 23, no. 5, pp. 1042–1057, Oct. 2020, doi: [10.1016/j.jestech.2019.11.009](https://doi.org/10.1016/j.jestech.2019.11.009).

- [12] L. P. R. Nadimuthu and K. Victor, "Performance analysis and optimization of solar-powered E-rickshaw for environmental sustainability in rural transportation," *Environ. Sci. Pollut. Res.*, vol. 28, no. 26, pp. 34278–34289, Jul. 2021, doi: [10.1007/s11356-021-12894-x](https://doi.org/10.1007/s11356-021-12894-x).
- [13] P. R. G. N. Lalith, G. Prabhakaran, A. Murugaiyan, and V. Kirubakaran, "Hybrid photovoltaic-thermal systems: Innovative CHP approach," in *Proc. 4th Int. Conf. Electr. Energy Syst. (ICEES)*, Feb. 2018, pp. 726–730, doi: [10.1109/ICEES.2018.8442352](https://doi.org/10.1109/ICEES.2018.8442352).
- [14] C. Sreenath, S. Prabhakaran, V. Rajakumaran, C. Shankar, S. S. S. Velan, and V. Kirubakaran, "Energy auditing of payment tiles making small scale industry: Suggestions and recommendations for energy conservation," in *Proc. Int. Conf. Circuits, Power Comput. Technol.*, Mar. 2015, pp. 1–4, doi: [10.1109/ICCPCT.2015.7159445](https://doi.org/10.1109/ICCPCT.2015.7159445).
- [15] US Department of Energy Advanced Manufacturing Office. (2005). *Eliminate Voltage Unbalance*. [Online]. Available: http://energy.gov/sites/prod/files/2014/04/f15/eliminate_voltage_unbalanced_motor_systems7.pdf
- [16] K. Kamaleswaran, M. Venkateshwaran, P. Harinath, M. A. Mydeen, and V. Kirubakaran, "Energy conservation potential in rural industry: A case study on coir industry," in *Proc. Int. Conf. Circuits, Power Comput. Technol.*, Mar. 2015, pp. 1–5, doi: [10.1109/ICCPCT.2015.7159444](https://doi.org/10.1109/ICCPCT.2015.7159444).
- [17] N. Phannil, C. Jettanasen, and A. Ngaopitakkul, "Harmonics and reduction of energy consumption in lighting systems by using LED lamps," *Energies*, vol. 11, no. 11, p. 3169, Nov. 2018, doi: [10.3390/en11113169](https://doi.org/10.3390/en11113169).
- [18] S. E. R. Bolduc, *Impacts of LED Lighting on Power Quality—EE Publishers*. Hatfield, U.K.: EE, 2018. [Online]. Available: <https://www.ee.co.za/article/impacts-of-led-lighting-on-power-quality.html>
- [19] S. S. S. Velan and V. Kirubakaran, "Implementation of energy conservation and management activities and its economics in GRI boy's hostel—A case study," in *Proc. Biennial Int. Conf. Power Energy Syst., Towards Sustain. Energy (PESTSE)*, Jan. 2016, pp. 1–10, doi: [10.1109/PESTSE.2016.7516491](https://doi.org/10.1109/PESTSE.2016.7516491).
- [20] R. P. B. da Silva, R. Quadros, H. R. Shaker, and L. C. P. da Silva, "Effects of mixed electronic loads on the electrical energy systems considering different loading conditions with focus on power quality and billing issues," *Appl. Energy*, vol. 277, Nov. 2020, Art. no. 115558, doi: [10.1016/j.apenergy.2020.115558](https://doi.org/10.1016/j.apenergy.2020.115558).
- [21] *Tamil Nadu Electricity Regulatory Determination of Tariff for Generation and Distribution*, TNERC, Chennai, India, 2017.
- [22] D. A. Selvaraj and K. Victor, "Design and performance of solar PV integrated domestic vapor absorption refrigeration system," *Int. J. Photoenergy*, vol. 2021, Feb. 2021, Art. no. 6655113, doi: [10.1155/2021/6655113](https://doi.org/10.1155/2021/6655113).
- [23] Electrical Installation Guide Contributors. (2019). *Effects of Harmonics—Increased Losses*. Accessed: Aug. 21, 2021. [Online]. Available: http://www.electrical-installation.org/enw/index.php?title=Effects_of_harmonics_-_Increased_losses&oldid=26856
- [24] Central Electricity Authority of India. (2018). *CO₂ Baseline Database for the Indian Power Sector*. Accessed: May 20, 2020. [Online]. Available: https://cea.nic.in/wp-content/uploads/baseline/2020/07/user_guide_ver14.pdf
- [25] S. Yoomak and A. Ngaopitakkul, "The study of harmonic reduction in light emitting diode (LED) roadway lighting system," in *Proc. 17th Int. Sci. Conf. Electr. Power Eng. (EPE)*, May 2016, pp. 1–5, doi: [10.1109/EPE.2016.7521726](https://doi.org/10.1109/EPE.2016.7521726).



KIRUBAKARAN VICTOR received the B.E. degree in mechanical engineering from the Government College of Engineering, Salem, and the M.Tech. and Ph.D. degrees from the National Institute of Technology, Trichy. He is currently working as an Associate Professor at the Centre for Rural Energy, The Gandhigram Rural Institute (Deemed to be University), Ministry of Education, and the Government of India. He is also a Program Officer of NSS unit of The Gandhigram Rural Institute (Deemed to be University). He has received financial help from the Department of Science and Technology for his research project titled "Studies on Gasification of Poultry litter" under Young Scientist Scheme. Prior to his present assignment, he has worked as a Research Associate at the Centre for Energy and Environmental Science and Technology (CEESAT), National Institute of Technology, where he developed various laboratories with the state of art equipment received under U.K. India RECs project. Apart from regular teaching, he has completed two major research projects, one minor research projects and several consultancy project to the total tune of Rs. 50.00 lakhs. His research interests include biomass gasification, thermal analysis, and energy engineering. He has also actively involved several extension programs. He has carried various village energy conservation awareness programs, organized six mega rallies on energy conservation.



CHAKARAJAMULA HUSSAIAN BASHA received the bachelor's degree in electrical and electronics engineering from Jawaharlal Nehru Technological University, Anantapuramu, India, in 2013, and the master's degree in power electronics and drives from VIT University, India, in 2016. He is currently working as an Assistant Professor with the Department of EEE, K. S. R. M. College of Engineering (Autonomous), Kadapa, Andhra Pradesh, India. He has published various SCIE and SCOPUS indexed journals. His research interests include PV cell modeling, fuel cell modeling, soft computing, artificial intelligence, power point tracking techniques, liquid dielectrics, spectroscopy analysis, and design of high step-up DC-DC converters for electric vehicle application.



LALITH PANKAJ RAJ NADIMUTHU received the bachelor's degree in electrical and electronics engineering from the PSNA College of Engineering and Technology and the Master of Technology degree from the Centre for Rural Energy, The Gandhigram Rural Institute (Deemed to be University). He is currently working as a Research Scholar at the Centre for Rural Energy, The Gandhigram Rural Institute (Deemed to be University), Ministry of Education, and the Government of India. He has received DST INSPIRE Fellowship from the Department of Science and Technology (DST), Ministry of Science and Technology, Government of India, for his research project. His area of aspiration is to provide climate change mitigation through renewable energy solutions. His research interests include renewable energy engineering, solar photovoltaic, electrical vehicle-vehicle to grid, smart grid, and energy auditing.



T. MARIPRASATH received the Ph.D. degree from the Rural Energy Centre, The Gandhigram Rural Institute (Deemed to be University), in January 2017, fully funded by the Ministry of Human Resource Development—Government of India. He has been working as an Associate Professor with the Department of EEE, K. S. R. M. College of Engineering (Autonomous), Kadapa, since June 2018. He has published six Science Citation Indexed journals. Moreover, he has published a book in Cambridge Scholars Publishing, U.K. Also, he had a patent. His research interests include renewable energy engineering, renewable energy resources, DC microgrid, green dielectrics, and artificial intelligence. He acted as a reviewer in IEEE, IET, Taylor Francis, and World Scientific Publishing Academy.



C. DHANAMJAYULU (Senior Member, IEEE) received the B.Tech. degree in electronics and communication engineering from JNTU University, Hyderabad, India, the M.Tech. degree in control and instrumentation systems from the Indian Institute of Technology Madras, Chennai, India, and the Ph.D. degree in power electronics from the Vellore Institute of Technology, Vellore, India. He was invited as a Visiting Researcher with the Department of Energy Technology, Aalborg University, Esbjerg, Denmark, funded by the Danida Mobility Grant, Ministry of Foreign Affairs of Denmark on Denmark's International Development Cooperation. Since 2010, he has been a Senior Assistant Professor with the Vellore Institute of Technology. He was a Postdoctoral Fellow with the Department of Energy Technology, Aalborg University, from October 2019 to January 2021. He is currently a Faculty Member and a member of the Control and Automation Department, School of Electrical Engineering, Vellore Institute of Technology. He is also a Senior Assistant Professor with the School of Electrical Engineering, Vellore Institute of Technology. His research interests include multilevel inverters, power converters, active power filters, power quality, grid-connected systems, smart grid, electric vehicle, electric spring, and tuning of memory elements and controller parameters using soft-switching techniques for power converters, average modeling, steady-state modeling, and small-signal modeling stability analysis of the converters and inverters.



SANJEEVIKUMAR PADMANABAN (Senior Member, IEEE) received the Ph.D. degree in electrical engineering from the University of Bologna, Bologna, Italy, in 2012. He was an Associate Professor at VIT University, from 2012 to 2013. In 2013, he joined the National Institute of Technology, India, as a Faculty Member. In 2014, he was invited as a Visiting Researcher at the Department of Electrical Engineering, Qatar University, Doha, Qatar, funded by the Qatar National Research Foundation (Government of Qatar). He continued his research activities with the Dublin Institute of Technology, Dublin, Ireland, in 2014. Further, he served as an Associate Professor for the Department of Electrical and Electronics Engineering, University of Johannesburg, Johannesburg, South Africa, from 2016 to 2018. Since 2018, he has been a Faculty Member with the Department of Energy Technology,

Aalborg University, Esbjerg, Denmark. He has authored over 300 scientific papers. He is a fellow of the Institution of Engineers, India; the Institution of Electronics and Telecommunication Engineers, India; and the Institution of Engineering and Technology, U.K. He was a recipient of the Best Paper cum Most Excellence Research Paper Award from IET-SEISCON'13, IET-CEAT'16, IEEE-EECSI'19, and IEEE-CENCON'19; and five best paper awards from ETAEERE'16 sponsored Lecture Notes in electrical engineering, Springer book. He is an Editor/an Associate Editor/an Editorial Board Member for refereed journals, in particular the IEEE SYSTEMS JOURNAL, IEEE TRANSACTIONS ON INDUSTRY APPLICATIONS, IEEE ACCESS, *IET Power Electronics*, *IET Electronics Letters*, and *International Transactions on Electrical Energy Systems* (Wiley); a Subject Editorial Board Member of *Energy Sources, Energies* journal (MDPI); and a Subject Editor of *IET Renewable Power Generation*, *IET Generation, Transmission and Distribution*, and *FACTS* journal (Canada).



BASEEM KHAN (Senior Member, IEEE) received the B.Eng. degree in electrical engineering from Rajiv Gandhi Technological University, Bhopal, India, in 2008, and the M.Tech. and D.Phil. degrees in electrical engineering from the Maulana Azad National Institute of Technology, Bhopal, in 2010 and 2014, respectively. He is currently working as a Faculty Member at Hawassa University, Ethiopia. His research interests include power system restructuring, power system planning, smart grid technologies, meta-heuristic optimization techniques, reliability analysis of renewable energy systems, power quality analysis, and renewable energy integration.

...