

On the Analysis and Synthesis of Wind Turbine Side–Side Tower Load Control via Demodulation

Atindriyo K. Pamososuryo^{1b}, Sebastiaan P. Mulders^{1b}, *Member, IEEE*, Riccardo Ferrari^{1b}, *Senior Member, IEEE*, and Jan-Willem van Wingerden^{1b}, *Senior Member, IEEE*

Abstract—As wind turbine power capacities continue to rise, taller and more flexible tower designs are needed for support. These designs often have the tower’s natural frequency in the turbine’s operating regime, increasing the risk of resonance excitation and fatigue damage. Advanced load-reducing control methods are needed to enable flexible tower designs that consider the complex dynamics of flexible turbine towers during partial-load operation. This article proposes a novel modulation–demodulation control (MDC) strategy for side–side tower load reduction driven by the varying speed of the turbine. The MDC method demodulates the periodic content at the once-per-revolution (1P) frequency in the tower motion measurements into two orthogonal channels. The proposed scheme extends the conventional tower controller by augmentation of the MDC contribution to the generator torque signal. A linear analysis framework into the multivariable system in the demodulated domain reveals varying degrees of coupling at different rotational speeds and a gain sign flip. As a solution, a decoupling strategy has been developed, which simplifies the controller design process and allows for a straightforward (but highly effective) diagonal linear time-invariant (LTI) controller design. The high-fidelity OpenFAST wind turbine software evaluates the proposed controller scheme, demonstrating effective reduction of the 1P periodic loading and the tower’s natural frequency excitation in the side–side tower motion.

Index Terms—Modulation–demodulation control (MDC), periodic load cancellation, side–side tower load control, wind turbine fatigue reduction.

I. INTRODUCTION

THE improvements in the cost-effectiveness of wind turbines can be traced back to the adoption of the upscaling strategy, in which the sizes of the turbine components are made larger [1]. Turbine rotors are made larger and can capture more energy by the increased swept area and towers are built taller to support such larger rotors. Moreover, at higher altitudes, the wind energy resource is of higher quality as the influence of surface friction is less prominent, resulting in more power production by a single machine.

Conventional tower upscaling, however, is not desirable as merely increasing tower heights and diameters while keeping the same wall thickness results in much heavier and more expensive structures. In addition, transportability constraints,

e.g., on tower base diameter, limit the size of which the towers can be designed, especially for onshore installations [2]. While satisfying the transportability requirements, reducing the tower wall thickness is a compelling solution to lower the needed amount of mass and thus manufacturing costs of tall towers. In contrast to conventional *soft–stiff* tower designs, resulting *soft–soft* designs lower the tower’s (first) natural frequency into the turbine operational range. Consequently, the risk of resonance by excitation of the time-varying rotor speed, also known as the once-per-revolution (1P) frequency, is thus becoming ever greater. Rotor imbalance could even further exacerbate this effect [3], [4]. Tower resonance excitation is even more concerning for the side–side tower oscillations than for the fore–aft due to the negligible contribution of the aerodynamic damping in the formerly mentioned direction [5]. So, reliable and advanced control solutions capable of fatigue load mitigation are of utmost importance to improve the viability of soft–soft tower designs.

Different control implementations have been made available in the literature for tower periodic load control and are generally classified as passive and active methods. Passive methods prevent prolonged turbine operation near the tower resonance frequency, usually by decreasing or increasing generator torque demand to accelerate or decelerate the rotor, depending on whether its speed is above or below the resonance frequency. This method is often referred to as frequency skipping by speed exclusion zones. Bossanyi [6] introduced the approach for avoiding tower resonance by blade passing frequency at three-times-per-revolution (3P) for three-bladed wind turbines. Licari et al. [7] studied the effects of the speed exclusion zone’s width tuning for 1P excitation in terms of load reduction and power quality. Smilden and Sørensen [8] later adopted this algorithm for preventing resonance of fore–aft tower motion by the 3P thrust oscillations. However, such conventional implementations are nontrivial due to the intricate logic that needs to be incorporated, resulting in not knowing whether the control solution is dynamically optimal. Therefore, a state-of-the-art quasi-linear parameter varying model predictive control (qLPV-MPC) method was developed to tackle the shortcomings and challenges of conventional methods [9].

Active control methods, on the other hand, feed tower measurements into a controller to generate counteracting forces through provided actuators so as to dampen the tower vibration [6], [10]. The controller, typically an integrator when acceleration is measured and is designed to increase tower damping. Depending on whether the fore–aft [6], [10], [11]

Manuscript received 4 September 2023; revised 21 December 2023; accepted 7 March 2024. Date of publication 29 March 2024; date of current version 20 August 2024. Recommended by Associate Editor L. Imsland. (Corresponding author: Atindriyo K. Pamososuryo.)

The authors are with Delft Center for Systems and Control, Delft University of Technology, 2628 CD Delft, The Netherlands (e-mail: A.K.Pamososuryo@tudelft.nl; S.P.Mulders@tudelft.nl; R.Ferrari@tudelft.nl; J.W.vanWingerden@tudelft.nl).

Digital Object Identifier 10.1109/TCST.2024.3377508

or side–side direction [10], [12] is targeted for damping, respectively, the collective pitch or generator torque demand is utilized as the control input. Such a conventional approach was originally devised to reduce tower vibration at its natural frequency. Nonetheless, a tower load controller specifically aiming at the time-varying 1P periodic loading has received little to no attention in the literature and would be an attractive complement to the conventional method.

This article extends the conventional control method by a modulation–demodulation setup to further improve side–side tower load reduction performance. Such a controller design additionally provides a reduction of the rotational-speed-driven load and allows for comprehensive system analysis and controller synthesis. To the best of the authors’ knowledge, such an approach has not yet received any attention in the wind turbine control literature.

In the control engineering field, an approach known as the modulation-demodulation control (MDC) is considered an effective solution to periodic disturbance cancellation problems [13], [14], [15]. MDC is able to adapt its control input’s frequency to reject a time-varying disturbance frequency and can handle the changes in the dynamics of the plant due to the variation of the disturbance frequency. A large body of literature has been dedicated to further studying MDC’s potential, which includes applications in diverse fields. For instance, Byl et al. [14] focuses on MDC tuning from the perspective of the frequency-domain loop-shaping method for the application of a diamond turning machine. The work of [16] analyses the feedback limitations of MDC by poles, zeros, and delays investigation. In [15], vibration control of flexible piezoelectric structures by MDC was conducted. Other applications include digital data storage system [17], helicopter [18], flexible web winding system [19], and tape system [20], just to mention a few.

The MDC control method bears similarities with a highly-anticipated and industrially applied periodic blade load alleviation technique known as individual pitch control (IPC) [21]. For most IPC implementations, the Coleman transformation [22] is employed to project measured individual blade moments containing periodic content from the rotating frame into a static nonrotating frame. The scheme can be thought of as a modulation–demodulation framework where structural analysis and controller design are simplified in the nonrotating domain. However, it has been known that larger and more flexible rotor structures create severe coupling of the considered multivariable system. Therefore, for single-input single-output (SISO) controller designs to be justified in the transformed domain, decoupling strategies must be taken into account [23], [24]. In MDC, identical and rather simple diagonal SISO controllers can also be designed onto low-frequency, orthogonal *quadrature* and *in-phase* channels resulting from the *demodulation* of the plant’s measurements. This operation is similar to the forward Coleman transformation in the conventional IPC. The computed control actions on these orthogonal channels are then converted into the actual usable input at the disturbance frequency by the *modulation* operation, similar to the reverse Coleman transformation. Nevertheless, despite its demonstrated effectiveness in wide

applications, little attention has been paid to adapting MDC for mitigating periodic loading affecting wind turbine side–side tower motion.

This article focuses on the development of MDC for the rejection of 1P periodic loading on wind turbine side–side tower motion. The proposed MDC results in a periodic generator torque control input with time-varying 1P frequency, which, given the measurements of the rotor speed, is able to track the disturbance’s frequency. However, frequency-domain analysis of the demodulated system shows that the quadrature and in-phase channels are not fully decoupled. Moreover, changing rotational speed induces a gain sign flip, which may cause instability in the closed-loop operation. Therefore, a decoupling strategy by phase offset inclusion, similar to that in the conventional IPC [24], is developed to arrive at fully decoupled quadrature and in-phase channels and simultaneously remove the gain sign flip.

The contribution of this work is fourfold:

- 1) formulating MDC for the mitigation of periodic load affecting wind turbine side–side tower motion induced by the time-varying 1P rotor excitation;
- 2) providing frequency domain frameworks for the analysis of the system coupling and controller behavior in their (de)modulated representations;
- 3) decoupling the multivariable system and correcting the gain sign flip by the inclusion of a phase offset, as well as illustrating the offset’s influence on the controller;
- 4) showcasing the performance of MDC in both simplified and high-fidelity computer-aided wind turbine simulation environments along with a conventional active tower damper.

The remainder of this article is structured as follows. Section II describes the nominal wind turbine dynamics and conventional tower damping controller. In Section III, the derivation of the proposed MDC framework in the frequency domain is presented. Section IV elaborates on controller and system analysis in the MDC framework, in which the cross-coupling phenomenon and gain sign flip in the quadrature and in-phase MDC channels are discussed. Then, in Section V, the phase offset inclusion for the channel decoupling and gain sign flip correction on the tower dynamics, as well as influence on the controller, is explained. In Section VI, the effectiveness of the proposed controller is demonstrated using low- and high-fidelity simulations. Concluding remarks are drawn in Section VII.

II. WIND TURBINE DYNAMICS AND CONVENTIONAL TOWER DAMPING CONTROLLER

To form the basis for controller design and analysis in this article, wind turbine aerodynamic and tower models are derived in Section II-A. As the goal of this article is to augment the proposed controller to that of the conventional active tower damping controller, the latter’s design is discussed in Section II-B and is combined with the tower dynamics. Section II-C derives the frequency domain representation of the combined tower dynamics for later uses in the MDC framework.

A. Tower and Aerodynamic Models

The model used for analysis and synthesis considered in this study consists of side-side tower dynamics and rotor aerodynamics. The tower dynamics are approximated as a second-order system, representing the first structural mode as follows:

$$\ddot{x}(t) = \frac{1}{m} \left(-d\dot{x}(t) - kx(t) + F_{sd}(t) + s_f(T_g(t) + \Delta T_{g,damp}(t) + \Delta T_g(t)) \right) \quad (1)$$

where m denotes the tower modal mass, d its damping, and k the modal stiffness. The notation t indicates a time-domain signal, which, for the sake of brevity, is omitted in the text unless necessary. Tower-top acceleration, velocity, and displacement are represented by \ddot{x} , \dot{x} , and x , respectively. The motion of the tower is affected by generator torque activities T_g , $\Delta T_{g,damp}$, and ΔT_g through the generator stator reaction, all of which are the considered control actions in this article. The torque T_g is used mainly in power production, whereas the additive torques $\Delta T_{g,damp}$ and ΔT_g are utilized to, respectively, increase the effective tower damping and mitigate the periodic loading F_{sd} . The factor $s_f = 1.5/H$, with H being the tower height, is the ratio between the rotational and translational displacements of the tower motion under the assumption that the tower is a prismatic beam [25].

The periodic loading aforementioned may develop on the rotor due to, e.g., a mass or aerodynamic imbalance and transferred to the fixed structure, which is modeled as the following sinusoidal force [26]:

$$F_{sd}(t) = a_{sd} \cos(\omega_r(t)t + \phi_{sd}) \quad (2)$$

where its amplitude and phase offset are denoted as a_{sd} and ϕ_{sd} , respectively, in which the former can be considered a centrifugal force [7]. Fig. 1 illustrates how this force affects the tower.

Remark 1: Although the main focus of this work is on the side-side tower loading, the proposed method explained later in Section III can also be applied to fore-aft tower loading. This is done by replacing (1) with that of the fore-aft tower dynamics, where thrust force is acting on the tower top, manipulable by collective blade pitching.

The frequency of F_{sd} varies in time as the rotor speed ω_r changes according to the following rotor aerodynamics, resembling a first-order rotational mass system:

$$\dot{\omega}_r(t) = \frac{1}{J_r} T_a(t) - \frac{G}{J_r} (T_g(t) + \Delta T_{g,damp}(t) + \Delta T_g(t)). \quad (3)$$

In the above equation, J_r represents the equivalent inertia at the low-speed-shaft (LSS) side and G is the gearbox ratio. The aerodynamic torque is given by

$$T_a(t) = \frac{1}{2\omega_r(t)} \rho_a \pi R^2 C_p(\omega_r(t), v(t), \beta(t)) v(t)^3$$

with the air density denoted by ρ_a , rotor radius R , and aerodynamic power coefficient C_p , being a function of ω_r , wind speed v and pitch angle β . To achieve maximum power




Fig. 1. Wind turbine is excited at the side-side direction by a periodic load due to the rotor imbalance at the 1P frequency $F_{sd}(t) = a_{sd} \cos(\psi(t) + \phi_{sd})$, with the azimuth $\psi(t) = \omega_r(t)t$. The tangential speed of the periodic load is indicated by $v_t(t)$, and $x(t)$ denotes tower top displacement in the horizontal direction.

extraction at the below-rated operating regime, as considered in this work, the so-called $K\omega_r^2$ control law [27] is employed for the torque controller

$$T_g(t) = \frac{1}{2\lambda^{*3}} \underbrace{\rho_a \pi R^5 C_p^*}_{K} \omega_r(t)^2 \quad (4)$$

where K is the optimal gain, λ^* as the design tip-speed ratio corresponding to the optimal power coefficient C_p^* at fine pitch position. This work employs only a simple maximum power tracking controller, as load mitigation is the main focus. However, a more advanced method is available in the literature for the interested reader (e.g., [28]).

B. Conventional Active Tower Damping Controller

With the wind turbine model at hand, a side-side tower damping controller is added to obtain the nominal system considered in the remainder of this article. The wind turbine tower dynamics (1) commonly possess only negligible damping d such that additional damping is required to mitigate fatigue loads at the tower's natural frequency. Conventionally, for the side-side direction, the extra damping is created by additional generator torque demand, being negatively proportional to the tower-top velocity (also taking into account s_f) as follows [10]:

$$\Delta T_{g,damp}(t) = -K_{conv} \dot{x}(t) \quad (5)$$

with

$$K_{conv} = \frac{d_{add}}{s_f} \quad (6)$$

as a constant gain where d_{add} is the additional, desired modal damping. Note that since \ddot{x} is often measurable, it is necessary to perform integration of this signal to obtain \dot{x} ; thus, this controller is essentially an integral controller.

The increase in the effective modal damping coefficient is now evident by substituting $\Delta T_{g,\text{damp}}$ in (1) with (5), such that the tower dynamics are rendered into

$$\ddot{x}(t) = \frac{1}{m} \left(-d_{\text{eff}}\dot{x}(t) - kx(t) + F_{\text{sd}}(t) + s_f(T_g(t) + \Delta T_g(t)) \right) \quad (7)$$

with $d_{\text{eff}} = d + d_{\text{add}}$ being the effective damping. However, the conventional tower damper does not focus on the mitigation of 1P periodic loading posed by F_{sd} . Later on in this article, the development of MDC for alleviating this rotor-speed-driven load is discussed further as an extension to this conventional controller, making use of (7).

C. Frequency Domain Representation

For a significant part of Sections III–VI, MDC design and analysis are done in the frequency domain. This requires the dynamics (7) to be expressed in this domain as well, where the transfer from ΔT_g to \dot{x} is considered. The Laplace transformation of the tower dynamics gives the following transfer function:

$$G(s) = \frac{\dot{X}(s)}{\Delta T_g(s)} = \frac{s_f s}{ms^2 + d_{\text{eff}}s + k} \quad (8)$$

where s is the Laplace operator. The notations $\dot{X}(s)$ and $\Delta T_g(s)$ are the tower-top velocity and additive generator torque in their frequency domain representation. Also useful is to define $N(s)$ and $D(s)$ to denote the numerator and denominator of $G(s)$.

III. MODULATION-DEMULATION CONTROL SCHEME

This section provides an elaboration on the MDC architecture, which is based on the approach proposed by Lau et al. [15]. The MDC architecture and accompanying analysis methods are utilized to provide a control-oriented analysis of the controller and wind turbine system. As a prerequisite for subsequent derivations, the following Laplace transforms of signal modulations at the disturbance frequency ω_r are defined:

$$\mathcal{L}\{r(t) \cos(\omega_r t)\} = \frac{1}{2}(R(s_-) + R(s_+)) \quad (9a)$$

$$\mathcal{L}\{r(t) \sin(\omega_r t)\} = -\frac{j}{2}(R(s_-) - R(s_+)) \quad (9b)$$

with $r(t)$ as an arbitrary time-domain signal and $R(s)$ its Laplace-transformed analog. For this linear analysis, ω_r is assumed to be constant over a single period. The notation $s_{\pm} = s \pm j\omega_r$ is introduced to indicate ω_r -shifted frequency content. Another useful relation for the derivations that follow is the following Euler's formula:

$$e^{j\phi} = \cos(\phi) + j \sin(\phi) \quad (10)$$

with ϕ as an arbitrary angle.

The MDC methodology follows the depiction in Fig. 2, where modulation and demodulation involve signal multiplications with trigonometric functions at the disturbance frequency ω_r . In contrast to the work of [15], any filtering in the demodulation stage is omitted and is relocated to the controller block/stage for the sake of generalization.

Demodulation is the first stage of the MDC scheme, where \dot{x} , being the output of the plant $G(s)$ perturbed by disturbance F_{sd} , is multiplied by cosine and sine of the disturbance frequency ω_r . The cosine and sine multiplication of \dot{x} results in

$$\begin{bmatrix} \dot{x}_c(t) \\ \dot{x}_s(t) \end{bmatrix} = \begin{bmatrix} 2 \cos(\omega_r t + \psi_{\text{off}}) \\ 2 \sin(\omega_r t + \psi_{\text{off}}) \end{bmatrix} \dot{x}(t) \quad (11)$$

with \dot{x}_c and \dot{x}_s being the quadrature and in-phase components of the output and ψ_{off} as a phase offset. It needs to be remarked that the factor of 2 in (11) follows the convention of [15] and that ψ_{off} is plant-specific and dependent on its dynamics, as detailed later on in Section V-B.

By making use of (9) and (10), the relation (11) results in the following frequency-domain representation:

$$\begin{bmatrix} \dot{X}_c(s) \\ \dot{X}_s(s) \end{bmatrix} = \left(e^{j\psi_{\text{off}}} \begin{bmatrix} 1 \\ -j \end{bmatrix} \dot{X}(s_-) + e^{-j\psi_{\text{off}}} \begin{bmatrix} 1 \\ j \end{bmatrix} \dot{X}(s_+) \right). \quad (12)$$

For each of the quadrature and in-phase channels, a linear time-invariant (LTI), SISO *demodulated controller* $C(s)$ is implemented and forms a diagonal decoupled structure, as shown in the following:

$$\begin{bmatrix} \Delta T_{g,c}(s) \\ \Delta T_{g,s}(s) \end{bmatrix} = \mathbf{C}(s) \begin{bmatrix} \dot{X}_c(s) \\ \dot{X}_s(s) \end{bmatrix} \quad (13)$$

where $\mathbf{C}(s) = C(s)\mathbf{I}_{2 \times 2}$. The diagonal controller structure is intended for equal load reduction performance on both channels of the multivariable demodulated system and is valid if both channels have negligible interaction/coupling. As will be shown in Section IV, this condition is generally not met for all operating points. The phase offset earlier introduced in (11) plays an important role in the decoupling of the system throughout varying operational conditions.

Transforming back the quadrature and in-phase control signals $\Delta T_{g,c}$ and $\Delta T_{g,s}$ from the demodulated domain back to the additive torque signal ΔT_g is accomplished by the modulation operation

$$\Delta T_g(s) = \frac{1}{2} \left([1 \quad -j] \begin{bmatrix} \Delta T_{g,c}(s_-) \\ \Delta T_{g,s}(s_-) \end{bmatrix} + [1 \quad j] \begin{bmatrix} \Delta T_{g,c}(s_+) \\ \Delta T_{g,s}(s_+) \end{bmatrix} \right) \quad (14)$$

which is the frequency domain equivalence of

$$\Delta T_g(t) = [\cos(\omega_r t) \quad \sin(\omega_r t)] \begin{bmatrix} \Delta T_{g,c}(t) \\ \Delta T_{g,s}(t) \end{bmatrix}. \quad (15)$$

The equation above completes the derivation for the MDC framework.




Fig. 2. MDC scheme for the cancellation of a side-side periodic load $F_{sd} = a_{sd} \cos(\omega_r t + \phi_{sd})$ affecting wind turbine tower $G(s)$. The demodulation operation is driven by the disturbance frequency ω_r and creates a separation of the output signal \dot{x} into quadrature and in-phase signals, \dot{x}_c and \dot{x}_s , respectively. On these channels, two identical SISO controllers $C(s)\mathbf{I}_{2 \times 2}$ are designed, generating the control inputs $\Delta T_{g,c}$ and $\Delta T_{g,s}$. Finally, modulation at ω_r combines these two control inputs into a single signal ΔT_g that is fed into $G(s)$ to alleviate the periodic loading. The phase offset ψ_{off} can be added to the demodulator to influence the system's behavior, such as channel decoupling. Note that the negative sign preceding $C(s)$ indicates the negative feedback convention used in the framework and the inverse of the scaling factor s_f follows F_{sd} for consistency with (7) and (8). This diagram only considers the proposed control solution with the tower dynamics $G(s)$; the complete wind turbine is also torque-controlled using the $K\omega_r^2$ controller strategy (4).




Fig. 3. (a) SISO modulated controller $C_m(s, \omega_r)$ and (b) MIMO demodulated plant $\mathbf{H}(s, \omega_r)$ in the MDC scheme.

IV. MDC CONTROLLER AND SYSTEM ANALYSIS

The established MDC framework allows for analysis of the system and controller, as depicted in Fig. 3. Fig. 3(a) shows the combination of the (de)modulators with the controller $C(s)$, forming a SISO *modulated controller* representation from \dot{x} to ΔT_g . This transformed controller possesses several beneficial properties, as further demonstrated in Section IV-A. Presented in Fig. 3(b) is the multiple-input multiple-output (MIMO) *demodulated plant* realization in the quadrature and in-phase channels from $[\Delta T_{g,c}, \Delta T_{g,s}]^T$ to $[\dot{x}_c, \dot{x}_s]^T$, resulting from the combination of $G(s)$ and the (de)modulators. Of particular importance is the knowledge of potential cross-coupling between the demodulated channels of the MIMO plant presented in Section IV-B. Section IV-C provides insights into the properties of the demodulated multivariable system toward the justification of a decentralized controller $C(s)$.

In Sections IV-A and IV-B, theoretical results for transformed controllers and systems are provided, which are subsequently leveraged for the analysis of a linear wind turbine model in Section IV-C. The phase offset ψ_{off} plays a remarkably important role in decoupling the demodulated system; however, to provide a clearer analysis, this variable will be included in the derivations after this section.

A. SISO Modulated Controller Representation

As previously indicated and shown in Fig. 3(a), the derived frequency-domain framework allows for a different perspective in analyzing the LTI controllers $C(s)$ in the modulation–demodulation scheme. This section shows a remarkable property of the MDC scheme in that the LTI controllers are transformed into a SISO linear time-varying (LTV) controller structure when the modulation and demodulation stages are accounted for.

The SISO modulated controller representation from $\dot{X}(s)$ to $\Delta T_g(s)$ is derived by first substituting (12) to (13) to obtain the following expression:

$$\begin{bmatrix} \Delta T_{g,c}(s) \\ \Delta T_{g,s}(s) \end{bmatrix} = C(s) \left(\begin{bmatrix} 1 \\ -j \end{bmatrix} \dot{X}(s_-) + \begin{bmatrix} 1 \\ j \end{bmatrix} \dot{X}(s_+) \right) \quad (16)$$

which is subsequently combined with (14), resulting in

$$\Delta T_g(s) = C_m(s, \omega_r) \dot{X}(s) = (C(s_-) + C(s_+)) \dot{X}(s) \quad (17)$$

being scheduled by ω_r . The above relation in (17) shows that simple LTI controllers in the demodulated system become LTV if the (de)modulators are included. Under the assumption that ω_r is slowly varying and does not (significantly) change within its period, as stated previously, the results from the linear analysis framework in this section generalize to the nonlinear implementation.

Using the derived relation between $C(s)$ and $C_m(s, \omega_r)$ in (17). This section shows three, $n = \{1, 2, 3\}$, controller

types of interest $C_n(s)$, for which a convenient analytical expression $C_{m,n}(s, \omega_r)$ exists.

- 1) The first LTI controller is a *proportional controller*

$$C_1 = K_P \quad (18)$$

with $K_P \in \mathbb{R}$ as a constant gain, produces $\Delta T_{g,c}$ and $\Delta T_{g,s}$ that scale \dot{x}_c and \dot{x}_s . This controller is transformed into

$$C_{m,1} = 2K_P \quad (19)$$

independent of ω_r —thus, retains the LTI characteristic of C_1 .

- 2) The second LTI controller is an *integral controller*

$$C_2(s) = \frac{K_I}{s} \quad (20)$$

with $K_I \in \mathbb{R}$ as an integral gain, which has infinite gain for steady-state deviations and alleviates high-frequency components of \dot{x}_c and \dot{x}_s . Transformation of the considered controller results in

$$C_{m,2}(s, \omega_r) = \frac{2K_I s}{s^2 + \omega_r^2} \quad (21)$$

being an undamped inverted notch filter with a complex pole pair at $\pm j\omega_r$ and, thus, infinite gain at ω_r [13]. This also means that full cancellation of periodic load at this frequency is possible by this type of controller. Also, it is worth mentioning that this controller structure bears a similarity with that of repetitive control. However, both controllers differ in that (21) only tackles the fundamental disturbance frequency, whereas repetitive control also inherently accounts for the higher harmonics. Thus, the former is more advantageous in terms of reduced actuator wear and tear. The interested reader is referred to the literature (e.g., [29], [30]) for more details on repetitive control.

- 3) The last LTI controller is a *first-order low-pass filter*

$$C_3(s) = \frac{K_L}{s + \omega_{LPF}} \quad (22)$$

with a constant gain $K_L \in \mathbb{R}$ and $\omega_{LPF} \in \mathbb{R}^+$ as the cut-off frequency. This controller is similar to the previous two LTI controllers in that it proportionally scales \dot{x}_c and \dot{x}_s but also alleviates high-frequency components in the demodulated measurement signals. The introduction of ω_{LPF} moves the pole away from the origin, resulting in a noninfinite steady-state gain, in contrast to the integrator controller. Its SISO-modulated expression

$$C_{m,3}(s, \omega_r) = \frac{2K_L(s + \omega_{LPF})}{s^2 + 2\omega_{LPF}s + \omega_{LPF}^2 + \omega_r^2} \quad (23)$$

interestingly, is also an inverted notch but with a beneficial property in that it contains a damping term in the denominator ($2\omega_{LPF}s$), tunable via the selection of ω_{LPF} . This means that, in contrast to $C_{m,2}(s, \omega_r)$, the gain of the controller at ω_r can be limited, which can be




Fig. 4. Bode magnitude plots of the demodulated controller $C_n(s)$ (top) and the resulting SISO modulated controller $C_{m,n}(s, \omega_r)$ (bottom), $n = \{1, 2, 3\}$. The proportional controller C_1 is mapped into $C_{m,1}$, being the same proportional controller but with an additional factor of 2. The integral controller $C_2(s)$ is rendered into an undamped notch filter $C_{m,2}(s, \omega_r)$ with infinite gain at $\omega_r = 0.5$ rad/s. The low-pass filter $C_3(s)$ with a cut-off frequency of $\omega_{LPF} = 0.01$ rad/s results into a damped inverted notch filter $C_{m,3}(s, \omega_r)$.

desirable in terms of actuation activity needed to dampen periodic loading and added robustness.

Fig. 4 depicts the Bode magnitude plots of the considered nominal and transformed controllers, which are, respectively, shown by the top and bottom plots to support the discussed observed conclusions. The plots are created with arbitrary choices for $\omega_r = 0.5$ rad/s, $\omega_{LPF} = 0.01$ rad/s and $K_P = 2$. For the gains in $C_2(s)$ and $C_3(s)$, $K_I = K_L = 2\omega_{LPF}$ is chosen such that its crossover frequency matches with that of $C_3(s)$, which results in a clearer comparison.

In addition to the aforementioned presented LTI controllers $C_n(s)$, alternative controller configurations, potentially of greater complexity, could be suggested and their SISO modulated (LTV) counterparts could be derived by using (17). Please refer to [15] for controller selection guidelines.

B. MIMO Demodulated Plant Representation

The incorporation of the (de)modulators in the proposed framework enables the plant dynamics to be represented as an MIMO system, as shown in Fig. 3(b), with which the presence of cross-coupling between channels can be investigated. To render the plant dynamics into their demodulated, MIMO representation, the SISO plant $G(s)$ is substituted into (12) such that the following equation is obtained:

$$\begin{bmatrix} \dot{X}_c(s) \\ \dot{X}_s(s) \end{bmatrix} = \begin{bmatrix} 1 \\ -j \end{bmatrix} G(s_-) \Delta T_g(s_-) + \begin{bmatrix} 1 \\ j \end{bmatrix} G(s_+) \Delta T_g(s_+) \quad (24)$$

and substituting (14) into (24) gives rise to the 2P (i.e., twice-per-revolution) terms indicated by $s_{2\pm} = s \pm 2j\omega_r$ as follows:

$$\begin{bmatrix} \dot{X}_c(s) \\ \dot{X}_s(s) \end{bmatrix} = \underbrace{\begin{bmatrix} \mathbf{G}_1(s, \omega_r)^\top \\ \mathbf{G}_2(s, \omega_r)^\top \\ \mathbf{G}_3(s, \omega_r)^\top \end{bmatrix}}_{\mathbf{H}(s, \omega_r)^\top} \begin{bmatrix} \Delta T_{g,c}(s_{2-}) \\ \Delta T_{g,s}(s_{2-}) \\ \Delta T_{g,c}(s) \\ \Delta T_{g,s}(s) \\ \Delta T_{g,c}(s_{2+}) \\ \Delta T_{g,s}(s_{2+}) \end{bmatrix} \quad (25)$$

with $\mathbf{H}(s, \omega_r)$ as the concatenation of the following transfer matrices:

$$\mathbf{G}_1(s, \omega_r) = \frac{1}{2} \begin{bmatrix} G(s_-) & -jG(s_-) \\ -jG(s_-) & -G(s_-) \end{bmatrix} \quad (26a)$$

$$\mathbf{G}_2(s, \omega_r) = \frac{1}{2} \begin{bmatrix} G(s_-) + G(s_+) & j(G(s_-) - G(s_+)) \\ j(-G(s_-) + G(s_+)) & G(s_-) + G(s_+) \end{bmatrix} \quad (26b)$$

$$\mathbf{G}_3(s, \omega_r) = \frac{1}{2} \begin{bmatrix} G(s_+) & jG(s_+) \\ jG(s_+) & -G(s_+) \end{bmatrix}. \quad (26c)$$

The higher harmonic terms add complexity to the control design and analysis since all the contributions $\mathbf{G}_1(s, \omega_r)$, $\mathbf{G}_2(s, \omega_r)$, and $\mathbf{G}_3(s, \omega_r)$ need to be accounted for. Therefore, the relation above is simplified by selecting an appropriate controller structure that filters out 2P frequency components such that several terms can be omitted, i.e., $[\Delta T_{g,c}(s_{2\pm}), \Delta T_{g,s}(s_{2\pm})]^\top \approx 0$. Among the LTI controllers presented in Section IV-A, either $C_2(s)$ or $C_3(s)$ is a viable candidate due to the roll-off at high frequencies. Therefore (25) simplifies into

$$\begin{bmatrix} \dot{X}_c(s) \\ \dot{X}_s(s) \end{bmatrix} \approx \mathbf{G}_2(s, \omega_r) \begin{bmatrix} \Delta T_{g,c}(s) \\ \Delta T_{g,s}(s) \end{bmatrix} \quad (27)$$

representing an approximation of the demodulated multivariable plant.

C. Application of MDC on a Simplified Wind Turbine

Now, with the tower dynamics transfer function $G(s)$ at hand, the definition of $\mathbf{G}_2(s, \omega_r)$ in (26) is used to transform the nominal dynamics into its demodulated counterpart. It is compelling to investigate their relations by studying Bode plots of both their dynamics. To this end, rather arbitrary wind turbine modal parameters $m = 3 \times 10^4$ kg, $d_{\text{eff}} = 3 \times 10^3$ Ns/m, and $k = 1.5 \times 10^4$ N/m are considered. The chosen parameters resemble a soft-soft wind turbine tower with its natural frequency being $\omega_n = (k/m)^{1/2} = 0.7071$ rad/s and the rotor operates in $\omega_r \in \Omega = [\omega_{r,\text{min}}, \omega_{r,\text{rated}}]$, with $\omega_{r,\text{min}} = 0.5$ rad/s and $\omega_{r,\text{rated}} = 1.2$ rad/s.

Fig. 5 shows the Bode plots of both $G(s)$ and $\mathbf{G}_2(s, \omega_r)$, in which the former and latter transfer functions are represented, respectively, in Fig. 5(a) and (b). As $\mathbf{G}_2(s, \omega_r)$ is a 2×2 Hermitian transfer function matrix, its main and off-diagonal elements

$$\begin{aligned} G_{2,11}(s, \omega_r) &= G_{2,22}(s, \omega_r) \\ &= \frac{1}{2} \frac{N(s_-)D(s_+) + N(s_+)D(s_-)}{D(s_-)D(s_+)} \end{aligned} \quad (28)$$

and

$$\begin{aligned} G_{2,12}(s, \omega_r) &= -G_{2,21}(s, \omega_r) \\ &= \frac{j}{2} \frac{N(s_-)D(s_+) - N(s_+)D(s_-)}{D(s_-)D(s_+)} \end{aligned} \quad (29)$$

are shown in the respective first and second columns of Fig. 5(b). Since $\mathbf{G}_2(s, \omega_r)$ is parameterized by the 1P frequency, its Bode plot is evaluated for different ω_r values. Specifically, in this case, three frequencies are considered to understand the system's behavior before, at, and after the tower's resonance frequency, i.e., $\omega_r^{(i)} = \{\omega_{r,\text{min}}, \omega_n, \omega_{r,\text{rated}}\}$, where $i = \{1, 2, 3\}$.

The modulation-demodulation of $G(s)$ at $s = j\omega_r^{(i)}$ maps its magnitude, $|G(j\omega_r^{(i)})|$, into the steady-state magnitude of the demodulated plant, $|\mathbf{G}_2(0, \omega_r^{(i)})|$. Roughly speaking, for the diagonal LTI SISO controller $\mathbf{C}(s)$ to be justified for the entire turbine operating range, it is desirable to have the steady-state magnitudes of the main diagonal be more dominant than the off-diagonal counterparts, that is,

$$|G_{2,11}(0, \omega_r)| \gg |G_{2,12}(0, \omega_r)| \quad \forall \omega_r \in \Omega. \quad (30)$$

When the above condition is met, the quadrature and in-phase channels are well decoupled and thus, no significant interaction at low-frequency region and steady-state between channels is present [15].

In Fig. 5(b), it is shown that this is the case for $\mathbf{G}_2(0, \omega_r^{(2)})$, with $\omega_r^{(2)} = \omega_n$. The reason behind such main-diagonal dominance at this operating point is partly due to the presence of a pair of zeros (differentiators) at the origin of $G_{2,12}(s, \omega_r^{(2)})$. Consequently, $|G_{2,12}(s, \omega_r^{(2)})|$ is 0 at steady-state and increases with a 40-dB/decade slope as frequency goes higher, also indicated in Fig. 5(b). Moreover, as $|G_{2,11}(s, \omega_r^{(2)})|$ has a maximized steady-state contribution, shown by the flat-line region at low frequencies, it can be directly concluded that (30) is satisfied in this case. This is not necessarily the case when $\omega_r \neq \omega_n$, as exemplified by $\omega_r^{(1)}$ and $\omega_r^{(3)}$. In both cases, the absence of any differential and integral actions in $G_{2,12}(s, \omega_r)$ results in flat magnitudes at low frequencies but with higher gains compared to $G_{2,11}(s, \omega_r)$; thus, cross-coupling is present for the lower frequency region of interest. Hence, it may be preferred to utilize $G_{2,12}(s, \omega_r)$ for control due to these higher gains at these operating conditions. Nevertheless, additional complexity arises in doing so as a 180° of phase difference presents in $\angle G_{2,12}(0, \omega_r)$ [shown by arrows 1 and 3 in Fig. 5(b)]. This infers that a gain sign flip occurs when the turbine switches operating regime from $\omega_r < \omega_n$ to $\omega_r > \omega_n$ and vice versa, which may result in instability.

Also noticeable in Fig. 5(b) is the presence of two resonance peaks in $|\mathbf{G}_2(s, \omega_r)|$ for $\omega_r^{(1)}$ and $\omega_r^{(3)}$ with their magnitudes being -6 dB lower than that of $|G(j\omega_n)|$. These two peaks originate from the shift of the nominal plant's natural frequency into $|\omega_n \pm \omega_r^{(i)}|$ due to the $D(s_{\pm})$ terms in (28) and (29), which also explains why only a single peak presents for $\omega_r^{(2)}$ case [15]. Although there is significant coupling in higher frequencies in the off-diagonal, only the low-frequent region is of interest for the controller design.




Fig. 5. Bode magnitude and phase plots of (a) nominal and (b) demodulated wind turbine models. In (a), vertical dashed lines indicate the operating range of a soft–soft wind turbine $G(s)$, where a resonance peak at about $\omega = \omega_n = 0.7071$ rad/s is apparent in the magnitude plot. A 180° phase shift occurs due to the presence of this resonance, as shown in the corresponding phase plot. The points indicated by labeled arrows $i = \{1, 2, 3\}$ represent three sample points $\omega_r^{(i)} = \{\omega_{r,\min}, \omega_n, \omega_{r,\text{rated}}\}$, with $\omega_{r,\min} = 0.5$ rad/s and $\omega_{r,\text{rated}} = 1.2$ rad/s, to evaluate the mapping from $G(s)$ into the steady-state components of $\mathbf{G}_2(s, \omega_r)$, as shown in (b), before, during, and after the resonance. Note the 40-dB/decade slope in the magnitude plot of $G_{2,12}(s, \omega_r^{(2)})$ at low frequencies, which indicates the presence of two zeros at the origin.

The above observation on the magnitude and phase mapping between both plant representations can be understood better by taking another look at (28) and (29). First, since both $G_{2,11}(s, \omega_r)$ and $G_{2,12}(s, \omega_r)$ are constituted by the same poles, whether or not (30) is satisfied depends only on the zeros of these transfer functions. Second, as these zeros are located at $z_{1,2} = \pm(\omega_n - \omega_r)^{1/2}$, they can be either purely on the imaginary axis, origin, or real axis, depending on the value of the rotational speed of the turbine with respect to the tower’s natural frequency. This creates different (steady-state) phase behavior for $\omega_r < \omega_n$ and $\omega_r > \omega_n$ because the latter produces a right-half-plane (RHP) zero at the dominant channel such that the aforementioned 180° phase difference/sign flip occurs. Therefore, to ensure main-diagonal dominance for the entire turbine operating range and elimination of the phase drop in the dominant channels, it becomes compelling to manipulate the zero locations of $G_{2,11}(s, \omega_r)$ and $G_{2,12}(s, \omega_r)$. In Section V, both goals can be achieved simultaneously by the inclusion of an offset in the MDC scheme.

Remark 2: Whether \ddot{x} , \dot{x} , or x is used as the output of the plant affects the numerator of $G(s)$ and thus the zeros of (28) and (29). This also determines how (30) is satisfied for different operating points. Nevertheless, regardless of the selected output signal, channel cross-coupling and a 180° phase shift in the dominant channel of $\mathbf{G}_2(s, \omega_r)$ still exists, which necessitates their compensation by phase offset inclusion.

V. QUADRATURE AND IN-PHASE CHANNELS DECOUPLING BY PHASE OFFSET INCLUSION

The MIMO demodulated plant channel cross-coupling, as well as the gain sign flip examined earlier, has uncovered potential challenges in the proposed MDC design. To gain more knowledge on the degree of this coupling for the entire turbine operating range, a more reliable metric, namely the

relative gain array (RGA), is used in Section V-A. As inferred in Section IV, the inclusion of the phase offset ψ_{off} in the MDC plays a key role in the decoupling of the MIMO demodulated plant. In Section V-B, the optimal phase offset value, by which the highest degree of decoupling and gain sign flip correction can be achieved, is discussed.

A. Relative Gain Array Analysis

RGA, denoted $\Lambda(\cdot)$, is a measure of interaction between multiple control channels [31]. The RGA is used to assess the coupling of the MIMO demodulated system at steady-state $\mathbf{G}_2(0, \omega_r)$ as follows:

$$\Lambda(\mathbf{G}_2(0, \omega_r)) = \mathbf{G}_2(0, \omega_r) \circ \mathbf{G}_2(0, \omega_r)^{-\top} \quad (31)$$

where “ \circ ” denotes an element-by-element multiplication known as the Hadamard or Schur product.

Fig. 6 shows the evaluation of $\Lambda(\mathbf{G}_2(0, \omega_r))$ for an extended range of rotor operation $\omega_r \in \Omega' = [0, 1.5]$ rad/s, where the magnitude of the main diagonal elements $|\Lambda_{11}| = |\Lambda_{22}|$ is shown by the blue lines and that of the off-diagonal $|\Lambda_{12}| = |\Lambda_{21}|$ is represented by the red lines. As the rows and columns of $\Lambda(\mathbf{G}_2(0, \omega_r))$ sum to 1, it is sufficient to mention only $|\Lambda_{11}|$ for the following discussion.

Fig. 6(a) depicts the current case where the main diagonal pairings are dominant with $|\Lambda_{11}| = 1$ only about $\omega_r^{(2)} = \omega_n$. Also evident is the increasing off-diagonal dominance as ω_r deviates from ω_n with $|\Lambda_{11}| \approx 0$ at $\omega_r^{(1)}$ and $\omega_r^{(3)}$. This shows agreement with the previous Bode plot observations in Fig. 5(b) and hints that the current input–output pairings preference is not suitable for the entire operating range [31]. Swapping the input–output pairings to the off-diagonal may be preferable but insufficient to account for the negative gain resulting from the 180° phase difference in $\angle \mathbf{G}_2(0, \omega_r)$ indicated by the red-shaded region. Fig. 6(b) shows an ideal case where $|\Lambda_{11}| = 1$ for the entire operating regime without

any gain sign change, as opposed to Fig. 6(a). In Section V-B, such a condition is shown to be achievable by means of phase offset inclusion in the proposed MDC framework.

B. Phase Offset Inclusion

In Section IV-C, it has been shown that the value of ω_r plays a role in the positioning of the zeros of $G_{2,11}(s, \omega_r)$ and $G_{2,12}(s, \omega_r)$, resulting in both channel cross-coupling and gain sign flip. The previously omitted phase offset ψ_{off} , however, may play a critical role in tackling both issues at the same time by influencing these zero locations. In particular, the optimal phase offset value, defined by

$$\psi_{\text{off}}^*(\omega_r) = -\angle G(j\omega_r) \quad (32)$$

can be chosen. As the plant's dynamics vary according to the frequency of the periodic excitation, ψ_{off}^* varies according to ω_r . In the remainder of this article, the notation ω_r is dropped when referring to ψ_{off}^* for brevity's sake. This offset value has been rigorously studied in the literature, where methods such as averaging theory, root locus, and loop-shaping have been employed. The interested reader is referred to [14], [32], and references therein for more detailed analysis. The effects of ψ_{off} inclusion on the MIMO demodulated plant and SISO modulated controller are discussed in Sections V-B1 and V-B2.

1) *Effects of ψ_{off} on MIMO Demodulated Plant:* To understand the effects ψ_{off} creates on $\mathbf{G}_2(s, \omega_r)$, the derivation done in Section IV-B is repeated by including this offset, which results in the following relation:

$$\mathbf{G}_2(s, \omega_r, \psi_{\text{off}}^*) = \begin{bmatrix} \frac{e^{j\psi_{\text{off}}^*} G(s_-) + e^{-j\psi_{\text{off}}^*} G(s_+)}{2} & j \frac{e^{j\psi_{\text{off}}^*} G(s_-) - e^{-j\psi_{\text{off}}^*} G(s_+)}{2} \\ j \frac{-e^{j\psi_{\text{off}}^*} G(s_-) + e^{-j\psi_{\text{off}}^*} G(s_+)}{2} & \frac{e^{j\psi_{\text{off}}^*} G(s_-) + e^{-j\psi_{\text{off}}^*} G(s_+)}{2} \end{bmatrix} \quad (33)$$

in which $\psi_{\text{off}} = \psi_{\text{off}}^*$ is applied. In comparison with the original definition of $\mathbf{G}_2(s, \omega_r)$ in (26b), $e^{\pm j\psi_{\text{off}}^*}$ terms appear in (33) after the inclusion of ψ_{off}^* into the MDC scheme. These terms play a role in zero positioning of both $G_{2,11}(s, \omega_r, \psi_{\text{off}}^*)$ and $G_{2,12}(s, \omega_r, \psi_{\text{off}}^*)$, thereby affecting their (steady-state) gains and phases.

Fig. 7 depicts the Bode plot of the MIMO demodulated wind turbine model including ψ_{off}^* (33). It is apparent that in comparison with the previous case in Fig. 5(b), the transfer function matrix has now become diagonally dominant, with their phases starting from zero at the steady state and not exhibiting 180° phase difference anymore. This main-diagonal dominance is made clearer by investigating the analytical expressions for the main and off-diagonal elements of the MIMO demodulated plant at steady-state by substituting (8) into (33) and setting $s = 0$ rad/s, that is (34) and (35), as shown at the bottom of the next page, respectively.

Then, the steady-state magnitudes of both the main and off-diagonal elements can be computed for all operating points, where the main diagonal's magnitude equals that of

the nominal plant at the excitation frequency

$$|G_{2,11}(0, \omega_r, \psi_{\text{off}}^*)| = |G(j\omega_r)| \quad (36)$$

whereas

$$|G_{2,12}(0, \omega_r, \psi_{\text{off}}^*)| = 0. \quad (37)$$

This means that (30) is always fulfilled.

Steady-state RGA evaluation of the MIMO demodulated plant after the optimal offset inclusion $\Lambda(\mathbf{G}(0, \omega_r, \psi_{\text{off}}^*))$ also confirms the above observation. This is depicted in Fig. 6(b), where $|\Lambda_{11}| = 1$ for the entire (extended) operating range.

The above observations conclude that under the inclusion of ψ_{off}^* , the main diagonal dominance is asserted and no gain sign flip is experienced as the rotational frequency sweeps through the tower's natural frequency. Therefore, the use of diagonal controller $\mathbf{C}(s)$ is now justified.

2) *Effects of ψ_{off} on SISO Modulated Controller:* Similar to Section V-B1, the effects of the ψ_{off} inclusion on the SISO modulated controller requires $C_m(s, \omega_r)$ derived in Section IV-A to be reformulated into

$$C_m(s, \omega_r, \psi_{\text{off}}) = e^{-j\psi_{\text{off}}} C(s_-) + e^{j\psi_{\text{off}}} C(s_+). \quad (38)$$

Effectively, the LTI controllers (18), (20), and (22) previously proposed are transformed by (38) [also by making use of (10)] into the following respective (LTV) controllers:

$$\begin{aligned} C_{m,1}(\psi_{\text{off}}) &= 2K_P \cos(\psi_{\text{off}}) \end{aligned} \quad (39)$$

$$\begin{aligned} C_{m,2}(s, \omega_r, \psi_{\text{off}}) &= \frac{2K_I (\cos(\psi_{\text{off}})s + \sin(\psi_{\text{off}})\omega_r)}{s^2 + \omega_r^2} \end{aligned} \quad (40)$$

$$\begin{aligned} C_{m,3}(s, \omega_r, \psi_{\text{off}}) &= \frac{2K_L (\cos(\psi_{\text{off}})(s + \omega_{\text{LPF}}) + \sin(\psi_{\text{off}})\omega_r)}{s^2 + 2\omega_{\text{LPF}}s + \omega_{\text{LPF}}^2 + \omega_r^2}. \end{aligned} \quad (41)$$

From (39)–(41), it can be seen that the phase offset ψ_{off} influences the modulated controllers in the following ways. First, for $C_{m,1}(\psi_{\text{off}})$, the phase offset affects the gain of the controller. However, in Section IV-B, it has been stated that this controller structure cannot filter out the 2P frequency components; therefore, it is not considered any further during the time-domain demonstration in Section VI. For $C_{m,2}(s, \omega_r, \psi_{\text{off}})$, its zero location becomes

$$z_{m,2} = -\omega_r \tan(\psi_{\text{off}}).$$

In the original formulation (21), $C_{m,2}(s, \omega_r)$ has a pure zero at the origin but the offset enables relocation of this zero into the left-half plane (LHP) or RHP. Similarly, for $C_{m,3}(s, \omega_r, \psi_{\text{off}})$, its zero is relocated from $-\omega_{\text{LPF}}$ into

$$z_{m,3} = -\omega_{\text{LPF}} - \omega_r \tan(\psi_{\text{off}}).$$

An in-depth analysis of the controller zero positioning by this offset is discussed in [14].

Fig. 8 illustrates the Bode plots of the SISO modulated controllers, similar to that of Section IV-A, without and with




Fig. 6. Steady-state RGA of $\mathbf{G}_2(s, \omega_r)$ over the operating regime of a simple wind turbine model (a) without and (b) with phase offset ψ_{off} . The inclusion of optimal phase offset ψ_{off}^* into the MDC results in decoupled quadrature and in-phase input–output channels at steady-state, as well as eliminating the need for control gain swapping. Please note that for the figures, \dot{x} is measured. In case of x or \ddot{x} , these results, in particular that of (a) will be different (see Remark 2).




Fig. 7. Bode plot of the demodulated wind turbine model with the optimal phase offset included $\mathbf{G}_2(s, \omega_r, \psi_{\text{off}}^*)$. It is evident that the steady-state off-diagonal contributions are attenuated and that the main diagonal components become dominant.

ψ_{off} . Compared to the inverted notch filters without ψ_{off} , those with the optimal offset included exhibit increased magnitude at the low frequencies due to the introduction of a zero [for $C_{m,2}(s, \omega_r, \psi_{\text{off}})$] or relocation of an existing zero to a high frequency [for $C_{m,3}(s, \omega_r, \psi_{\text{off}})$]. For both controllers, the same ψ_{off} is chosen.

VI. SIMULATION RESULTS

In this section, simulations demonstrating the performance of the proposed control scheme are carried out. The control scheme consists of the conventional active tower damping controller for increasing the effective damping of the side–side tower motion, as explained in Section II-B. This conventional




Fig. 8. Bode plots of SISO modulated controllers, without (dashed lines) and with (solid lines) ψ_{off} , $C_{m,n}(s, \omega_r)$ and $C_{m,n}(s, \omega_r, \psi_{\text{off}})$, respectively, $n = \{1, 2, 3\}$ and $\omega_r = 0.5$ rad/s.

controller is augmented by the MDC studied earlier in Sections IV and V to alleviate the periodic 1P fatigue load.

Time-domain simulations at two fidelity levels are considered, where the lower fidelity simulations, discussed in Section VI-A, show the proof-of-concept of the MDC framework with the simplified wind turbine model derived earlier. Afterward, high-fidelity simulations employing the National Renewable Energy Laboratory (NREL) OpenFAST software package [33] are covered in Section VI-B.

A. Simplified Turbine Simulations

For the simulations presented here, the wind turbine model derived in Section II is employed. The synthetic tower properties used in Section IV-C are utilized for the tower dynamics (1). The parameters of NREL 5-MW reference

$$\mathbf{G}_{2,11}(0, \omega_r, \psi_{\text{off}}^*) = s_f \frac{m \sin(\psi_{\text{off}}^*) \omega_r^3 + d \cos(\psi_{\text{off}}^*) \omega_r^2 - k \sin(\psi_{\text{off}}^*) \omega_r}{d^2 \omega_r^2 + k^2 - 2km \omega_r^2 + m^2 \omega_r^4} \quad (34)$$

$$\mathbf{G}_{2,12}(0, \omega_r, \psi_{\text{off}}^*) = s_f \frac{-m \cos(\psi_{\text{off}}^*) \omega_r^3 + d \sin(\psi_{\text{off}}^*) \omega_r^2 + k \cos(\psi_{\text{off}}^*) \omega_r}{d^2 \omega_r^2 + k^2 - 2km \omega_r^2 + m^2 \omega_r^4} \quad (35)$$

TABLE I

PARAMETERS OF THE (MODIFIED) NREL 5-MW REFERENCE WIND TURBINE AND ENVIRONMENT CONDITION

Description	Notation	Value	Unit
Rated generator power	-	5	MW
Optimal tip-speed ratio	λ^*	7	-
Max. power coefficient	C_p^*	0.458	-
Fine pitch angle	-	0	°
Optimal torque gain (LSS)	K	$2.1286 \cdot 10^6$	Nm/(rad/s) ²
LSS equivalent inertia	J_r	$4.0802 \cdot 10^7$	kgm ²
Gearbox ratio	G	97	-
Rotor radius	R	63	m
Minimum rotor speed	$\omega_{r,\min}$	0.5	rad/s
Rated rotor speed	$\omega_{r,\text{rated}}$	1.2	rad/s
Rated generator torque	$T_{g,\text{rated}}$	43.09355	kNm
Generator efficiency	-	0.944	-
Hub height	H	90	m
Tow. natural frequency (sca.)	$\omega_{n,s}$	0.6963	rad/s
Tow. modal mass (sca.)	m_s	$3.6200 \cdot 10^5$	kg
Tow. modal damping (sca.)	d_s	$2.4588 \cdot 10^3$	Ns/m
Tow. modal stiffness (sca.)	k_s	$1.7677 \cdot 10^5$	N/m
Air density	ρ	1.225	kg/m ³

sca. = scaled

wind turbine [34], as shown in Table I, are used for the rotor dynamics (3) and to determine the below-rated torque controller gain according to (4).

A steady, uniform, staircase wind inflow from $v = 5$ m/s to $v = 10$ m/s with 1.25 m/s of speed increment is generated for the simulations. Each wind speed lasts for 250 s, resulting in 1250 s of total simulation time. The choice of this wind speed condition is made such that the rotor starts about $\omega_{r,\min}$ at $\omega_r = 0.58$ rad/s and ends near $\omega_{r,\text{rated}}$ at $\omega_r = 1.128$ rad/s, thus covering most of the operating range Ω and that resonance is experienced when $v = 6.25$ m/s at $t = 250 - 500$ s. To model a rotor imbalance, F_{sd} with $a_{sd} = 150$ N and $\phi_{sd} = \pi/4$ rad is selected, equivalent to $a_{sd}/s_f = 9$ kNm of torque amplitude at the tower-top.

Figs. 9 and 10 depict the performance of the controllers in the MDC scheme, where only the (damped) inverted notch filters are of interest, without and with ψ_{off}^* included. The respective blue and red lines show the former and latter MDCs, whereas the gray lines show the uncontrolled wind turbine responses. In Figs. 9 and 10, \dot{x} and ΔT_g measurements are depicted by the top and bottom plots, respectively. For MDCs without ψ_{off}^* , $\psi_{\text{off}} = -90^\circ$ is used for the whole operating range Ω to swap the input-output pairings to the more dominant off-diagonal pairs (see Section V-A). For brevity's sake, the notation $C_{m,n}(s, \omega_r)$ is kept for referring to the pair-swapped MDCs in this section.

The tuning gains for the controllers are chosen to be $K_I = K_L = 1500$ and $\omega_{L\text{PF}} = 0.025$ rad/s by loop-shaping while ensuring stability. During the simulations, the value of ψ_{off}^* , used to decouple the control channels, is determined by means of a lookup table (LUT), fed by filtered rotor measurements where a first-order LPF with a cut-off frequency of 0.2 rad/s is employed.

Fig. 9 compares the performance of the undamped inverted notch filters $C_{m,2}(s, \omega_r)$ and $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$. It is observed from Fig. 9 that $C_{m,2}(s, \omega_r)$ does not cancel the 1P periodic loading at the tower as shown in the measurements of \dot{x} .




Fig. 9. Time series response of tower velocity (top) and additive generator torque (bottom) under staircase wind $v = 5 - 10$ m/s where the performance of $C_{m,2}(s, \omega_r)$ and $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$ are demonstrated. Horizontal dashed lines of ± 9 kNm in the bottom plot indicate the periodic load magnitude's equivalence in terms of torque. A zoomed-in plot depicts control action behavior at the end of the simulation.

During resonance, tower oscillation starts to grow due to the strong coupling at this frequency as the main-diagonal pairings gain dominance [see Fig. 6(a)]. After the resonance, the controller enters the negative gain region (i.e., sign flip occurs) and the growth of ΔT_g becomes unbounded. On the other hand, $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$ does not exhibit instability and fully cancels the 1P load. The full cancellation of the periodic load is attributed to the infinite gain of the controller at the disturbance frequency. Notice the convergence of the control action's amplitude to 9 kNm (equal to a_{sd}/s_f) as indicated by the horizontal dashed lines and a zoomed-in plot for $t = 1200 - 1250$ s.

Fig. 10 depicts the performance of the damped inverted notch filters $C_{m,3}(s, \omega_r)$ and $C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$. The differences in both controllers' performance are evident once the wind speed reaches $v = 6.25$ m/s, where resonance starts to occur. The former is shown to dampen the tower's oscillation at about $t = 400 - 450$ s (and slightly beyond when $v = 7.5$ m/s is reached), however, not as effective as the latter, shown by the greater reduction in \dot{x} with lower control action. An inset plot at the top highlights that after the resonance, exemplified for $t = 725 - 750$ s, a slight increase in tower oscillation is caused by $C_{m,3}(s, \omega_r)$. On the other hand, evident tower motion reduction is performed by $C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$. In comparison to $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$ in Fig. 9, $C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$ does not fully cancel the 1P periodic loading due to limited gain at ω_r . Nonetheless, maximum ΔT_g magnitude of only ≈ 4.5 kNm is observed in $C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$ contrast to aggressive 9 kNm exhibited by $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$.

From these simplified wind turbine simulations, it is concluded that ψ_{off}^* is crucial in the load-mitigating performance of the proposed MDCs and in preventing closed-loop instability. Second, it can be observed that MDCs perform best in terms of 1P load reduction when $\omega_r = \omega_n$ as their gains are highest at this frequency. This motivates a gain-scheduling




Fig. 10. Time series response of tower velocity (top) and additive generator torque (bottom) under staircase wind $v = 5 - 10$ m/s where the performance of $C_{m,3}(s, \omega_r)$ and $C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$ are demonstrated. A zoomed-in plot depicts tower velocities at $t = 725 - 750$ s.

strategy to be incorporated into the framework, done in the higher fidelity simulations of the following section.

B. OpenFAST Simulations

In the high-fidelity OpenFAST simulations presented in this section, the NREL 5-MW reference wind turbine is again used. However, since this reference turbine's tower was originally classified as soft–stiff, its wall thickness is downscaled by a factor of 7.5 to recast it into a soft–soft tower design. This consequently reduces tower mass so that its first natural frequency approximates $\omega_n = 0.7071$ rad/s of the soft–soft tower in the simplified wind turbine setting. The tower modal mass, damping, and stiffness for this scaled tower are denoted, respectively, as m_s , d_s , and k_s in Table I and the tower's natural frequency is denoted $\omega_{n,s}$.

For controller design, the reference wind turbine is linearized at the below-rated wind speeds, ranging from $v = 4$ m/s to $v = 10$ m/s with 1-m/s increment. Fig. 11 shows the Bode plots of the linearized wind turbine (gray lines) for the different operating points, where the transfer from the generator torque to tower velocity is taken. Also plotted is the second order tower model $G(s)$ (black lines), in which modal properties of the scaled reference wind turbine's tower are employed, as well as gain adjustment to fit the linearized wind turbine plots. The gain adjustment is made by setting s_f to 1.667 m^{-1} , which from the physical point of view may infer that, for the employed reference turbine, the prismatic beam assumption as used in (1) might be inaccurate. Note that numerical artifacts present in the linearized wind turbine at frequencies lower than 0.01 rad/s, which makes the use of the fit model $G(s)$ more convenient.

Additional damping is added to the lightly-damped $G(s)$ by the conventional active tower damper explained in Section II-B. The gain of the conventional controller is chosen to be $K_{L,\text{conv}} = -10\,000$, which is equivalent to increasing the modal damping into $d_{\text{eff},s} = 1.9125 \cdot 10^4$ Ns/m. The negative sign of $K_{L,\text{conv}}$ is needed to account for the difference in the coor-




Fig. 11. Bode plot of linearized NREL 5-MW reference wind turbine and fit simple model $G(s)$ and closed-loop model with the conventional active tower controller. Vertical dashed lines indicate the operating range of the turbine.

dinate convention used in the simple model and OpenFAST. In Fig. 11, the Bode plot of the fit plant $G(s)$ in closed-loop with this conventional controller is shown by the red, dashed lines and denoted $G'(s)$.

Having a damped tower, the next step is to cascade MDCs on top of the conventional controller. One needs to be reminded that the conventional controller and MDCs serve different purposes and are fundamentally different in that the former increases the effective damping of the tower structure whilst the latter cancels rotational-speed-driven load at the tower. Stated differently, the MDCs can be treated as generalized tower dampers in that they can add more damping to the tower motion not only at a fixed (natural) frequency (such as exemplified in [15]) but also at a varying one, such as used in this work.

Similar to the simple wind turbine simulations, the (damped) inverted notch filters $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$ and $C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$, with $\omega_{\text{LPF}} = 0.01$ rad/s used in the latter, are employed. To cast similar 1P load-reducing performance of MDCs for the entire operating regime, gain-scheduling is implemented by setting the controller gains $K_I = K_L = 0.022\gamma$ with the inverse of the plant's magnitude at the disturbance frequency $\gamma = 1/|G'(j\omega_r)|$ [35] while ensuring stability. Fig. 12 depicts the resulting Bode plots of the SISO [see Fig. 12(a)] and MIMO loop transfer functions [see Fig. 12(b)]

$$L_{m,n}(s, \omega_r^{(i)}, \psi_{\text{off}}^*) = G(s)C_{m,n}(s, \omega_r^{(i)}, \psi_{\text{off}}^*)$$

and

$$L_n(s, \omega_r^{(i)}, \psi_{\text{off}}^*) = G_2(s, \omega_r^{(i)}, \psi_{\text{off}}^*)C_n(s)$$

respectively, where $\omega_r^{(i)} = \{\omega_{r,\text{min}}, \omega_{n,s}, \omega_{r,\text{rated}}\}$. During the constant and turbulent wind cases that follow, the information of γ and $\psi_{\text{off}}^* = \angle G'(j\omega_r)$ (for decoupling the control channels) are fed into the MDCs by LUTs, making use of low-pass-filtered rotor speed measurements with the same cut-off frequency as used in the simple wind turbine simulations.




Fig. 12. Bode plots of SISO and MIMO loop transfer functions for $\omega_r^{(i)} = \{\omega_{r,\text{min}}, \omega_{n,s}, \omega_{r,\text{rated}}\}$. (a) SISO loop transfers with an undamped inverted notch filter and a damped inverted notch filter are depicted with the respective solid and dashed lines. (b) Corresponding transformed MIMO transfers are shown, where the solid lines illustrate the MIMO demodulated plant with an integral controller and dashed lines with a low-pass filter.

1) *Constant Wind Simulations:* Steady, uniform constant wind cases at $v = \{5, 6.25, 10\}$ m/s, each lasting for 1000 s, are employed for simulations in this section, which produce rotor speeds being lower, equal, and higher than the resonance frequency at steady-state. To induce a 1P excitation to the fixed structure by a rotor mass imbalance, a blade's mass density is lowered by 2% with respect to the original value [9] such that two blades are equally heavier than one other blade.

Fig. 13 shows the wind turbine tower velocity and total additive generator torque measurements $\Delta T_{g,\text{total}} = \Delta T_{g,\text{damp}} + \Delta T_g$ for these cases, shown during the steady-state at $t = 900 - 1000$ s. The uncontrolled wind turbine signals are shown by the gray lines and those with only the conventional controller $C_{\text{conv}} = K_{\text{conv}}$ are shown by the blue lines. The conventional tower damper targets fatigue loading at the tower's natural frequency, while tower excitations at other frequencies are not alleviated as effectively, especially the 1P-driven load. This is evident in




Fig. 13. OpenFAST time series results in constant wind cases $v = \{5, 6.25, 10\}$ m/s. During the steady-state at $t = 900 - 1000$ s, a large portion of the tower load is mitigated by the conventional controller cascaded with MDCs where $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$ yields the most reduction. Increased controller input at higher wind speeds is caused by the greater amplitude of the 1P periodic load.

Fig. 13, where the conventional controller performs well only in the second steady wind case where $\omega_r = \omega_n$.

Nevertheless, some residual oscillations are still shown. The performance of C_{conv} is improved by cascading it with the MDCs $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$ and $C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$, illustrated by the respective red and green lines. Similar to the simplified wind turbine simulations in Section VI-A, the infinite gain of $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$ at the 1P frequency creates the most control effort in every case compared to other settings. This consequently allows the controller to mitigate most of the periodic loads while still providing damping at the tower's natural frequency. Less 1P load reduction due to the less aggressive control action at this frequency is demonstrated when C_{conv} is combined with $C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$, while still outperforming C_{conv} without MDCs. Also noticeably different than the simplified wind turbine simulations is the effect of the gain-scheduling of the MDCs, such that the effectiveness of the 1P load reduction is not only observed during the resonance but also when $\omega_r < \omega_n$ at $v = 5$ m/s and $\omega_r > \omega_n$ at $v = 10$ m/s.

Remark 3: The rotor mass imbalance creates greater centrifugal force when the rotor spins faster, resulting in greater 1P loading amplitude at higher rotational speeds, in contrast to the constant amplitude assumed in simplified wind turbine simulations. This explains the need for larger control action of the cascaded controllers for higher rotor speeds.

2) *Turbulent Wind Simulations:* Two Kaimal turbulent cases are chosen based on the International Electrotechnical Commission (IEC) 61400-1 standard [36] with $v_h = 6.25$ m/s of mean wind speed at hub height. Turbulence intensities of $I_T = 4\%$ and $I_T = 12\%$ are selected to represent low and high turbulence, respectively. For these wind cases, 2000 s of simulations are run, where the first 200 s is not accounted for to exclude transient effects from the analysis. The same rotor mass imbalance from the steady wind simulations is used here to induce 1P loading.

Results of these turbulent cases are presented in Fig. 14. Fig. 14(a) depicts the time series results, where records at $t = 875 - 1075$ s and $t = 1575 - 1775$ s are shown for the respective low and high turbulence cases. In Fig. 14(a), v , ω_r , \dot{x} , and $\Delta T_{g,\text{total}}$ measurements are shown from the first to the fourth rows, respectively. Also indicated by the red dashed lines in the measurements of v and ω_r are v_h and $\omega_{n,s}$. Fig. 14(b) depicts the corresponding power spectral density (PSD) plots of \dot{x} and $\Delta T_{g,\text{total}}$, post-processed from the time series measurements. In low turbulence where v varies closer to v_h , ω_r tends to cause tower resonance more frequently compared to when turbulence is higher. This explains the higher PSD magnitude of \dot{x} about ω_n (gray dashed lines) during low turbulence with respect to its higher turbulent counterpart. Regarding controllers' activity, results consistent with the previous steady wind simulations are observed in the two turbulence cases. In the time series, C_{conv} is shown to perform less effectively than when operated in conjunction with MDCs. In terms of load reduction, C_{conv} with $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$ performs best. More benign control action is exercised when $C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$ is incorporated but resultingly, slightly less reduction in tower fatigue load is performed.

The capabilities of the MDCs to follow and cancel the varying 1P periodic load frequency are shown best by the high turbulence case, where 1P frequency varies more and covers a wider range than in low turbulence. This is most evident in the PSD result of \dot{x} , lower frequency content with respect to C_{conv} is evident not only at ω_n but also at the surrounding frequencies. In the PSD plot of $\Delta T_{g,\text{total}}$ in Fig. 14(b), multiple peaks at 0.6, 0.63, 0.74, and 0.78 rad/s are seen for the cascaded controller settings, apart from that at ω_n . This indicates intensive 1P load reduction activity at the said frequencies, which are virtually nonexistent except at 0.74 rad/s for the C_{conv} setting.

A statistical evaluation of the measurement data from the simulations is done in terms of standard deviations. Table II summarizes those of the side-side tower velocity $\sigma_{\dot{x}}$, total additive generator torque $\sigma_{\Delta T_{g,\text{total}}}$, and generated power σ_{P_g} . Respectively, these values indicate changes in the side-side tower fatigue load, controller activity, and power fluctuation. While the tower load control methods aim to mitigate side-side tower load, its influence on the fore-aft tower load is also of interest; therefore, the standard deviation of the fore-aft tower velocity $\sigma_{\dot{x}_{\text{fa}}}$ is also computed. For the sake of completeness, the mean generated power μ_{P_g} is used to assess changes in the average power production due to the controllers' activities. Upward (\uparrow) and downward (\downarrow) arrows are used to indicate standard deviation and mean values that are higher and lower with respect to the uncontrolled turbine. The overall computed $\sigma_{\dot{x}}$ and $\sigma_{\Delta T_{g,\text{total}}}$ for both turbulent cases point to the same conclusion as the time series and PSD results. Best fatigue load reduction, shown by the least $\sigma_{\dot{x}}$ values, is achieved by C_{conv} and $C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$, the control action of which is also the most active, as indicated by the corresponding $\sigma_{\Delta T_{g,\text{total}}}$. With respect to this configuration, C_{conv} and $C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$ are able to compromise between the actuation effort and load mitigation, shown by their milder





Fig. 14. (a) Time series and (b) PSD results of the turbulent wind cases. Cascaded conventional tower damper and MDCs outperform the conventional controller without MDCs in both low and high turbulence. For $v_h = 6.25$ m/s, different turbulence intensities influence the prevalence of resonances, as shown in (a), thereby affecting the PSD content about $\omega_{n,s} = 0.6963$ rad/s (gray dashed lines) in (b). Greater variation in the 1P frequency during high turbulence results in the cascaded controllers actively operating in a wider frequency range to mitigate the periodic load, shown clearly in the PSD of $\Delta T_{g,\text{total}}$.

$\sigma_{\Delta T_{g,\text{total}}}$ from which slightly lower $\sigma_{\dot{x}}$ is obtained. Again, C_{conv} shows the least increase in $\sigma_{\Delta T_{g,\text{total}}}$ with respect to the uncontrolled case, but also the least load reduction among other controller setups. Results from $\sigma_{\dot{x}_{\text{fa}}}$ computation indicate that the side-side tower load controllers only affect slightly the fore-aft tower motion, in contrast to $\sigma_{\dot{x}}$. As torque fluctuation

TABLE II

STANDARD DEVIATIONS OF SIDE-SIDE TOWER VELOCITY $\sigma_{\dot{x}_i}$, FORE-AFT TOWER VELOCITY $\sigma_{\dot{x}_{fa}}$, TOTAL ADDITIVE GENERATOR TORQUE $\sigma_{\Delta T_{g,\text{total}}}$, AND GENERATED POWER σ_{P_g} , AS WELL AS MEAN GENERATED POWER μ_{P_g} FOR THE TURBULENT WIND CASES

I_T (%)	Controller	$\sigma_{\dot{x}_i}$ (m/s)	$\sigma_{\dot{x}_{fa}}$ (m/s)	$\sigma_{\Delta T_{g,\text{total}}}$ (kNm)	σ_{P_g} (kW)	μ_{P_g} (kW)
4	Uncontrolled	0.646	0.018	0	67.924	825.023
	C_{conv}	↓ 0.126	↓ 0.013	↑ 1.263	↑ 113.249	↑ 825.708
	$C_{\text{conv}} \& C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$	↓ 0.016	↓ 0.015	↑ 1.638	↑ 132.500	↑ 825.769
	$C_{\text{conv}} \& C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$	↓ 0.041	↓ 0.014	↑ 1.476	↑ 123.685	↑ 825.775
12	Uncontrolled	0.393	0.021	0	201.579	842.690
	C_{conv}	↓ 0.095	↓ 0.020	↑ 0.945	↑ 212.809	↓ 842.662
	$C_{\text{conv}} \& C_{m,2}(s, \omega_r, \psi_{\text{off}}^*)$	↓ 0.041	↑ 0.023	↑ 1.953	↑ 245.641	↑ 842.828
	$C_{\text{conv}} \& C_{m,3}(s, \omega_r, \psi_{\text{off}}^*)$	↓ 0.047	0.021	↑ 1.525	↑ 229.328	↑ 842.716

↑ / ↓: increase/decrease w.r.t. uncontrolled wind turbine.

affects the generator power due to their proportional relation, the trend of σ_{P_g} follows that of $\sigma_{\Delta T_{g,\text{total}}}$. Important to note here is during the high turbulence, generated power fluctuates more due to the high variation in the wind, thus the much higher overall standard deviation with respect to the low turbulence case. Improvements in terms of power fluctuation may be achieved by utilization of individual blade pitching in place of additive generator torque due to the less coupling with the generator power [37]. However, implementing side-side tower periodic load cancellation by individual blade pitching methods is outside the scope of this article and is a subject of future work. That said, the computed μ_{P_g} shows that the controllers do not lead to significant changes in the average power production, which indicates that the proposed method can still be desirable. Having the simulation results analyzed, the conclusions of this work are drawn in Section VII.

VII. CONCLUSION

In this article, an MDC framework for the cancellation of 1P periodic loading acting on wind turbine side-side tower motion has been proposed. The framework relies on the modulation of input and demodulation of output signals at the periodic load frequency, resulting in each signal being representable in its quadrature and in-phase components. Convenient yet effective diagonal LTI controllers are designed onto these channels, representable as an LTV when combined with the modulation-demodulation. MIMO representation of the plant has also been rendered in terms of the quadrature and in-phase channels, which, by frequency-domain analysis, has been shown to contain cross-coupling at steady-state and instability-inducing gain sign flip. A phase offset, the optimal value of which is defined as the negative of the nominal plant's phase at the 1P frequency, has been shown to be a remedy for both the cross-coupling and gain sign flip issues. Simulations at two different levels of fidelity have been conducted to demonstrate the effectiveness of two proposed MDC designs, being undamped and damped inverted notch filters centered at the 1P frequency. Low-fidelity simulations exhibited the controllers' performance deterioration and instability when the optimal phase offset was not incorporated. OpenFAST was employed to simulate steady and turbulent wind cases in a higher-fidelity setting, in which the MDCs are cascaded with a conventional tower damping controller. Results have

indicated a performance improvement of the conventional controller in fatigue load reduction when the MDCs are operated synergetically. The conventional tower damper has been shown to mitigate only the tower's natural frequency, while the MDCs target the 1P periodic loading caused by a mass imbalance in the rotor disk. Suggestions for future work include combining MDC and frequency-skipping methods, incorporating individual blade pitching for periodic side-side tower load cancellation, and implementation for canceling higher harmonic structural loads such as 3P for three-bladed turbines.

REFERENCES

- [1] P. Veers et al., "Grand challenges in the science of wind energy," *Science*, vol. 366, Oct. 2019, Art. no. eaau2027.
- [2] K. Dykes, R. Damiani, O. Roberts, and E. Lantz, "Analysis of ideal towers for tall wind applications," Nat. Renew. Energy Lab. (NREL), Golden, CO, USA, Tech. Rep. NREL/CP-5000-70642, Jan. 2018.
- [3] R. Ramlau and J. Niebsch, "Imbalance estimation without test masses for wind turbines," *J. Sol. Energy Eng.*, vol. 131, no. 1, Feb. 2009, Art. no. 011010.
- [4] M. Saathoff, M. Rosemeier, T. Kleinselbeck, and B. Rathmann, "Effect of individual blade pitch angle misalignment on the remaining useful life of wind turbines," *Wind Energy Sci.*, vol. 6, no. 5, pp. 1079–1087, Sep. 2021.
- [5] T. Burton, N. Jenkins, D. Sharpe, and E. Bossanyi, *Wind Energy Handbook*. Chichester, U.K.: Wiley, May 2011.
- [6] E. A. Bossanyi, "Wind turbine control for load reduction," *Wind Energy*, vol. 6, no. 3, pp. 229–244, Jul. 2003.
- [7] J. Licari, J. B. Ekanayake, and N. Jenkins, "Investigation of a speed exclusion zone to prevent tower resonance in variable-speed wind turbines," *IEEE Trans. Sustain. Energy*, vol. 4, no. 4, pp. 977–984, Oct. 2013.
- [8] E. Smilden and A. J. Sørensen, "Application of a speed exclusion zone algorithm on a large 10MW offshore wind turbine," in *Proc. ASME 35th Int. Conf. Ocean, Offshore Arctic Eng. Amer. Soc. Mech. Eng. Digit. Collection*, Oct. 2016, pp. 1–12.
- [9] S. P. Mulders, T. G. Hovgaard, J. D. Grunnet, and J. W. van Wingerden, "Preventing wind turbine tower natural frequency excitation with a quasi-LPV model predictive control scheme," *Wind Energy*, vol. 23, pp. 627–644, Mar. 2020.
- [10] E. L. van der Hooff, P. Schaak, and T. van Engelen, "Wind turbine control algorithms," ECN, The Netherlands, Tech. Rep. Ecn-C-03-111, vols. DOWEC-F1W1, pp. 1–89, Dec. 2003.
- [11] A. D. Wright and L. J. Fingersh, "Advanced control design for wind turbines; Part I: Control design, implementation, and initial tests," NREL, Golden, CO, USA, Tech. Rep. NREL/TP-500-42437, 927269, Mar. 2008.
- [12] Z. Zhang, S. Nielsen, F. Blaabjerg, and D. Zhou, "Dynamics and control of lateral tower vibrations in offshore wind turbines by means of active generator torque," *Energies*, vol. 7, no. 11, pp. 7746–7772, Nov. 2014.

- [13] M. Bodson, A. Sacks, and P. Khosla, "Harmonic generation in adaptive feedforward cancellation schemes," *IEEE Trans. Autom. Control*, vol. 39, no. 9, pp. 1939–1944, Sep. 1994.
- [14] M. F. Byl, S. J. Ludwick, and D. L. Trumper, "A loop shaping perspective for tuning controllers with adaptive feedforward cancellation," *Precis. Eng.*, vol. 29, no. 1, pp. 27–40, Jan. 2005.
- [15] K. Lau, D. E. Quevedo, B. J. G. Vautier, G. C. Goodwin, and S. O. R. Moheimani, "Design of modulated and demodulated controllers for flexible structures," *Control Eng. Pract.*, vol. 15, no. 3, pp. 377–388, Mar. 2007.
- [16] K. Lau, G. C. Goodwin, and R. T. M'Closkey, "Properties of modulated and demodulated systems with implications to feedback limitations," *Automatica*, vol. 41, no. 12, pp. 2123–2129, Dec. 2005.
- [17] A. H. Sacks, M. Bodson, and W. Messner, "Advanced methods for repeatable runout compensation [disc drives]," *IEEE Trans. Magn.*, vol. 31, no. 2, pp. 1031–1036, Mar. 1995.
- [18] K. B. Ariyur and M. Krstic, "Feedback attenuation and adaptive cancellation of blade vortex interaction on a helicopter blade element," *IEEE Trans. Control Syst. Technol.*, vol. 7, no. 5, pp. 596–605, Sep. 1999.
- [19] Y. Xu, M. de Mathelin, and D. Knittel, "Adaptive rejection of quasi-periodic tension disturbances in the unwinding of a non-circular roll," in *Proc. Amer. Control Conf.*, vol. 5, May 2002, pp. 4009–4014.
- [20] H. Zhong, V. Kulkarni, and L. Pao, "Adaptive control for rejecting disturbances with time-varying frequencies in tape systems," in *Proc., Amer. Control Conf.*, vol. 1, 2005, pp. 533–538.
- [21] E. A. Bossanyi, "Individual blade pitch control for load reduction," *Wind Energy*, vol. 6, no. 2, pp. 119–128, Apr. 2003.
- [22] G. Bir, "Multi-blade coordinate transformation and its application to wind turbine analysis," in *Proc. ASME Wind Energy Symp.*, Jan. 2008, pp. 1–15.
- [23] R. Ungurán et al., "Feedback-feedforward individual pitch control design for wind turbines with uncertain measurements," in *Proc. Amer. Control Conf. (ACC)*, Jul. 2019, pp. 4151–4158.
- [24] S. P. Mulders, A. K. Pamososuryo, G. E. Disario, and J. V. Wingerden, "Analysis and optimal individual pitch control decoupling by inclusion of an azimuth offset in the multiblade coordinate transformation," *Wind Energy*, vol. 22, no. 3, pp. 341–359, Mar. 2019.
- [25] K. Selvam, S. Kanev, J. W. van Wingerden, T. van Engelen, and M. Verhaegen, "Feedback-feedforward individual pitch control for wind turbine load reduction," *Int. J. Robust Nonlinear Control*, vol. 19, no. 1, pp. 72–91, Jan. 2009.
- [26] A. K. Pamososuryo, S. Paul Mulders, R. Ferrari, and J.-W. van Wingerden, "Periodic load estimation of a wind turbine tower using a model demodulation transformation," in *Proc. Amer. Control Conf. (ACC)*, Jun. 2022, pp. 5271–5276.
- [27] E. A. Bossanyi, "The design of closed loop controllers for wind turbines," *Wind Energy*, vol. 3, no. 3, pp. 149–163, Jul. 2000.
- [28] L. Brandetti, S. P. Mulders, Y. Liu, S. Watson, and J.-W. van Wingerden, "Analysis and multi-objective optimisation of wind turbine torque control strategies," *Wind Energy Sci.*, vol. 8, no. 10, pp. 1553–1573, Oct. 2023.
- [29] M. Steinbuch, "Repetitive control for systems with uncertain period-time," *Automatica*, vol. 38, no. 12, pp. 2103–2109, Dec. 2002.
- [30] Y. Liu, R. Ferrari, and J.-W. van Wingerden, "Load reduction for wind turbines: An output-constrained, subspace predictive repetitive control approach," *Wind Energy Sci.*, vol. 7, no. 2, pp. 523–537, Mar. 2022.
- [31] S. Skogestad and I. Postlethwaite, *Multivariable Feedback Control: Analysis and Design*. Hoboken, NJ, USA: Wiley, 2005.
- [32] W. Messner and M. Bodson, "Design of adaptive feedforward algorithms using internal model equivalence," *Int. J. Adapt. Control Signal Process.*, vol. 9, no. 2, pp. 199–212, Mar. 1995.
- [33] *Openfast/Openfast: Openfast V3.0.0*, NREL, Golden, CO, USA, Jun. 2021.
- [34] J. Jonkman, S. Butterfield, W. Musial, and G. Scott, "Definition of a 5-MW reference wind turbine for offshore system development," Nat. Renew. Energy Lab. (NREL), Golden, CO, USA, Tech. Rep. NREL/TP-500-38060, 2009.
- [35] C. Hendrickson and R. T. M'Closkey, "Phase compensation strategies for modulated-demodulated control with application to pulsed jet injection," *J. Dyn. Syst., Meas., Control*, vol. 134, no. 1, Jan. 2012, Art. no. 011024.
- [36] *Wind Turbines Part 1: Design Requirements*, document IEC 61400-1, Int. Electrotechnical Commission, 2005.
- [37] A. Pamososuryo, Y. Liu, T. Hovgaard, R. Ferrari, and J. van Wingerden, "Individual pitch control by convex economic model predictive control for wind turbine side-side tower load alleviation," *J. Phys., Conf. Ser.*, vol. 2265, no. 3, May 2022, Art. no. 032071.



Atindriyo K. Pamososuryo was born in Medan, Indonesia, in 1991. He received the M.Sc. degree from Delft Center for Systems and Control, Delft University of Technology, Delft, The Netherlands, in 2018, where he is currently pursuing the Ph.D. degree.

His research interests include but are not limited to, dynamical system modeling, state estimation, linear parameter varying systems, and model-predictive control. In particular, his main focus is on the applications in the wind energy field for advancements in load reduction and power production capabilities at the wind turbine level, in which he also collaborated with Vestas Wind Systems A/S, Denmark.

Mr. Pamososuryo received the O. Howard Schuck Award from the American Automatic Control Council for his contribution to the applied control engineering field in 2023.



Sebastiaan P. Mulders (Member, IEEE) received the M.Sc. degree in systems and control and the Ph.D. degree in wind turbine control from Delft University of Technology, Delft, The Netherlands, in 2015 and 2020, respectively.

Since 2021, he has been a Post-Doctoral Researcher on the development of learning algorithms for wind turbine controllers with Delft University of Technology, where he has also been an Assistant Professor since 2022. His main research interest is in data-enabled control codesign. The codesign approach is supported by machine learning techniques for the synergetic and efficient optimization of the system and controller to reach higher performance levels for present-day complex systems with increased levels of interactions.



Riccardo Ferrari (Senior Member, IEEE) received the Laurea and Ph.D. degrees from the University of Trieste, Trieste, Italy, in 2004 and 2009, respectively.

He held both academic and industrial research and development positions, in particular as a researcher in the field of process instrumentation and control for the steel-making sector. He is a Marie Curie Alumnus and currently an Associate Professor with Delft Center for Systems and Control, Delft University of Technology, Delft, The Netherlands. His research interests include fault-tolerant control and fault diagnosis and attack detection in large-scale cyber-physical systems, with applications to wind energy generation, electric mobility, and cooperative autonomous vehicles.



Jan-Willem van Wingerden (Senior Member, IEEE) was born in Ridderkerk, The Netherlands, in 1980. He received the B.S. and Ph.D. (cum laude) degrees in mechanical engineering and in control engineering from Delft Center for Systems and Control, Delft University of Technology, Delft, The Netherlands, in 2004 and 2008, respectively. His Ph.D. thesis was titled Smart Dynamic Rotor Control for Large Offshore Wind Turbines.

He is currently a Full Professor with Delft University of Technology. His current research interest is mainly centered on the development of data-driven controllers for wind turbines and wind farms.